

Final Interoperability Test Report

FIT #: **97**
 Date: 5/16/2023
 Location: DNV-GL,Arnhem, Netherlands
 Page 1 of 29

APPLICANT

Company: EDMI Limited

Address: 47 Yishun Industrial Park A, 768724 Yishun, Singapore

DEVICE

Device type	Mk10M	
<i>Type indication on MID certificate</i>		<i>MID Certificate No.</i>
Mk10M		T11583
<i>IDIS Specification reference</i>	<i>DNV-gl IDIS Certification run No</i>	<i>Digital signature of the test report.</i>
Package 2 ed. 2.0	2084	20A4D68454CF5DE7C4B0F411BE0FB14A
<i>First certification</i>	<i>IDIS Label</i>	<i>Modular device</i>
<input checked="" type="checkbox"/>	0096	<input type="checkbox"/>
<i>General information about the device</i>		
Polyphase Meter		

FIRMWARE VERSIONS TESTED

				<i>Final Interoperability Test No. 97</i>
Firmware No.	Firmware ID1	Firmware ID2	Firmware ID3	Verdict
1	\2.H.7-281222B003	\2.H.7-05A222A006	\BOOT221D	Passed

Honeywell

Iskraemeco d.d.

Itron

Landis+Gyr AG

Fit #97

Device:EDMI Mk10M

DNV-GL, Arnhem, Netherlands, 16.05.2023

Page 2 of 29

FIRMWARE VERSIONS HISTORY				<i>Final Integration Test</i>	
Firmware No.	Firmware ID1	Firmware ID2	Firmware ID3	No.	Verdict
1	\2.H.7-281222B003	\2.H.7-05A222A006	\BOOT221D	97	Passed

TEST REPORT - Firmware No. 1		
<i>Test</i>	<i>Verdict</i>	<i>Remark</i>
Connect and release	Passed	
All Device IDs	Passed	
COSEM logical device name	Passed	
SAP assignment	Passed	
FW version and signature	Passed	
All Device ID's	Passed	
Broadcast Date and time	Passed	
Broadcast Special Days Table	Passed	
Event logs	Passed	
Billing data period 1	Passed	
M-Bus Channel Setup	Not Tested	Only one M-Bus Master Port in use
M-Bus Results	Not Tested	
M-Bus Devices IDs	Not Tested	
M-Bus profiles	Not Tested	
M-Bus Load profiles	Not Tested	
M-Bus control logs	Not Tested	
M-Bus Disconnect log	Not Tested	
FIT Push	Passed	Power Off Push N/A
FIT Miscellaneous	Passed	FIT Wake Up Not Supported
Optical Port Connectivity	Passed	
Consumer Information Interface	Passed	

FIT Conformance Test Report

```

*****
IDIS Conformance test report
04-MAY-2023 12:33:28
iCTT2 Package 2, Edition 2.0, Revision 1 (136)
Licensed to: KEMA-IDIS Cert.
Tester: Tom Levels
*****

*****
* Identification *
*****

Manufacturer = {
  Name = '\EDMI Ltd.'
  ThreeLettersId = '\EDM'
}
DeviceUnderTest = {
  Type = '\IM130-00A0-10211-1000-002-051'
  IDISDeviceType = 103
  IDISFunctionType = [EXTENSION_D]
  SerialNr = 51400057
  IPVersion = IPV4
  DataLinkLayer = GPRS
  ConsumerInformationPush = FALSE
  SMSSupported = FALSE
  ClipCallSupported = FALSE
}

Active firmware identifier (1-0:0.2.0.255) = \2.H.7-281222B003
Active firmware identifier 1 (1-1:0.2.0.255) = \2.H.7-05A222A006

```



```

        <OctetString Value="\5" />
    </Data>

Mngmt Get Device ID 6, IDIS certification number 0-0:96.1.5.255 (@66)
(11) .logical_name PASSED
    <Data>
        <OctetString Value="0000600105FF" />
    </Data>
(12) .value PASSED
    <Data>
        <OctetString Value="" />
    </Data>

*****
Test Case 3 : Read COSEM Logical Device Name, 2 item(s)
*****

Mngmt Get COSEM logical device name 0-0:42.0.0.255 (@42)
(1) .logical_name PASSED
    <Data>
        <OctetString Value="00002A0000FF" />
    </Data>
(2) .value PASSED
    <Data>
        <OctetString Value="\EDM1030151400057" />
    </Data>

*****
Test Case 4 : Read SAP Assignment, 2 item(s)
*****

Mngmt Get SAP Assignment 0-0:41.0.0.255 (@4)
(1) .logical_name PASSED
    <Data>
        <OctetString Value="0000290000FF" />
    </Data>
(2) .SAP_assignment_list PASSED
    <Data>
        <Array Qty="0001" >
            <Structure Qty="0002" >
                <LongUnsigned Value="0001" />
                <OctetString Value="\EDM1030151400057" />
            </Structure>
        </Array>
    </Data>

*****
Test Case 5 : Read Active FW Version, 12 item(s)
*****

Mngmt Get Active firmware identifier 1-0:0.2.0.255 (@412)
(1) .logical_name PASSED
    <Data>
        <OctetString Value="0100000200FF" />
    </Data>
(2) .value PASSED
    <Data>
        <OctetString Value="\2.H.7-281222B003" />
    </Data>

Mngmt Get Active firmware signature 1-0:0.2.8.255 (@416)
(3) .logical_name PASSED
    <Data>
        <OctetString Value="0100000208FF" />
    </Data>
(4) .value PASSED
    <Data>
        <OctetString
Value="4ADA6982049139C697EF4762E20470A493E6B7853251BD2B987C66129C7756DA4832EC8F4CA8B2F0649386
74FFE8CC3A6F7FE1997EDF35BC91F5D55C9EAFB498" />
    </Data>

Mngmt Get Active firmware identifier 1 1-1:0.2.0.255 (@420)

```

(5) .logical_name	PASSED
<pre> <Data> <OctetString Value="0101000200FF" /> </Data> </pre>	
(6) .value	PASSED
<pre> <Data> <OctetString Value="\2.H.7-05A222A006" /> </Data> </pre>	
Mngmt Get Active firmware signature 1 1-1:0.2.8.255 (@424)	
(7) .logical_name	PASSED
<pre> <Data> <OctetString Value="0101000208FF" /> </Data> </pre>	
(8) .value	PASSED
<pre> <Data> <OctetString Value="D48561D57860FD30172418D94241E92C2C8AD9CC49B875273F0CEC311C149119320EB2F72BAD4E5311A282 E489AC0971A8B88AD4688206B83D240A01542B63CF" /> </Data> </pre>	
Mngmt Get Active firmware identifier 2 1-2:0.2.0.255 (@428)	
(9) .logical_name	PASSED
<pre> <Data> <OctetString Value="0102000200FF" /> </Data> </pre>	
(10) .value	PASSED
<pre> <Data> <OctetString Value="\BOOT221D" /> </Data> </pre>	
Mngmt Get Active firmware signature 2 1-2:0.2.8.255 (@432)	
(11) .logical_name	PASSED
<pre> <Data> <OctetString Value="0102000208FF" /> </Data> </pre>	
(12) .value	PASSED
<pre> <Data> <OctetString Value="33A894A77AB45242B1FC9FDF0130E677DA0576CE17CD79B1A591112568E44B00C298B907CE6D72D1ED27A A59E41B97B7F304683628DAA41557180B69715B2DE" /> </Data> </pre>	
<pre> ***** Test Case 6 : Set Clock, 1 item(s) ***** </pre>	
Pre Set Clock 0-0:1.0.0.255 (@75)	
(1) .time	PASSED
<pre> <Data> <OctetString Value="07E70504FF100000FF8000FF" /> </Data> </pre>	
<pre> ***** Test Case 7 : Get Clock, 1 item(s) ***** </pre>	
Mngmt Get Clock 0-0:1.0.0.255 (@75)	
(1) .time	PASSED
<pre> <Data> <OctetString Value="07E705040410000000FF8880" /> </Data> </pre>	
<pre> ***** Test Case 8 : Set Special Days, 1 item(s) ***** </pre>	
Pre Set Special Days Table 0-0:11.0.0.255 (@125)	
(1) .entries	PASSED
<pre> <Data> <Array Qty="001E" > <Structure Qty="0003" > <LongUnsigned Value="001E" /> </pre>	

```

    <OctetString Value="FFFF0101FF" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0003" >
    <LongUnsigned Value="001D" />
    <OctetString Value="FFFF0102FF" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0003" >
    <LongUnsigned Value="001C" />
    <OctetString Value="FFFF0103FF" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0003" >
    <LongUnsigned Value="001B" />
    <OctetString Value="FFFF0104FF" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0003" >
    <LongUnsigned Value="001A" />
    <OctetString Value="FFFF0105FF" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0003" >
    <LongUnsigned Value="0019" />
    <OctetString Value="FFFF0106FF" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0003" >
    <LongUnsigned Value="0018" />
    <OctetString Value="FFFF0107FF" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0003" >
    <LongUnsigned Value="0017" />
    <OctetString Value="FFFF0108FF" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0003" >
    <LongUnsigned Value="0016" />
    <OctetString Value="FFFF0109FF" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0003" >
    <LongUnsigned Value="0015" />
    <OctetString Value="FFFF010AFF" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0003" >
    <LongUnsigned Value="0014" />
    <OctetString Value="FFFF0201FF" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0003" >
    <LongUnsigned Value="0013" />
    <OctetString Value="FFFF0202FF" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0003" >
    <LongUnsigned Value="0012" />
    <OctetString Value="FFFF0203FF" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0003" >
    <LongUnsigned Value="0011" />
    <OctetString Value="FFFF0204FF" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0003" >
    <LongUnsigned Value="0010" />
    <OctetString Value="FFFF0205FF" />
    <Unsigned Value="02" />
  </Structure>

```

```

<Structure Qty="0003" >
  <LongUnsigned Value="000F" />
  <OctetString Value="FFFF0206FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="000E" />
  <OctetString Value="FFFF0207FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="000D" />
  <OctetString Value="FFFF0208FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="000C" />
  <OctetString Value="FFFF0209FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="000B" />
  <OctetString Value="FFFF020AFF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="000A" />
  <OctetString Value="FFFF0301FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0009" />
  <OctetString Value="FFFF0302FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0008" />
  <OctetString Value="FFFF0303FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0007" />
  <OctetString Value="FFFF0304FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0006" />
  <OctetString Value="FFFF0305FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0005" />
  <OctetString Value="FFFF0306FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0004" />
  <OctetString Value="FFFF0307FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0003" />
  <OctetString Value="FFFF0308FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0002" />
  <OctetString Value="FFFF0309FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0001" />
  <OctetString Value="FFFF030AFF" />

```



```

        <Unsigned Value="02" />
    </Structure>
</Array>
</Data>

*****
Test Case 9 : Get Special Days, 1 item(s)
*****

Mngmt Get Special Days Table 0-0:11.0.0.255 (@125)
(1) .entries
    <Data>
        <Array Qty="001E" >
            <Structure Qty="0003" >
                <LongUnsigned Value="001E" />
                <OctetString Value="FFFF0101FF" />
                <Unsigned Value="02" />
            </Structure>
            <Structure Qty="0003" >
                <LongUnsigned Value="001D" />
                <OctetString Value="FFFF0102FF" />
                <Unsigned Value="02" />
            </Structure>
            <Structure Qty="0003" >
                <LongUnsigned Value="001C" />
                <OctetString Value="FFFF0103FF" />
                <Unsigned Value="02" />
            </Structure>
            <Structure Qty="0003" >
                <LongUnsigned Value="001B" />
                <OctetString Value="FFFF0104FF" />
                <Unsigned Value="02" />
            </Structure>
            <Structure Qty="0003" >
                <LongUnsigned Value="001A" />
                <OctetString Value="FFFF0105FF" />
                <Unsigned Value="02" />
            </Structure>
            <Structure Qty="0003" >
                <LongUnsigned Value="0019" />
                <OctetString Value="FFFF0106FF" />
                <Unsigned Value="02" />
            </Structure>
            <Structure Qty="0003" >
                <LongUnsigned Value="0018" />
                <OctetString Value="FFFF0107FF" />
                <Unsigned Value="02" />
            </Structure>
            <Structure Qty="0003" >
                <LongUnsigned Value="0017" />
                <OctetString Value="FFFF0108FF" />
                <Unsigned Value="02" />
            </Structure>
            <Structure Qty="0003" >
                <LongUnsigned Value="0016" />
                <OctetString Value="FFFF0109FF" />
                <Unsigned Value="02" />
            </Structure>
            <Structure Qty="0003" >
                <LongUnsigned Value="0015" />
                <OctetString Value="FFFF010AFF" />
                <Unsigned Value="02" />
            </Structure>
            <Structure Qty="0003" >
                <LongUnsigned Value="0014" />
                <OctetString Value="FFFF0201FF" />
                <Unsigned Value="02" />
            </Structure>
            <Structure Qty="0003" >
                <LongUnsigned Value="0013" />
                <OctetString Value="FFFF0202FF" />
                <Unsigned Value="02" />
            </Structure>
        </Array>
    </Data>

```

PASSED

```

<Structure Qty="0003" >
  <LongUnsigned Value="0012" />
  <OctetString Value="FFFF0203FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0011" />
  <OctetString Value="FFFF0204FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0010" />
  <OctetString Value="FFFF0205FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="000F" />
  <OctetString Value="FFFF0206FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="000E" />
  <OctetString Value="FFFF0207FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="000D" />
  <OctetString Value="FFFF0208FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="000C" />
  <OctetString Value="FFFF0209FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="000B" />
  <OctetString Value="FFFF020AFF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="000A" />
  <OctetString Value="FFFF0301FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0009" />
  <OctetString Value="FFFF0302FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0008" />
  <OctetString Value="FFFF0303FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0007" />
  <OctetString Value="FFFF0304FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0006" />
  <OctetString Value="FFFF0305FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0005" />
  <OctetString Value="FFFF0306FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0004" />
  <OctetString Value="FFFF0307FF" />

```

```

        <Unsigned Value="02" />
    </Structure>
    <Structure Qty="0003" >
        <LongUnsigned Value="0003" />
        <OctetString Value="FFFF0308FF" />
        <Unsigned Value="02" />
    </Structure>
    <Structure Qty="0003" >
        <LongUnsigned Value="0002" />
        <OctetString Value="FFFF0309FF" />
        <Unsigned Value="02" />
    </Structure>
    <Structure Qty="0003" >
        <LongUnsigned Value="0001" />
        <OctetString Value="FFFF030AFF" />
        <Unsigned Value="02" />
    </Structure>
</Array>
</Data>

```

 Test Case 10 : Read Event Log Buffers, 20 item(s)

```

Mngmt Get Disconnecter Control Log 0-0:99.98.2.255 (@193)
(1) .logical_name PASSED
    <Data>
        <OctetString Value="0000636202FF" />
    </Data>
(2) .buffer PASSED
    Earliest date: 13-OCT-2022 09:10:00, latest date: 04-MAY-2023 12:10:00
    Middle date: 13-OCT-2022 12:10:19
(3) .entries_in_use PASSED
    <Data>
        <DoubleLongUnsigned Value="0000002F" />
    </Data>
(4) .profile_entries PASSED
    <Data>
        <DoubleLongUnsigned Value="00000096" />
    </Data>

Mngmt Get Standard Event Log 0-0:99.98.0.255 (@301)
(5) .logical_name PASSED
    <Data>
        <OctetString Value="0000636200FF" />
    </Data>
(6) .buffer PASSED
    Earliest date: 11-OCT-2022 23:59:50, latest date: 27-OCT-2024 03:15:25
    Middle date: 04-MAY-2023 16:05:34
(7) .entries_in_use PASSED
    <Data>
        <DoubleLongUnsigned Value="00000096" />
    </Data>
(8) .profile_entries PASSED
    <Data>
        <DoubleLongUnsigned Value="00000096" />
    </Data>

Mngmt Get Fraud Detection Log 0-0:99.98.1.255 (@316)
(9) .logical_name PASSED
    <Data>
        <OctetString Value="0000636201FF" />
    </Data>
(10) .buffer PASSED
    Earliest date: 13-OCT-2022 09:10:00, latest date: 04-MAY-2023 16:03:53
    Middle date: 13-OCT-2022 11:24:18
(11) .entries_in_use PASSED
    <Data>
        <DoubleLongUnsigned Value="0000002B" />
    </Data>
(12) .profile_entries PASSED
    <Data>
        <DoubleLongUnsigned Value="00000096" />
    </Data>

```

```

    </Data>

Mngmt Get Communication Log 0-0:99.98.5.255 (@331)
(13) .logical_name PASSED
    <Data>
        <OctetString Value="0000636205FF" />
    </Data>
(14) .buffer PASSED
    Earliest date: 13-OCT-2022 10:11:47, latest date: 04-MAY-2023 18:41:49
    Middle date: 04-MAY-2023 16:37:20
(15) .entries_in_use PASSED
    <Data>
        <DoubleLongUnsigned Value="00000096" />
    </Data>
(16) .profile_entries PASSED
    <Data>
        <DoubleLongUnsigned Value="00000096" />
    </Data>

Mngmt Get Power Quality Log 0-0:99.98.4.255 (@1340)
(17) .logical_name PASSED
    <Data>
        <OctetString Value="0000636204FF" />
    </Data>
(18) .buffer PASSED
    Earliest date: 13-OCT-2022 09:10:00, latest date: 04-MAY-2023 16:30:48
    Middle date: 13-OCT-2022 12:45:36
(19) .entries_in_use PASSED
    <Data>
        <DoubleLongUnsigned Value="0000001B" />
    </Data>
(20) .profile_entries PASSED
    <Data>
        <DoubleLongUnsigned Value="00000096" />
    </Data>

*****
Test Case 11 : Reading Data of Billing Period 1, 8 item(s)
*****

Mngmt Get Data of billing period 1 0-0:98.1.0.255 (@158)
(1) .logical_name PASSED
    <Data>
        <OctetString Value="0000620100FF" />
    </Data>
(2) .buffer PASSED
    Earliest date: 02-NOV-2022 00:00:00, latest date: 02-NOV-2024 00:00:00
    Middle date: 02-MAY-2023 00:00:00
(3) .capture_objects PASSED
    <Data>
        <Array Qty="0005" >
            <Structure Qty="0004" >
                <LongUnsigned Value="0008" />
                <OctetString Value="0000010000FF" />
                <Integer Value="02" />
                <LongUnsigned Value="0000" />
            </Structure>
            <Structure Qty="0004" >
                <LongUnsigned Value="0003" />
                <OctetString Value="0100010801FF" />
                <Integer Value="02" />
                <LongUnsigned Value="0000" />
            </Structure>
            <Structure Qty="0004" >
                <LongUnsigned Value="0003" />
                <OctetString Value="0100010802FF" />
                <Integer Value="02" />
                <LongUnsigned Value="0000" />
            </Structure>
            <Structure Qty="0004" >
                <LongUnsigned Value="0003" />
                <OctetString Value="0100020801FF" />
                <Integer Value="02" />
            </Structure>
        </Array>
    </Data>

```

```

        <LongUnsigned Value="0000" />
    </Structure>
    <Structure Qty="0004" >
        <LongUnsigned Value="0003" />
        <OctetString Value="0100020802FF" />
        <Integer Value="02" />
        <LongUnsigned Value="0000" />
    </Structure>
    </Array>
</Data>
(4) .capture_period PASSED
    <Data>
        <DoubleLongUnsigned Value="00000000" />
    </Data>
(5) .sort_method PASSED
    <Data>
        <Enum Value="01" />
    </Data>
(6) .sort_object PASSED
    <Data>
        <Structure Qty="0004" >
            <LongUnsigned Value="0000" />
            <OctetString Value="000000000000" />
            <Integer Value="00" />
            <LongUnsigned Value="0000" />
        </Structure>
    </Data>
(7) .entries_in_use PASSED
    <Data>
        <DoubleLongUnsigned Value="0000000C" />
    </Data>
(8) .profile_entries PASSED
    <Data>
        <DoubleLongUnsigned Value="00000012" />
    </Data>

```

```

*****
Test Case 12 : Ext. M - M-Bus Setup LGZ G350, 52 item(s)
*****

```

```

Mngmt Get M-Bus master port setup 1 0-0:24.6.0.255 (@1566)
(1) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(2) .comm_speed
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus master port setup 2 0-1:24.6.0.255 (@1570)
(3) .logical_name
INAPPLICABLE
    Optional object is not implemented
(4) .comm_speed
INAPPLICABLE
    Optional object is not implemented

Mngmt Get M-Bus client channel 1 0-1:24.1.0.255 (@1574)
(5) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(6) .mbus_port_reference
INAPPLICABLE
    Object is not required according to OM and/or extensions
(7) .capture_definition
INAPPLICABLE
    Object is not required according to OM and/or extensions
(8) .capture_period
INAPPLICABLE
    Object is not required according to OM and/or extensions
(9) .primary_address
INAPPLICABLE
    Object is not required according to OM and/or extensions

```

```

(10) .identification_number
INAPPLICABLE
    Object is not required according to OM and/or extensions
(11) .manufacturer_id
INAPPLICABLE
    Object is not required according to OM and/or extensions
(12) .version
INAPPLICABLE
    Object is not required according to OM and/or extensions
(13) .device_type
INAPPLICABLE
    Object is not required according to OM and/or extensions
(14) .access_number
INAPPLICABLE
    Object is not required according to OM and/or extensions
(15) .status
INAPPLICABLE
    Object is not required according to OM and/or extensions
(16) .alarm
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus client channel 2 0-2:24.1.0.255 (@1596)
(17) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(18) .mbus_port_reference
INAPPLICABLE
    Object is not required according to OM and/or extensions
(19) .capture_definition
INAPPLICABLE
    Object is not required according to OM and/or extensions
(20) .capture_period
INAPPLICABLE
    Object is not required according to OM and/or extensions
(21) .primary_address
INAPPLICABLE
    Object is not required according to OM and/or extensions
(22) .identification_number
INAPPLICABLE
    Object is not required according to OM and/or extensions
(23) .manufacturer_id
INAPPLICABLE
    Object is not required according to OM and/or extensions
(24) .version
INAPPLICABLE
    Object is not required according to OM and/or extensions
(25) .device_type
INAPPLICABLE
    Object is not required according to OM and/or extensions
(26) .access_number
INAPPLICABLE
    Object is not required according to OM and/or extensions
(27) .status
INAPPLICABLE
    Object is not required according to OM and/or extensions
(28) .alarm
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus client channel 3 0-3:24.1.0.255 (@1618)
(29) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(30) .mbus_port_reference
INAPPLICABLE
    Object is not required according to OM and/or extensions
(31) .capture_definition
INAPPLICABLE
    Object is not required according to OM and/or extensions
(32) .capture_period
INAPPLICABLE
    Object is not required according to OM and/or extensions

```

```

(33) .primary_address
INAPPLICABLE
    Object is not required according to OM and/or extensions
(34) .identification_number
INAPPLICABLE
    Object is not required according to OM and/or extensions
(35) .manufacturer_id
INAPPLICABLE
    Object is not required according to OM and/or extensions
(36) .version
INAPPLICABLE
    Object is not required according to OM and/or extensions
(37) .device_type
INAPPLICABLE
    Object is not required according to OM and/or extensions
(38) .access_number
INAPPLICABLE
    Object is not required according to OM and/or extensions
(39) .status
INAPPLICABLE
    Object is not required according to OM and/or extensions
(40) .alarm
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus client channel 4 0-4:24.1.0.255 (@1640)
(41) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(42) .mbus_port_reference
INAPPLICABLE
    Object is not required according to OM and/or extensions
(43) .capture_definition
INAPPLICABLE
    Object is not required according to OM and/or extensions
(44) .capture_period
INAPPLICABLE
    Object is not required according to OM and/or extensions
(45) .primary_address
INAPPLICABLE
    Object is not required according to OM and/or extensions
(46) .identification_number
INAPPLICABLE
    Object is not required according to OM and/or extensions
(47) .manufacturer_id
INAPPLICABLE
    Object is not required according to OM and/or extensions
(48) .version
INAPPLICABLE
    Object is not required according to OM and/or extensions
(49) .device_type
INAPPLICABLE
    Object is not required according to OM and/or extensions
(50) .access_number
INAPPLICABLE
    Object is not required according to OM and/or extensions
(51) .status
INAPPLICABLE
    Object is not required according to OM and/or extensions
(52) .alarm
INAPPLICABLE
    Object is not required according to OM and/or extensions

```

```

*****
Test Case 13 : Ext. M - M-Bus Results uncorrected Vol. & valve, 40 item(s)
*****

```

```

Mngmt Get M-Bus Value channel 1, instance 1 0-1:24.2.1.255 (@1662)
(1) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(2) .value
INAPPLICABLE

```

```

    Object is not required according to OM and/or extensions
(3) .scaler_unit
INAPPLICABLE
    Object is not required according to OM and/or extensions
(4) .status
INAPPLICABLE
    Object is not required according to OM and/or extensions
(5) .capture_time
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Value channel 1, instance 2 0-1:24.2.2.255 (@1670)
(6) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(7) .value
INAPPLICABLE
    Object is not required according to OM and/or extensions
(8) .scaler_unit
INAPPLICABLE
    Object is not required according to OM and/or extensions
(9) .status
INAPPLICABLE
    Object is not required according to OM and/or extensions
(10) .capture_time
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Value channel 2, instance 1 0-2:24.2.1.255 (@1694)
(11) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(12) .value
INAPPLICABLE
    Object is not required according to OM and/or extensions
(13) .scaler_unit
INAPPLICABLE
    Object is not required according to OM and/or extensions
(14) .status
INAPPLICABLE
    Object is not required according to OM and/or extensions
(15) .capture_time
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Value channel 2, instance 2 0-2:24.2.2.255 (@1702)
(16) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(17) .value
INAPPLICABLE
    Object is not required according to OM and/or extensions
(18) .scaler_unit
INAPPLICABLE
    Object is not required according to OM and/or extensions
(19) .status
INAPPLICABLE
    Object is not required according to OM and/or extensions
(20) .capture_time
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Value channel 3, instance 1 0-3:24.2.1.255 (@1726)
(21) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(22) .value
INAPPLICABLE
    Object is not required according to OM and/or extensions
(23) .scaler_unit
INAPPLICABLE
    Object is not required according to OM and/or extensions

```



```

(24) .status
INAPPLICABLE
    Object is not required according to OM and/or extensions
(25) .capture_time
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Value channel 3, instance 2 0-3:24.2.2.255 (@1734)
(26) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(27) .value
INAPPLICABLE
    Object is not required according to OM and/or extensions
(28) .scaler_unit
INAPPLICABLE
    Object is not required according to OM and/or extensions
(29) .status
INAPPLICABLE
    Object is not required according to OM and/or extensions
(30) .capture_time
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Value channel 4, instance 1 0-4:24.2.1.255 (@1758)
(31) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(32) .value
INAPPLICABLE
    Object is not required according to OM and/or extensions
(33) .scaler_unit
INAPPLICABLE
    Object is not required according to OM and/or extensions
(34) .status
INAPPLICABLE
    Object is not required according to OM and/or extensions
(35) .capture_time
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Value channel 4, instance 2 0-4:24.2.2.255 (@1766)
(36) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(37) .value
INAPPLICABLE
    Object is not required according to OM and/or extensions
(38) .scaler_unit
INAPPLICABLE
    Object is not required according to OM and/or extensions
(39) .status
INAPPLICABLE
    Object is not required according to OM and/or extensions
(40) .capture_time
INAPPLICABLE
    Object is not required according to OM and/or extensions

*****
Test Case 14 : Ext. M - M-Bus Device IDs, 16 item(s)
*****

Mngmt Get M-Bus Device ID 1 channel 1 0-1:96.1.0.255 (@1790)
(1) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(2) .value
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Device ID 1 channel 2 0-2:96.1.0.255 (@1794)
(3) .logical_name
INAPPLICABLE

```

```

    Object is not required according to OM and/or extensions
(4) .value
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Device ID 1 channel 3 0-3:96.1.0.255 (@1798)
(5) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(6) .value
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Device ID 1 channel 4 0-4:96.1.0.255 (@1802)
(7) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(8) .value
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Device ID 2 channel 1 0-1:96.1.1.255 (@1806)
(9) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(10) .value
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Device ID 2 channel 2 0-2:96.1.1.255 (@1810)
(11) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(12) .value
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Device ID 2 channel 3 0-3:96.1.1.255 (@1814)
(13) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(14) .value
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Device ID 2 channel 4 0-4:96.1.1.255 (@1818)
(15) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(16) .value
INAPPLICABLE
    Object is not required according to OM and/or extensions

*****
Test Case 15 : Ext. M - M-Bus Load Profiles, 32 item(s)
*****

Mngmt Get M-Bus Master Load profile for channel 1 0-1:24.3.0.255 (@1838)
(1) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(2) .buffer
INAPPLICABLE
    Object is not required according to OM and/or extensions
(3) .capture_objects
INAPPLICABLE
    Object is not required according to OM and/or extensions
(4) .capture_period
INAPPLICABLE
    Object is not required according to OM and/or extensions
(5) .sort_method
INAPPLICABLE
    Object is not required according to OM and/or extensions

```

```

(6) .sort_object
INAPPLICABLE
    Object is not required according to OM and/or extensions
(7) .entries_in_use
INAPPLICABLE
    Object is not required according to OM and/or extensions
(8) .profile_entries
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Master Load profile for channel 2 0-2:24.3.0.255 (@1849)
(9) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(10) .buffer
INAPPLICABLE
    Object is not required according to OM and/or extensions
(11) .capture_objects
INAPPLICABLE
    Object is not required according to OM and/or extensions
(12) .capture_period
INAPPLICABLE
    Object is not required according to OM and/or extensions
(13) .sort_method
INAPPLICABLE
    Object is not required according to OM and/or extensions
(14) .sort_object
INAPPLICABLE
    Object is not required according to OM and/or extensions
(15) .entries_in_use
INAPPLICABLE
    Object is not required according to OM and/or extensions
(16) .profile_entries
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Master Load profile for channel 3 0-3:24.3.0.255 (@1860)
(17) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(18) .buffer
INAPPLICABLE
    Object is not required according to OM and/or extensions
(19) .capture_objects
INAPPLICABLE
    Object is not required according to OM and/or extensions
(20) .capture_period
INAPPLICABLE
    Object is not required according to OM and/or extensions
(21) .sort_method
INAPPLICABLE
    Object is not required according to OM and/or extensions
(22) .sort_object
INAPPLICABLE
    Object is not required according to OM and/or extensions
(23) .entries_in_use
INAPPLICABLE
    Object is not required according to OM and/or extensions
(24) .profile_entries
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Master Load profile for channel 4 0-4:24.3.0.255 (@1871)
(25) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(26) .buffer
INAPPLICABLE
    Object is not required according to OM and/or extensions
(27) .capture_objects
INAPPLICABLE
    Object is not required according to OM and/or extensions

```

```

(28) .capture_period
INAPPLICABLE
    Object is not required according to OM and/or extensions
(29) .sort_method
INAPPLICABLE
    Object is not required according to OM and/or extensions
(30) .sort_object
INAPPLICABLE
    Object is not required according to OM and/or extensions
(31) .entries_in_use
INAPPLICABLE
    Object is not required according to OM and/or extensions
(32) .profile_entries
INAPPLICABLE
    Object is not required according to OM and/or extensions

```

```

*****
Test Case 16 : Ext. M - M-Bus Control Logs, 40 item(s)
*****

```

Mngmt Get M-Bus Master Control log object 1 0-1:24.5.0.255 (@1941)

```

(1) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(2) .buffer
INAPPLICABLE
    Object is not required according to OM and/or extensions
(3) .capture_objects
INAPPLICABLE
    Object is not required according to OM and/or extensions
(4) .capture_period
INAPPLICABLE
    Object is not required according to OM and/or extensions
(5) .sort_method
INAPPLICABLE
    Object is not required according to OM and/or extensions
(6) .sort_object
INAPPLICABLE
    Object is not required according to OM and/or extensions
(7) .entries_in_use
INAPPLICABLE
    Object is not required according to OM and/or extensions
(8) .profile_entries
INAPPLICABLE
    Object is not required according to OM and/or extensions

```

Mngmt Get M-Bus Master Control log object 2 0-2:24.5.0.255 (@1952)

```

(9) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(10) .buffer
INAPPLICABLE
    Object is not required according to OM and/or extensions
(11) .capture_objects
INAPPLICABLE
    Object is not required according to OM and/or extensions
(12) .capture_period
INAPPLICABLE
    Object is not required according to OM and/or extensions
(13) .sort_method
INAPPLICABLE
    Object is not required according to OM and/or extensions
(14) .sort_object
INAPPLICABLE
    Object is not required according to OM and/or extensions
(15) .entries_in_use
INAPPLICABLE
    Object is not required according to OM and/or extensions
(16) .profile_entries
INAPPLICABLE
    Object is not required according to OM and/or extensions

```

Mngmt Get M-Bus Master Control log object 3 0-3:24.5.0.255 (@1963)

```

(17) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(18) .buffer
INAPPLICABLE
    Object is not required according to OM and/or extensions
(19) .capture_objects
INAPPLICABLE
    Object is not required according to OM and/or extensions
(20) .capture_period
INAPPLICABLE
    Object is not required according to OM and/or extensions
(21) .sort_method
INAPPLICABLE
    Object is not required according to OM and/or extensions
(22) .sort_object
INAPPLICABLE
    Object is not required according to OM and/or extensions
(23) .entries_in_use
INAPPLICABLE
    Object is not required according to OM and/or extensions
(24) .profile_entries
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Master Control log object 4 0-4:24.5.0.255 (@1974)
(25) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(26) .buffer
INAPPLICABLE
    Object is not required according to OM and/or extensions
(27) .capture_objects
INAPPLICABLE
    Object is not required according to OM and/or extensions
(28) .capture_period
INAPPLICABLE
    Object is not required according to OM and/or extensions
(29) .sort_method
INAPPLICABLE
    Object is not required according to OM and/or extensions
(30) .sort_object
INAPPLICABLE
    Object is not required according to OM and/or extensions
(31) .entries_in_use
INAPPLICABLE
    Object is not required according to OM and/or extensions
(32) .profile_entries
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Event Log 0-0:99.98.3.255 (@1989)
(33) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(34) .buffer
INAPPLICABLE
    Object is not required according to OM and/or extensions
(35) .capture_objects
INAPPLICABLE
    Object is not required according to OM and/or extensions
(36) .capture_period
INAPPLICABLE
    Object is not required according to OM and/or extensions
(37) .sort_method
INAPPLICABLE
    Object is not required according to OM and/or extensions
(38) .sort_object
INAPPLICABLE
    Object is not required according to OM and/or extensions
(39) .entries_in_use
INAPPLICABLE
    Object is not required according to OM and/or extensions

```

```

(40) .profile_entries
INAPPLICABLE
    Object is not required according to OM and/or extensions

*****
Test Case 17 : Ext. M - M-Bus Disconnect, 22 item(s)
*****

Mngmt Get M-Bus Master Disconnect control object 1 0-1:24.4.0.255 (@1882)
(1) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(2) .output_state
INAPPLICABLE
    Object is not required according to OM and/or extensions
(3) .control_state
INAPPLICABLE
    Object is not required according to OM and/or extensions
(4) .control_mode
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Master Disconnect control object 2 0-2:24.4.0.255 (@1890)
(5) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(6) .output_state
INAPPLICABLE
    Object is not required according to OM and/or extensions
(7) .control_state
INAPPLICABLE
    Object is not required according to OM and/or extensions
(8) .control_mode
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Master Disconnect control object 3 0-3:24.4.0.255 (@1898)
(9) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(10) .output_state
INAPPLICABLE
    Object is not required according to OM and/or extensions
(11) .control_state
INAPPLICABLE
    Object is not required according to OM and/or extensions
(12) .control_mode
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Master Disconnect control object 4 0-4:24.4.0.255 (@1906)
(13) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(14) .output_state
INAPPLICABLE
    Object is not required according to OM and/or extensions
(15) .control_state
INAPPLICABLE
    Object is not required according to OM and/or extensions
(16) .control_mode
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Disconnect control scheduler 0-1:15.0.1.255 (@1914)
(17) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(18) .executed_script
INAPPLICABLE
    Object is not required according to OM and/or extensions
(19) .type
INAPPLICABLE

```

```

        Object is not required according to OM and/or extensions
    (20) .execution_time
INAPPLICABLE
        Object is not required according to OM and/or extensions

    Mngmt Get M-Bus Disconnecter script table 0-1:10.0.106.255 (@1920)
    (21) .logical_name
INAPPLICABLE
        Object is not required according to OM and/or extensions
    (22) .scripts
INAPPLICABLE
        Object is not required according to OM and/or extensions

*****
Test Case 18 : FIT Wake up, 2 item(s)
*****
    (1) Wake up with clip call from unknown number
INAPPLICABLE
        Clip call not supported
    (2) Wake up with SMS from unknown number
INAPPLICABLE
        SMS not supported

*****
Test Case 19 : FIT Push, 3 item(s)
*****
    (1) Push on installation                                     PASSED
    (2) Push on alarm                                           PASSED
    (3) Push on power down
INAPPLICABLE
        Push setup on power down not available

*****
Test Case 20 : FIT Miscellaneous, 4 item(s)
*****
    (1) Disconnecter Script Table                               PASSED
    (2) Load profile with period 1 DST ambiguity               PASSED
    (3) Load profile power down withing one period            PASSED
    (4) Load profile power down over two periods               PASSED

*****
* CTI *
*****

// Conformance Test Information (CTI) Template
// 1.6

Manufacturer = {
    Name = '\EDMI Ltd.'
    ThreeLettersId = '\EDM'
}

DeviceUnderTest = {
    Type = '\1M130-00A0-10211-1000-002-051'
    IDISDeviceType = 103
    IDISFunctionType = [Extension_D]
    SerialNr = 51400057
    IPVersion = IPv4
    DataLinkLayer = GPRS
    ConsumerInformationPush = FALSE
    SMSSupported = FALSE
    ClipCallSupported = FALSE
}

TestOptions =
{
}

ObjectModel = {
    // Optional objects implemented
    OptionalObjects = '\
        + '1-0:0.9.1.255|1,' // Local Time (@86)
        + '1-0:0.9.2.255|1,' // Local Date (@90)
    
```

```

+ '1-1:0.2.0.255|1,' // Active firmware identifier 1 (@420)
+ '1-1:0.2.8.255|1,' // Active firmware signature 1 (@424)
+ '1-2:0.2.0.255|1,' // Active firmware identifier 2 (@428)
+ '1-2:0.2.8.255|1,' // Active firmware signature 2 (@432)
+ '1-0:9.8.0.255|3,' // Apparent energy import (+VA) (QI+QIV) (@497)
+ '1-0:10.8.0.255|3,' // Apparent energy export (-VA) (QII+QIII) (@503)
+ '1-0:5.8.1.255|3,' // Reactive energy (QI) rate 1 (@606)
+ '1-0:5.8.2.255|3,' // Reactive energy (QI) rate 2 (@612)
+ '1-0:5.8.3.255|3,' // Reactive energy (QI) rate 3 (@618)
+ '1-0:5.8.4.255|3,' // Reactive energy (QI) rate 4 (@624)
+ '1-0:6.8.1.255|3,' // Reactive energy (QII) rate 1 (@630)
+ '1-0:6.8.2.255|3,' // Reactive energy (QII) rate 2 (@636)
+ '1-0:6.8.3.255|3,' // Reactive energy (QII) rate 3 (@642)
+ '1-0:6.8.4.255|3,' // Reactive energy (QII) rate 4 (@648)
+ '1-0:7.8.1.255|3,' // Reactive energy (QIII) rate 1 (@654)
+ '1-0:7.8.2.255|3,' // Reactive energy (QIII) rate 2 (@660)
+ '1-0:7.8.3.255|3,' // Reactive energy (QIII) rate 3 (@666)
+ '1-0:7.8.4.255|3,' // Reactive energy (QIII) rate 4 (@672)
+ '1-0:8.8.1.255|3,' // Reactive energy (QIV) rate 1 (@678)
+ '1-0:8.8.2.255|3,' // Reactive energy (QIV) rate 2 (@684)
+ '1-0:8.8.3.255|3,' // Reactive energy (QIV) rate 3 (@690)
+ '1-0:8.8.4.255|3,' // Reactive energy (QIV) rate 4 (@696)
+ '1-0:9.8.1.255|3,' // Apparent energy import (+VA) rate 1 (@702)
+ '1-0:9.8.2.255|3,' // Apparent energy import (+VA) rate 2 (@708)
+ '1-0:9.8.3.255|3,' // Apparent energy import (+VA) rate 3 (@714)
+ '1-0:9.8.4.255|3,' // Apparent energy import (+VA) rate 4 (@720)
+ '1-0:10.8.1.255|3,' // Apparent energy export (-VA) rate 1 (@726)
+ '1-0:10.8.2.255|3,' // Apparent energy export (-VA) rate 2 (@732)
+ '1-0:10.8.3.255|3,' // Apparent energy export (-VA) rate 3 (@738)
+ '1-0:10.8.4.255|3,' // Apparent energy export (-VA) rate 4 (@744)
+ '1-0:15.8.1.255|3,' // Active energy Combined total (|+A|+|-A|) rate 1 (@750)
+ '1-0:15.8.2.255|3,' // Active energy Combined total (|+A|+|-A|) rate 2 (@756)
+ '1-0:15.8.3.255|3,' // Active energy Combined total (|+A|+|-A|) rate 3 (@762)
+ '1-0:15.8.4.255|3,' // Active energy Combined total (|+A|+|-A|) rate 4 (@768)
+ '1-0:9.4.0.255|5,' // Demand Register 5 - Apparent energy import (+VA) (@827)
+ '1-0:10.4.0.255|5,' // Demand Register 6 - Apparent energy export (-VA) (@840)
+ '1-0:9.6.0.255|4,' // Maximum Demand Register 21 - Apparent energy import (+VA) (@1061)
+ '1-0:9.6.1.255|4,' // Maximum Demand Register 22 - Apparent energy import (+VA) - rate
1 (@1069)
+ '1-0:9.6.2.255|4,' // Maximum Demand Register 23 - Apparent energy import (+VA) - rate
2 (@1077)
+ '1-0:9.6.3.255|4,' // Maximum Demand Register 24 - Apparent energy import (+VA) - rate
3 (@1085)
+ '1-0:9.6.4.255|4,' // Maximum Demand Register 25 - Apparent energy import (+VA) - rate
4 (@1093)
+ '1-0:10.6.0.255|4,' // Maximum Demand Register 26 - Apparent energy export (-VA)
(@1101)
+ '1-0:10.6.1.255|4,' // Maximum Demand Register 27 - Apparent energy export (-VA) - rate
1 (@1109)
+ '1-0:10.6.2.255|4,' // Maximum Demand Register 28 - Apparent energy export (-VA) - rate
2 (@1117)
+ '1-0:10.6.3.255|4,' // Maximum Demand Register 29 - Apparent energy export (-VA) - rate
3 (@1125)
+ '1-0:10.6.4.255|4,' // Maximum Demand Register 30 - Apparent energy export (-VA) - rate
4 (@1133)
+ '1-0:14.7.0.255|3,' // Instantaneous net frequency; any phase (@1450)
+ '1-0:9.7.0.255|3,' // Instantaneous apparent import power (+VA) (@1486)
+ '1-0:10.7.0.255|3,' // Instantaneous apparent export power (-VA) (@1492)
+ '1-0:13.7.0.255|3,' // Instantaneous Power factor (+A/+VA) (@1537)
+ '1-0:13.5.0.255|4,' // Last Average Power factor (+A/+VA) (@1543)
+ '1-0:13.3.0.255|4,' // Minimum Power factor (+A/+VA) (@1551)
+ '1-0:0.8.2.255|3,' // Measurement Period 3 for Instantaneous values (@1559)
+ '0-0:20.0.0.255|19' // IEC local port setup - IEC Optical port (@2001)

```

```

InstanceExtraInfo = {
  LogicalName = '0-0:20.0.0.255'
  ClassId = 19
  AttributeExtraInfo = {
    AttributeId = 7
    SetData = '\<Data><OctetString Value="3132333435363738" /></Data>'
  }
  AttributeExtraInfo = {

```



```

        AttributeId = 8
        SetData = '\<Data><OctetString Value="3132333435363738" /></Data>'
    }
    AttributeExtraInfo = {
        AttributeId = 9
        SetData = '\<Data><OctetString Value="3132333435363738" /></Data>'
    }
}

// Set value for Consumer Message Text
InstanceExtraInfo = {
    LogicalName = '0-0:96.13.0.255'
    ClassId = 1
    AttributeExtraInfo = {
        AttributeId = 2
        SetData = '\<Data><OctetString Value="3132333435363738" /></Data>'
    }
}
InstanceExtraInfo = {
    LogicalName = '0-0:1.0.0.255'
    ClassId = 8
    AttributeExtraInfo = {
        AttributeId = 2
        SetData = '\<Data><OctetString Value="07E70504FF10000FF8000FF" /></Data>' // yyyy mm
dd dow hh mm ss
    }
}

InstanceExtraInfo = {
    // Set special days to 30 entries
    LogicalName = '0-0:11.0.0.255'
    ClassId = 11
    AttributeExtraInfo = {
        AttributeId = 2
        SetData = '\<Data>'
+       <Array Qty="1E" >'
+       <Structure Qty="03" >'
+       <LongUnsigned Value="001E" />'
+       <OctetString Value="FFFF0101FF" />'
+       <Unsigned Value="02" />'
+       </Structure>'
+       <Structure Qty="03" >'
+       <LongUnsigned Value="001D" />'
+       <OctetString Value="FFFF0102FF" />'
+       <Unsigned Value="02" />'
+       </Structure>'
+       <Structure Qty="03" >'
+       <LongUnsigned Value="001C" />'
+       <OctetString Value="FFFF0103FF" />'
+       <Unsigned Value="02" />'
+       </Structure>'
+       <Structure Qty="03" >'
+       <LongUnsigned Value="001B" />'
+       <OctetString Value="FFFF0104FF" />'
+       <Unsigned Value="02" />'
+       </Structure>'
+       <Structure Qty="03" >'
+       <LongUnsigned Value="001A" />'
+       <OctetString Value="FFFF0105FF" />'
+       <Unsigned Value="02" />'
+       </Structure>'
+       <Structure Qty="03" >'
+       <LongUnsigned Value="0019" />'
+       <OctetString Value="FFFF0106FF" />'
+       <Unsigned Value="02" />'
+       </Structure>'
+       <Structure Qty="03" >'
+       <LongUnsigned Value="0018" />'
+       <OctetString Value="FFFF0107FF" />'
+       <Unsigned Value="02" />'
+       </Structure>'
+       <Structure Qty="03" >'
+       <LongUnsigned Value="0017" />'

```

```

+'      <OctetString Value="FFFF0108FF" />'
+'      <Unsigned Value="02" />'
+'    </Structure>'
+'  <Structure Qty="03" >'
+'    <LongUnsigned Value="0016" />'
+'    <OctetString Value="FFFF0109FF" />'
+'    <Unsigned Value="02" />'
+'  </Structure>'
+'  <Structure Qty="03" >'
+'    <LongUnsigned Value="0015" />'
+'    <OctetString Value="FFFF010AFF" />'
+'    <Unsigned Value="02" />'
+'  </Structure>'
+'  <Structure Qty="03" >'
+'    <LongUnsigned Value="0014" />'
+'    <OctetString Value="FFFF0201FF" />'
+'    <Unsigned Value="02" />'
+'  </Structure>'
+'  <Structure Qty="03" >'
+'    <LongUnsigned Value="0013" />'
+'    <OctetString Value="FFFF0202FF" />'
+'    <Unsigned Value="02" />'
+'  </Structure>'
+'  <Structure Qty="03" >'
+'    <LongUnsigned Value="0012" />'
+'    <OctetString Value="FFFF0203FF" />'
+'    <Unsigned Value="02" />'
+'  </Structure>'
+'  <Structure Qty="03" >'
+'    <LongUnsigned Value="0011" />'
+'    <OctetString Value="FFFF0204FF" />'
+'    <Unsigned Value="02" />'
+'  </Structure>'
+'  <Structure Qty="03" >'
+'    <LongUnsigned Value="0010" />'
+'    <OctetString Value="FFFF0205FF" />'
+'    <Unsigned Value="02" />'
+'  </Structure>'
+'  <Structure Qty="03" >'
+'    <LongUnsigned Value="000F" />'
+'    <OctetString Value="FFFF0206FF" />'
+'    <Unsigned Value="02" />'
+'  </Structure>'
+'  <Structure Qty="03" >'
+'    <LongUnsigned Value="000E" />'
+'    <OctetString Value="FFFF0207FF" />'
+'    <Unsigned Value="02" />'
+'  </Structure>'
+'  <Structure Qty="03" >'
+'    <LongUnsigned Value="000D" />'
+'    <OctetString Value="FFFF0208FF" />'
+'    <Unsigned Value="02" />'
+'  </Structure>'
+'  <Structure Qty="03" >'
+'    <LongUnsigned Value="000C" />'
+'    <OctetString Value="FFFF0209FF" />'
+'    <Unsigned Value="02" />'
+'  </Structure>'
+'  <Structure Qty="03" >'
+'    <LongUnsigned Value="000B" />'
+'    <OctetString Value="FFFF020AFF" />'
+'    <Unsigned Value="02" />'
+'  </Structure>'
+'  <Structure Qty="03" >'
+'    <LongUnsigned Value="000A" />'
+'    <OctetString Value="FFFF0301FF" />'
+'    <Unsigned Value="02" />'
+'  </Structure>'
+'  <Structure Qty="03" >'
+'    <LongUnsigned Value="0009" />'
+'    <OctetString Value="FFFF0302FF" />'
+'    <Unsigned Value="02" />'
+'  </Structure>'

```

```

+'          <Structure Qty="03" >'
+'            <LongUnsigned Value="0008" />'
+'            <OctetString Value="FFFF0303FF" />'
+'            <Unsigned Value="02" />'
+'          </Structure>'
+'          <Structure Qty="03" >'
+'            <LongUnsigned Value="0007" />'
+'            <OctetString Value="FFFF0304FF" />'
+'            <Unsigned Value="02" />'
+'          </Structure>'
+'          <Structure Qty="03" >'
+'            <LongUnsigned Value="0006" />'
+'            <OctetString Value="FFFF0305FF" />'
+'            <Unsigned Value="02" />'
+'          </Structure>'
+'          <Structure Qty="03" >'
+'            <LongUnsigned Value="0005" />'
+'            <OctetString Value="FFFF0306FF" />'
+'            <Unsigned Value="02" />'
+'          </Structure>'
+'          <Structure Qty="03" >'
+'            <LongUnsigned Value="0004" />'
+'            <OctetString Value="FFFF0307FF" />'
+'            <Unsigned Value="02" />'
+'          </Structure>'
+'          <Structure Qty="03" >'
+'            <LongUnsigned Value="0003" />'
+'            <OctetString Value="FFFF0308FF" />'
+'            <Unsigned Value="02" />'
+'          </Structure>'
+'          <Structure Qty="03" >'
+'            <LongUnsigned Value="0002" />'
+'            <OctetString Value="FFFF0309FF" />'
+'            <Unsigned Value="02" />'
+'          </Structure>'
+'          <Structure Qty="03" >'
+'            <LongUnsigned Value="0001" />'
+'            <OctetString Value="FFFF030AFF" />'
+'            <Unsigned Value="02" />'
+'          </Structure>'
+'        </Array>'
+'      </Data>'
+'    }
+'  }
+'}

TestParameters = {

  ConnectDisconnectDelay = 5000
  ClientSystemTitle = '58585A0102030405'

  ImageTransfer = {
    ImageIdentifier = '\2.H.7-281222B003'
    ImageFileName = '\2.H.7-281222B003.bin'
    Timeout = 120000
  }

  PushTimeout = 60000
  MinInterWPDUFramesDelay = 1000
  ProfilePeriodsQty = 6
  CaptureDelay = 15000
  ClipCallDuration = 20000

  AutoConnect = {
    Repetitions = 0
    RepetitionDelay = 0
  }

  PushSetup = {
    NumberOfRetries = 1
    RepetitionDelay = 30
  }
}

```

```

WakeUpDelay = 30000
DisconnectToSendSMSDelay = 10000
DataNotificationToDisconnectDelay = 4000
}

LocalSecurityElements = {
  Public = {
    ContextName = LONG_NAMES
    MechanismName = LOWEST_LEVEL_SECURITY
    Policy = NO_SECURITY
  }
  Management = {
    ContextName = LONG_NAMES_WITH_CIPHERING
    MechanismName = HIGH_LEVEL_SECURITY_GMAC
    Policy = AUTHENTICATION_AND_ENCRYPTION
    Password = '\12345678'
  }
  PreEstablished = {
    Policy = AUTHENTICATION_AND_ENCRYPTION
    ServerMaxReceivePduSize = 1224
    CipheringStyle = GENERAL
  }
}

RemoteSecurityElements = {
  Public = {
    ContextName = LONG_NAMES
    MechanismName = LOWEST_LEVEL_SECURITY
    Policy = NO_SECURITY
  }
  Management = {
    ContextName = LONG_NAMES_WITH_CIPHERING
    MechanismName = HIGH_LEVEL_SECURITY_GMAC
    Policy = AUTHENTICATION_AND_ENCRYPTION
    Password = '\12345678'
  }
  PreEstablished = {
    Policy = AUTHENTICATION_AND_ENCRYPTION
    ServerMaxReceivePduSize = 1224
    CipheringStyle = GENERAL
  }
}

SMSSecurityElements = {
  PreEstablished = {
    Policy = AUTHENTICATION_AND_ENCRYPTION
    ServerMaxReceivePDUSize = 138
    CipheringStyle = GENERAL
  }
}

HDLCPProfile = {
  PhysicalLayer = {
    OpeningMode = MODE_E
    HdlcBaud = 9600
  }
  DataLinkLayer = {
    InactivityTimeout = 30000
    InterFrameTimeout = 150
    ResponseTimeout = 30000
    DISCToNDMTimeout = 5000
    AddressingSchemes = [TWO_BYTES_ADDRESSING]
    ServerLowerMACAddress = 17
  }
}

// Mandatory parameters of the 'Remote' TCP Profile
TCPProfile = {
  ServerTCPPort = 4059
  ResponseTimeout = 30000
  ConnectTimeout = 60000
}

```

```
    DisconnectToConnectDelay = 10000
}

G3PLCProfile = {
    ResponseTimeout = 30000
    ConnectTimeout = 10000
    UDPPort = 61616
    PSK = "AB10341145111BC3C12DE8FF11142204"
}

// END CTI_Template

*****
* Miscellaneous *
*****

TestMode:                TCP
Test Plan Signature:     DACF66B3C5D3456427BD1C6419F470BD
Object Model:           IDIS-S02-002 - object model Pack2 Ed2.0 - V2.29 (20200831)-FIT MBUS
Tests G350 (CorrectedAndValve status).xlsx
DUT system title:       45444D6713104D79
Run number:             2084
```