

Final Interoperability Test Report

FIT #: **102**
 Date: 6/20/2023
 Location: DNV-GL, Arnhem, Netherlands
 Page 1 of 38

APPLICANT

Company: Wasion Group Limited

Address: No.468 Tongzipo West Road, Wasion Science Park, 410205 Changsha, China

DEVICE

Device type	aMeter300	
<i>Type indication on MID certificate</i>		<i>MID Certificate No.</i>
aMeter300		1266-21
<i>IDIS Specification reference</i>	<i>DNV-gl IDIS Certification run No</i>	<i>Digital signature of the test report.</i>
Package 2 ed. 2.0	2166	F2C5E50C50A7284A4C10E93471CF5384
<i>First certification</i>	<i>IDIS Label</i>	<i>Modular device</i>
<input type="checkbox"/>	0066-2	<input type="checkbox"/>
<i>General information about the device</i>		
Polyphase Smart Meter		

FIRMWARE VERSIONS TESTED

FIRMWARE VERSIONS TESTED				<i>Final Interoperability Test No. 102</i>
Firmware No.	Firmware ID1	Firmware ID2	Firmware ID3	Verdict
2	\aM300-L-B0500202	\aM300-N-B0500202		Passed

Honeywell

Iskraemeco d.d.

Itron

Landis+Gyr AG

FIRMWARE VERSIONS HISTORY				Final Integration Test	
Firmware No.	Firmware ID1	Firmware ID2	Firmware ID3	No.	Verdict
1	\aM300-L-B0500202	\aM300-N-B0500202		54	Passed
2	\aM300-L-B0500202	\aM300-N-B0500202		102	Passed

TEST REPORT - Firmware No. 1		
<i>Test</i>	<i>Verdict</i>	<i>Remark</i>
Connect and release	Passed	
All Device IDs	Passed	
COSEM logical device name	Passed	
SAP assignment	Passed	
FW version and signature	Passed	
All Device ID's	Passed	
Broadcast Date and time	Passed	
Broadcast Special Days Table	Passed	
Event logs	Passed	
Billing data period 1	Passed	
M-Bus Channel Setup	Passed	Only one M-Bus Master Port in use
M-Bus Results	Passed	
M-Bus Devices IDs	Passed	
M-Bus profiles	Passed	
M-Bus Load profiles	Passed	
M-Bus control logs	Passed	
M-Bus Disconnect log	Passed	
FIT Push	Passed	Power Off Push N/A
FIT Miscellaneous	Passed	
Optical Port Connectivity	Passed	
Consumer Information Interface	Passed	
<i>FIT Conformance Test Report</i>		
<pre> ***** IDIS Conformance test report 15-JUN-2023 13:37:21 iCTT2 Package 2, Edition 2.0, Revision 1 (136) Licensed to: KEMA-IDIS Cert. Tester: Tom Levels ***** ***** * Identification * ***** Manufacturer = { Name = '\Wasion Group Limited' ThreeLettersId = '\WSE' } DeviceUnderTest = { Type = '\aMeter300' IDISDeviceType = 103 IDISFunctionType = [EXTENSION_D, EXTENSION_L, EXTENSION_M] SerialNr = 3684408 IPVersion = IPV6 DataLinkLayer = G3 ConsumerInformationPush = FALSE EUI64Address = '386E21FFFE383838' SMSSupported = FALSE ClipCallSupported = FALSE } </pre>		

```

Active firmware identifier (1-0:0.2.0.255) = \aM300-L-B0500202
Active firmware identifier 1 (1-1:0.2.0.255) = \aM300-N-B0500202

*****
* Summary *
*****

PASSED                266
FAILED                0
DISABLED              0
INAPPLICABLE         7
INCONCLUSIVE         0
FATAL                 0
TOTAL                 273

*****
Test Case 1 : Connect and release, 4 item(s)
*****
(1) Connect Public           PASSED
(2) Release Public          PASSED
(3) Connect Management      PASSED
(4) Release Management      PASSED

*****
Test Case 2 : Read Device IDs, 12 item(s)
*****

Mngmt Get Device ID 1, manufacturing number 0-0:96.1.0.255 (@46)
(1) .logical_name           PASSED
    <Data>
    <OctetString Value="0000600100FF" />
    </Data>
(2) .value                  PASSED
    <Data>
    <OctetString Value="\03684408" />
    </Data>

Mngmt Get Device ID 2 0-0:96.1.1.255 (@50)
(3) .logical_name           PASSED
    <Data>
    <OctetString Value="0000600101FF" />
    </Data>
(4) .value                  PASSED
    <Data>
    <OctetString Value="\00000016" />
    </Data>

Mngmt Get Device ID 3 0-0:96.1.2.255 (@54)
(5) .logical_name           PASSED
    <Data>
    <OctetString Value="0000600102FF" />
    </Data>
(6) .value                  PASSED
    <Data>
    <OctetString Value="\3" />
    </Data>

Mngmt Get Device ID 4 0-0:96.1.3.255 (@58)
(7) .logical_name           PASSED
    <Data>
    <OctetString Value="0000600103FF" />
    </Data>
(8) .value                  PASSED
    <Data>
    <OctetString Value="\4" />
    </Data>

Mngmt Get Device ID 5 0-0:96.1.4.255 (@62)
(9) .logical_name           PASSED
    <Data>
    <OctetString Value="0000600104FF" />
    </Data>
(10) .value                 PASSED

```

```

    <Data>
      <OctetString Value="\5" />
    </Data>

Mngmt Get Device ID 6, IDIS certification number 0-0:96.1.5.255 (@66)
(11) .logical_name PASSED
    <Data>
      <OctetString Value="0000600105FF" />
    </Data>
(12) .value PASSED
    <Data>
      <OctetString Value="\6" />
    </Data>

*****
Test Case 3 : Read COSEM Logical Device Name, 2 item(s)
*****

Mngmt Get COSEM logical device name 0-0:42.0.0.255 (@42)
(1) .logical_name PASSED
    <Data>
      <OctetString Value="00002A0000FF" />
    </Data>
(2) .value PASSED
    <Data>
      <OctetString Value="\WSE1030703684408" />
    </Data>

*****
Test Case 4 : Read SAP Assignment, 2 item(s)
*****

Mngmt Get SAP Assignment 0-0:41.0.0.255 (@4)
(1) .logical_name PASSED
    <Data>
      <OctetString Value="0000290000FF" />
    </Data>
(2) .SAP_assignment_list PASSED
    <Data>
      <Array Qty="0001" >
        <Structure Qty="0002" >
          <LongUnsigned Value="0001" />
          <OctetString Value="\WSE1030703684408" />
        </Structure>
      </Array>
    </Data>

*****
Test Case 5 : Read Active FW Version, 12 item(s)
*****

Mngmt Get Active firmware identifier 1-0:0.2.0.255 (@412)
(1) .logical_name PASSED
    <Data>
      <OctetString Value="0100000200FF" />
    </Data>
(2) .value PASSED
    <Data>
      <OctetString Value="\aM300-L-B0500202" />
    </Data>

Mngmt Get Active firmware signature 1-0:0.2.8.255 (@416)
(3) .logical_name PASSED
    <Data>
      <OctetString Value="0100000208FF" />
    </Data>
(4) .value PASSED
    <Data>
      <OctetString Value="A9FC0332" />
    </Data>

Mngmt Get Active firmware identifier 1 1-1:0.2.0.255 (@420)
(5) .logical_name PASSED

```

```

    <Data>
      <OctetString Value="0101000200FF" />
    </Data>
(6) .value PASSED
    <Data>
      <OctetString Value="\aM300-N-B0500202" />
    </Data>

Mngmt Get Active firmware signature 1 1-1:0.2.8.255 (@424)
(7) .logical_name PASSED
    <Data>
      <OctetString Value="0101000208FF" />
    </Data>
(8) .value PASSED
    <Data>
      <OctetString Value="4221032D" />
    </Data>

Mngmt Get Active firmware identifier 2 1-2:0.2.0.255 (@428)
(9) .logical_name
INAPPLICABLE
  Optional object is not implemented
(10) .value
INAPPLICABLE
  Optional object is not implemented

Mngmt Get Active firmware signature 2 1-2:0.2.8.255 (@432)
(11) .logical_name
INAPPLICABLE
  Optional object is not implemented
(12) .value
INAPPLICABLE
  Optional object is not implemented

*****
Test Case 6 : Set Clock, 1 item(s)
*****

Pre Set Clock 0-0:1.0.0.255 (@75)
(1) .time PASSED
    <Data>
      <OctetString Value="07E7060FFF100000FF8000FF" />
    </Data>

*****
Test Case 7 : Get Clock, 1 item(s)
*****

Mngmt Get Clock 0-0:1.0.0.255 (@75)
(1) .time PASSED
    <Data>
      <OctetString Value="07E7060F0410000100FF8880" />
    </Data>

*****
Test Case 8 : Set Special Days, 1 item(s)
*****

Pre Set Special Days Table 0-0:11.0.0.255 (@125)
(1) .entries PASSED
    <Data>
      <Array Qty="001E" >
        <Structure Qty="0003" >
          <LongUnsigned Value="0001" />
          <OctetString Value="FFFF0101FF" />
          <Unsigned Value="02" />
        </Structure>
        <Structure Qty="0003" >
          <LongUnsigned Value="0002" />
          <OctetString Value="FFFF0102FF" />
          <Unsigned Value="02" />
        </Structure>
      </Array>
    </Data>

```

```

    <LongUnsigned Value="0003" />
    <OctetString Value="FFFF0103FF" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0003" >
    <LongUnsigned Value="0004" />
    <OctetString Value="FFFF0104FF" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0003" >
    <LongUnsigned Value="0005" />
    <OctetString Value="FFFF0105FF" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0003" >
    <LongUnsigned Value="0006" />
    <OctetString Value="FFFF0106FF" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0003" >
    <LongUnsigned Value="0007" />
    <OctetString Value="FFFF0107FF" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0003" >
    <LongUnsigned Value="0008" />
    <OctetString Value="FFFF0108FF" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0003" >
    <LongUnsigned Value="0009" />
    <OctetString Value="FFFF0109FF" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0003" >
    <LongUnsigned Value="000A" />
    <OctetString Value="FFFF010AFF" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0003" >
    <LongUnsigned Value="000B" />
    <OctetString Value="FFFF0201FF" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0003" >
    <LongUnsigned Value="000C" />
    <OctetString Value="FFFF0202FF" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0003" >
    <LongUnsigned Value="000D" />
    <OctetString Value="FFFF0203FF" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0003" >
    <LongUnsigned Value="000E" />
    <OctetString Value="FFFF0204FF" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0003" >
    <LongUnsigned Value="000F" />
    <OctetString Value="FFFF0205FF" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0003" >
    <LongUnsigned Value="0010" />
    <OctetString Value="FFFF0206FF" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0003" >
    <LongUnsigned Value="0011" />
    <OctetString Value="FFFF0207FF" />
    <Unsigned Value="02" />
  </Structure>

```

```

</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0012" />
  <OctetString Value="FFFF0208FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0013" />
  <OctetString Value="FFFF0209FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0014" />
  <OctetString Value="FFFF020AFF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0015" />
  <OctetString Value="FFFF0301FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0016" />
  <OctetString Value="FFFF0302FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0017" />
  <OctetString Value="FFFF0303FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0018" />
  <OctetString Value="FFFF0304FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0019" />
  <OctetString Value="FFFF0305FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="001A" />
  <OctetString Value="FFFF0306FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="001B" />
  <OctetString Value="FFFF0307FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="001C" />
  <OctetString Value="FFFF0308FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="001D" />
  <OctetString Value="FFFF0309FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="001E" />
  <OctetString Value="FFFF030AFF" />
  <Unsigned Value="02" />
</Structure>
</Array>
</Data>

```

```

*****
Test Case 9 : Get Special Days, 1 item(s)
*****

```


Mngmt Get Special Days Table 0-0:11.0.0.255 (@125)

(1) .entries

PASSED

```

<Data>
  <Array Qty="001E" >
    <Structure Qty="0003" >
      <LongUnsigned Value="0001" />
      <OctetString Value="FFFF0101FF" />
      <Unsigned Value="02" />
    </Structure>
    <Structure Qty="0003" >
      <LongUnsigned Value="0002" />
      <OctetString Value="FFFF0102FF" />
      <Unsigned Value="02" />
    </Structure>
    <Structure Qty="0003" >
      <LongUnsigned Value="0003" />
      <OctetString Value="FFFF0103FF" />
      <Unsigned Value="02" />
    </Structure>
    <Structure Qty="0003" >
      <LongUnsigned Value="0004" />
      <OctetString Value="FFFF0104FF" />
      <Unsigned Value="02" />
    </Structure>
    <Structure Qty="0003" >
      <LongUnsigned Value="0005" />
      <OctetString Value="FFFF0105FF" />
      <Unsigned Value="02" />
    </Structure>
    <Structure Qty="0003" >
      <LongUnsigned Value="0006" />
      <OctetString Value="FFFF0106FF" />
      <Unsigned Value="02" />
    </Structure>
    <Structure Qty="0003" >
      <LongUnsigned Value="0007" />
      <OctetString Value="FFFF0107FF" />
      <Unsigned Value="02" />
    </Structure>
    <Structure Qty="0003" >
      <LongUnsigned Value="0008" />
      <OctetString Value="FFFF0108FF" />
      <Unsigned Value="02" />
    </Structure>
    <Structure Qty="0003" >
      <LongUnsigned Value="0009" />
      <OctetString Value="FFFF0109FF" />
      <Unsigned Value="02" />
    </Structure>
    <Structure Qty="0003" >
      <LongUnsigned Value="000A" />
      <OctetString Value="FFFF010AFF" />
      <Unsigned Value="02" />
    </Structure>
    <Structure Qty="0003" >
      <LongUnsigned Value="000B" />
      <OctetString Value="FFFF0201FF" />
      <Unsigned Value="02" />
    </Structure>
    <Structure Qty="0003" >
      <LongUnsigned Value="000C" />
      <OctetString Value="FFFF0202FF" />
      <Unsigned Value="02" />
    </Structure>
    <Structure Qty="0003" >
      <LongUnsigned Value="000D" />
      <OctetString Value="FFFF0203FF" />
      <Unsigned Value="02" />
    </Structure>
    <Structure Qty="0003" >
      <LongUnsigned Value="000E" />
      <OctetString Value="FFFF0204FF" />
      <Unsigned Value="02" />
    </Structure>
  </Array>

```

```

</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="000F" />
  <OctetString Value="FFFF0205FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0010" />
  <OctetString Value="FFFF0206FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0011" />
  <OctetString Value="FFFF0207FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0012" />
  <OctetString Value="FFFF0208FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0013" />
  <OctetString Value="FFFF0209FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0014" />
  <OctetString Value="FFFF020AFF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0015" />
  <OctetString Value="FFFF0301FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0016" />
  <OctetString Value="FFFF0302FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0017" />
  <OctetString Value="FFFF0303FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0018" />
  <OctetString Value="FFFF0304FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0019" />
  <OctetString Value="FFFF0305FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="001A" />
  <OctetString Value="FFFF0306FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="001B" />
  <OctetString Value="FFFF0307FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="001C" />
  <OctetString Value="FFFF0308FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="001D" />

```

```

        <OctetString Value="FFFF0309FF" />
        <Unsigned Value="02" />
    </Structure>
    <Structure Qty="0003" >
        <LongUnsigned Value="001E" />
        <OctetString Value="FFFF030AFF" />
        <Unsigned Value="02" />
    </Structure>
</Array>
</Data>

*****
Test Case 10 : Read Event Log Buffers, 20 item(s)
*****

Mngmt Get Disconnecter Control Log 0-0:99.98.2.255 (@193)
(1) .logical_name PASSED
    <Data>
        <OctetString Value="0000636202FF" />
    </Data>
(2) .buffer PASSED
    Earliest date: 24-FEB-2022 11:19:45, latest date: 27-OCT-2024 01:44:55
    Middle date: 15-JUN-2024 00:00:00
(3) .entries_in_use PASSED
    <Data>
        <DoubleLongUnsigned Value="000000B3" />
    </Data>
(4) .profile_entries PASSED
    <Data>
        <DoubleLongUnsigned Value="000000C8" />
    </Data>

Mngmt Get Standard Event Log 0-0:99.98.0.255 (@301)
(5) .logical_name PASSED
    <Data>
        <OctetString Value="0000636200FF" />
    </Data>
(6) .buffer PASSED
    Earliest date: 18-APR-2023 17:13:18, latest date: 27-OCT-2024 01:53:09
    Middle date: 15-JUN-2023 16:09:21
(7) .entries_in_use PASSED
    <Data>
        <DoubleLongUnsigned Value="0000002E" />
    </Data>
(8) .profile_entries PASSED
    <Data>
        <DoubleLongUnsigned Value="000001F4" />
    </Data>

Mngmt Get Fraud Detection Log 0-0:99.98.1.255 (@316)
(9) .logical_name PASSED
    <Data>
        <OctetString Value="0000636201FF" />
    </Data>
(10) .buffer PASSED
    Earliest date: 02-JUL-2022 06:13:01, latest date: 27-OCT-2024 01:47:44
    Middle date: 18-APR-2023 10:37:58
(11) .entries_in_use PASSED
    <Data>
        <DoubleLongUnsigned Value="00000078" />
    </Data>
(12) .profile_entries PASSED
    <Data>
        <DoubleLongUnsigned Value="000000C8" />
    </Data>

Mngmt Get Communication Log 0-0:99.98.5.255 (@331)
(13) .logical_name PASSED
    <Data>
        <OctetString Value="0000636205FF" />
    </Data>
(14) .buffer PASSED
    Earliest date: 01-JUL-2022 01:54:56, latest date: 15-JUN-2023 17:58:42

```

```

Middle date: 28-FEB-2023 16:42:23
(15) .entries_in_use                                     PASSED
    <Data>
        <DoubleLongUnsigned Value="00000019" />
    </Data>
(16) .profile_entries                                   PASSED
    <Data>
        <DoubleLongUnsigned Value="000000C8" />
    </Data>

Mngmt Get Power Quality Log 0-0:99.98.4.255 (@1340)
(17) .logical_name                                     PASSED
    <Data>
        <OctetString Value="0000636204FF" />
    </Data>
(18) .buffer                                           PASSED
    Earliest date: 24-FEB-2022 11:19:45, latest date: 18-APR-2023 10:48:21
    Middle date: 24-FEB-2022 11:21:08
(19) .entries_in_use                                     PASSED
    <Data>
        <DoubleLongUnsigned Value="00000013" />
    </Data>
(20) .profile_entries                                   PASSED
    <Data>
        <DoubleLongUnsigned Value="000000C8" />
    </Data>

*****
Test Case 11 : Reading Data of Billing Period 1, 8 item(s)
*****

Mngmt Get Data of billing period 1 0-0:98.1.0.255 (@158)
(1) .logical_name                                     PASSED
    <Data>
        <OctetString Value="0000620100FF" />
    </Data>
(2) .buffer                                           PASSED
    Earliest date: 02-MAY-2023 00:00:00, latest date: 02-NOV-2024 00:00:00
    Middle date: 02-NOV-2023 00:00:00
(3) .capture_objects                                   PASSED
    <Data>
        <Array Qty="0005" >
            <Structure Qty="0004" >
                <LongUnsigned Value="0008" />
                <OctetString Value="0000010000FF" />
                <Integer Value="02" />
                <LongUnsigned Value="0000" />
            </Structure>
            <Structure Qty="0004" >
                <LongUnsigned Value="0003" />
                <OctetString Value="0100010801FF" />
                <Integer Value="02" />
                <LongUnsigned Value="0000" />
            </Structure>
            <Structure Qty="0004" >
                <LongUnsigned Value="0003" />
                <OctetString Value="0100010802FF" />
                <Integer Value="02" />
                <LongUnsigned Value="0000" />
            </Structure>
            <Structure Qty="0004" >
                <LongUnsigned Value="0003" />
                <OctetString Value="0100020801FF" />
                <Integer Value="02" />
                <LongUnsigned Value="0000" />
            </Structure>
            <Structure Qty="0004" >
                <LongUnsigned Value="0003" />
                <OctetString Value="0100020802FF" />
                <Integer Value="02" />
                <LongUnsigned Value="0000" />
            </Structure>
        </Array>
    </Data>

```

```

    </Data>
(4) .capture_period PASSED
    <Data>
      <DoubleLongUnsigned Value="00000000" />
    </Data>
(5) .sort_method PASSED
    <Data>
      <Enum Value="01" />
    </Data>
(6) .sort_object PASSED
    <Data>
      <Structure Qty="0004" >
        <LongUnsigned Value="0008" />
        <OctetString Value="0000010000FF" />
        <Integer Value="02" />
        <LongUnsigned Value="0000" />
      </Structure>
    </Data>
(7) .entries_in_use PASSED
    <Data>
      <DoubleLongUnsigned Value="0000000C" />
    </Data>
(8) .profile_entries PASSED
    <Data>
      <DoubleLongUnsigned Value="00000018" />
    </Data>

*****
Test Case 12 : Ext. M - M-Bus Setup LGZ G350, 52 item(s)
*****

Mngmt Get M-Bus master port setup 1 0-0:24.6.0.255 (@1566)
(1) .logical_name PASSED
    <Data>
      <OctetString Value="0000180600FF" />
    </Data>
(2) .comm_speed PASSED
    <Data>
      <Enum Value="03" />
    </Data>

Mngmt Get M-Bus master port setup 2 0-1:24.6.0.255 (@1570)
(3) .logical_name
INAPPLICABLE
  Optional object is not implemented
(4) .comm_speed
INAPPLICABLE
  Optional object is not implemented

Mngmt Get M-Bus client channel 1 0-1:24.1.0.255 (@1574)
(5) .logical_name PASSED
    <Data>
      <OctetString Value="0001180100FF" />
    </Data>
(6) .mbus_port_reference PASSED
    <Data>
      <OctetString Value="0000180600FF" />
    </Data>
(7) .capture_definition PASSED
    <Data>
      <Array Qty="0004" >
        <Structure Qty="0002" >
          <OctetString Value="\L" />
          <OctetString Value="933A" />
        </Structure>
        <Structure Qty="0002" >
          <OctetString Value="8940" />
          <OctetString Value="FD1A" />
        </Structure>
        <Structure Qty="0002" >
          <OctetString Value="" />
          <OctetString Value="" />
        </Structure>
      </Array>
    </Data>

```

```

        <Structure Qty="0002" >
            <OctetString Value="" />
            <OctetString Value="" />
        </Structure>
    </Array>
</Data>
(8) .capture_period PASSED
    <Data>
        <DoubleLongUnsigned Value="00000E10" />
    </Data>
(9) .primary_address PASSED
    <Data>
        <Unsigned Value="01" />
    </Data>
(10) .identification_number PASSED
    <Data>
        <DoubleLongUnsigned Value="00047BB1" />
    </Data>
(11) .manufacturer_id PASSED
    <Data>
        <LongUnsigned Value="19AC" />
    </Data>
(12) .version PASSED
    <Data>
        <Unsigned Value="02" />
    </Data>
(13) .device_type PASSED
    <Data>
        <Unsigned Value="03" />
    </Data>
(14) .access_number PASSED
    <Data>
        <Unsigned Value="00" />
    </Data>
(15) .status PASSED
    <Data>
        <Unsigned Value="00" />
    </Data>
(16) .alarm PASSED
    <Data>
        <Unsigned Value="00" />
    </Data>

Mngmt Get M-Bus client channel 2 0-2:24.1.0.255 (@1596)
(17) .logical_name PASSED
    <Data>
        <OctetString Value="0002180100FF" />
    </Data>
(18) .mbus_port_reference PASSED
    <Data>
        <OctetString Value="0000180600FF" />
    </Data>
(19) .capture_definition PASSED
    <Data>
        <Array Qty="0004" >
            <Structure Qty="0002" >
                <OctetString Value="\L" />
                <OctetString Value="933A" />
            </Structure>
            <Structure Qty="0002" >
                <OctetString Value="8940" />
                <OctetString Value="FD1A" />
            </Structure>
            <Structure Qty="0002" >
                <OctetString Value="" />
                <OctetString Value="" />
            </Structure>
            <Structure Qty="0002" >
                <OctetString Value="" />
                <OctetString Value="" />
            </Structure>
        </Array>
    </Data>

```

(20)	.capture_period	PASSED
	<Data>	
	<DoubleLongUnsigned Value="00000E10" />	
	</Data>	
(21)	.primary_address	PASSED
	<Data>	
	<Unsigned Value="02" />	
	</Data>	
(22)	.identification_number	PASSED
	<Data>	
	<DoubleLongUnsigned Value="00047BB2" />	
	</Data>	
(23)	.manufacturer_id	PASSED
	<Data>	
	<LongUnsigned Value="19AC" />	
	</Data>	
(24)	.version	PASSED
	<Data>	
	<Unsigned Value="02" />	
	</Data>	
(25)	.device_type	PASSED
	<Data>	
	<Unsigned Value="03" />	
	</Data>	
(26)	.access_number	PASSED
	<Data>	
	<Unsigned Value="00" />	
	</Data>	
(27)	.status	PASSED
	<Data>	
	<Unsigned Value="00" />	
	</Data>	
(28)	.alarm	PASSED
	<Data>	
	<Unsigned Value="00" />	
	</Data>	
Mngmt Get M-Bus client channel 3 0-3:24.1.0.255 (@1618)		
(29)	.logical_name	PASSED
	<Data>	
	<OctetString Value="0003180100FF" />	
	</Data>	
(30)	.mbus_port_reference	PASSED
	<Data>	
	<OctetString Value="0000180600FF" />	
	</Data>	
(31)	.capture_definition	PASSED
	<Data>	
	<Array Qty="0004" >	
	<Structure Qty="0002" >	
	<OctetString Value="\L" />	
	<OctetString Value="933A" />	
	</Structure>	
	<Structure Qty="0002" >	
	<OctetString Value="8940" />	
	<OctetString Value="FD1A" />	
	</Structure>	
	<Structure Qty="0002" >	
	<OctetString Value="" />	
	<OctetString Value="" />	
	</Structure>	
	<Structure Qty="0002" >	
	<OctetString Value="" />	
	<OctetString Value="" />	
	</Structure>	
	</Array>	
	</Data>	
(32)	.capture_period	PASSED
	<Data>	
	<DoubleLongUnsigned Value="00000E10" />	
	</Data>	
(33)	.primary_address	PASSED
	<Data>	

	<Unsigned Value="03" />	
	</Data>	
(34)	.identification_number	PASSED
	<Data>	
	<DoubleLongUnsigned Value="00047BB4" />	
	</Data>	
(35)	.manufacturer_id	PASSED
	<Data>	
	<LongUnsigned Value="19AC" />	
	</Data>	
(36)	.version	PASSED
	<Data>	
	<Unsigned Value="02" />	
	</Data>	
(37)	.device_type	PASSED
	<Data>	
	<Unsigned Value="03" />	
	</Data>	
(38)	.access_number	PASSED
	<Data>	
	<Unsigned Value="00" />	
	</Data>	
(39)	.status	PASSED
	<Data>	
	<Unsigned Value="00" />	
	</Data>	
(40)	.alarm	PASSED
	<Data>	
	<Unsigned Value="00" />	
	</Data>	
Mngmt Get M-Bus client channel 4 0-4:24.1.0.255 (@1640)		
(41)	.logical_name	PASSED
	<Data>	
	<OctetString Value="0004180100FF" />	
	</Data>	
(42)	.mbus_port_reference	PASSED
	<Data>	
	<OctetString Value="0000180600FF" />	
	</Data>	
(43)	.capture_definition	PASSED
	<Data>	
	<Array Qty="0004" >	
	<Structure Qty="0002" >	
	<OctetString Value="\L" />	
	<OctetString Value="933A" />	
	</Structure>	
	<Structure Qty="0002" >	
	<OctetString Value="8940" />	
	<OctetString Value="FD1A" />	
	</Structure>	
	<Structure Qty="0002" >	
	<OctetString Value="" />	
	<OctetString Value="" />	
	</Structure>	
	<Structure Qty="0002" >	
	<OctetString Value="" />	
	<OctetString Value="" />	
	</Structure>	
	</Array>	
	</Data>	
(44)	.capture_period	PASSED
	<Data>	
	<DoubleLongUnsigned Value="00000E10" />	
	</Data>	
(45)	.primary_address	PASSED
	<Data>	
	<Unsigned Value="04" />	
	</Data>	
(46)	.identification_number	PASSED
	<Data>	
	<DoubleLongUnsigned Value="00047BB3" />	
	</Data>	

(47)	.manufacturer_id	PASSED
	<Data>	
	<LongUnsigned Value="19AC" />	
	</Data>	
(48)	.version	PASSED
	<Data>	
	<Unsigned Value="02" />	
	</Data>	
(49)	.device_type	PASSED
	<Data>	
	<Unsigned Value="03" />	
	</Data>	
(50)	.access_number	PASSED
	<Data>	
	<Unsigned Value="00" />	
	</Data>	
(51)	.status	PASSED
	<Data>	
	<Unsigned Value="00" />	
	</Data>	
(52)	.alarm	PASSED
	<Data>	
	<Unsigned Value="00" />	
	</Data>	

Test Case 13 : Ext. M - M-Bus Results uncorrected Vol. & valve, 40 item(s)		

Mngmt Get M-Bus Value channel 1, instance 1 0-1:24.2.1.255 (@1662)		
(1)	.logical_name	PASSED
	<Data>	
	<OctetString Value="0001180201FF" />	
	</Data>	
(2)	.value	PASSED
	<Data>	
	<DoubleLongUnsigned Value="00000FB7" />	
	</Data>	
(3)	.scaler_unit	PASSED
	<Data>	
	<Structure Qty="0002" >	
	<Integer Value="FD" />	
	<Enum Value="0D" />	
	</Structure>	
	</Data>	
(4)	.status	PASSED
	<Data>	
	<Unsigned Value="04" />	
	</Data>	
(5)	.capture_time	PASSED
	<Data>	
	<OctetString Value="07E7060F04113A2100FF8880" />	
	</Data>	
Mngmt Get M-Bus Value channel 1, instance 2 0-1:24.2.2.255 (@1670)		
(6)	.logical_name	PASSED
	<Data>	
	<OctetString Value="0001180202FF" />	
	</Data>	
(7)	.value	PASSED
	<Data>	
	<DoubleLongUnsigned Value="00000001" />	
	</Data>	
(8)	.scaler_unit	PASSED
	<Data>	
	<Structure Qty="0002" >	
	<Integer Value="00" />	
	<Enum Value="FF" />	
	</Structure>	
	</Data>	
(9)	.status	PASSED
	<Data>	
	<Unsigned Value="04" />	

	</Data>	
(10)	.capture_time <Data> <OctetString Value="07E7060F04113A2100FF8880" /> </Data>	PASSED
	Mngmt Get M-Bus Value channel 2, instance 1 0-2:24.2.1.255 (@1694)	
(11)	.logical_name <Data> <OctetString Value="0002180201FF" /> </Data>	PASSED
(12)	.value <Data> <DoubleLongUnsigned Value="00000C02" /> </Data>	PASSED
(13)	.scaler_unit <Data> <Structure Qty="0002" > <Integer Value="FD" /> <Enum Value="0D" /> </Structure> </Data>	PASSED
(14)	.status <Data> <Unsigned Value="04" /> </Data>	PASSED
(15)	.capture_time <Data> <OctetString Value="07E7060F04113A2400FF8880" /> </Data>	PASSED
	Mngmt Get M-Bus Value channel 2, instance 2 0-2:24.2.2.255 (@1702)	
(16)	.logical_name <Data> <OctetString Value="0002180202FF" /> </Data>	PASSED
(17)	.value <Data> <DoubleLongUnsigned Value="00000001" /> </Data>	PASSED
(18)	.scaler_unit <Data> <Structure Qty="0002" > <Integer Value="00" /> <Enum Value="FF" /> </Structure> </Data>	PASSED
(19)	.status <Data> <Unsigned Value="04" /> </Data>	PASSED
(20)	.capture_time <Data> <OctetString Value="07E7060F04113A2400FF8880" /> </Data>	PASSED
	Mngmt Get M-Bus Value channel 3, instance 1 0-3:24.2.1.255 (@1726)	
(21)	.logical_name <Data> <OctetString Value="0003180201FF" /> </Data>	PASSED
(22)	.value <Data> <DoubleLongUnsigned Value="00000EEA" /> </Data>	PASSED
(23)	.scaler_unit <Data> <Structure Qty="0002" > <Integer Value="FD" /> <Enum Value="0D" /> </Structure> </Data>	PASSED
(24)	.status	PASSED

	<Data> <Unsigned Value="04" /> </Data>	
(25)	.capture_time <Data> <OctetString Value="07E7060F04113A2700FF8880" /> </Data>	PASSED
Mngmt Get M-Bus Value channel 3, instance 2 0-3:24.2.2.255 (@1734)		
(26)	.logical_name <Data> <OctetString Value="0003180202FF" /> </Data>	PASSED
(27)	.value <Data> <DoubleLongUnsigned Value="00000001" /> </Data>	PASSED
(28)	.scaler_unit <Data> <Structure Qty="0002" > <Integer Value="00" /> <Enum Value="FF" /> </Structure> </Data>	PASSED
(29)	.status <Data> <Unsigned Value="04" /> </Data>	PASSED
(30)	.capture_time <Data> <OctetString Value="07E7060F04113A2700FF8880" /> </Data>	PASSED
Mngmt Get M-Bus Value channel 4, instance 1 0-4:24.2.1.255 (@1758)		
(31)	.logical_name <Data> <OctetString Value="0004180201FF" /> </Data>	PASSED
(32)	.value <Data> <DoubleLongUnsigned Value="00000B1E" /> </Data>	PASSED
(33)	.scaler_unit <Data> <Structure Qty="0002" > <Integer Value="FD" /> <Enum Value="0D" /> </Structure> </Data>	PASSED
(34)	.status <Data> <Unsigned Value="04" /> </Data>	PASSED
(35)	.capture_time <Data> <OctetString Value="07E7060F04113A2A00FF8880" /> </Data>	PASSED
Mngmt Get M-Bus Value channel 4, instance 2 0-4:24.2.2.255 (@1766)		
(36)	.logical_name <Data> <OctetString Value="0004180202FF" /> </Data>	PASSED
(37)	.value <Data> <DoubleLongUnsigned Value="00000001" /> </Data>	PASSED
(38)	.scaler_unit <Data> <Structure Qty="0002" > <Integer Value="00" /> <Enum Value="FF" /> </Structure>	PASSED

```

    </Data>
(39) .status PASSED
    <Data>
        <Unsigned Value="04" />
    </Data>
(40) .capture_time PASSED
    <Data>
        <OctetString Value="07E7060F04113A2A00FF8880" />
    </Data>

*****
Test Case 14 : Ext. M - M-Bus Device IDs, 16 item(s)
*****

Mngmt Get M-Bus Device ID 1 channel 1 0-1:96.1.0.255 (@1790)
(1) .logical_name PASSED
    <Data>
        <OctetString Value="0001600100FF" />
    </Data>
(2) .value PASSED
    <Data>
        <OctetString Value="\00000540029380911" />
    </Data>

Mngmt Get M-Bus Device ID 1 channel 2 0-2:96.1.0.255 (@1794)
(3) .logical_name PASSED
    <Data>
        <OctetString Value="0002600100FF" />
    </Data>
(4) .value PASSED
    <Data>
        <OctetString Value="\00000540029381011" />
    </Data>

Mngmt Get M-Bus Device ID 1 channel 3 0-3:96.1.0.255 (@1798)
(5) .logical_name PASSED
    <Data>
        <OctetString Value="0003600100FF" />
    </Data>
(6) .value PASSED
    <Data>
        <OctetString Value="\00000540029381211" />
    </Data>

Mngmt Get M-Bus Device ID 1 channel 4 0-4:96.1.0.255 (@1802)
(7) .logical_name PASSED
    <Data>
        <OctetString Value="0004600100FF" />
    </Data>
(8) .value PASSED
    <Data>
        <OctetString Value="\00000540029381111" />
    </Data>

Mngmt Get M-Bus Device ID 2 channel 1 0-1:96.1.1.255 (@1806)
(9) .logical_name PASSED
    <Data>
        <OctetString Value="0001600101FF" />
    </Data>
(10) .value PASSED
    <Data>
        <OctetString Value="" />
    </Data>

Mngmt Get M-Bus Device ID 2 channel 2 0-2:96.1.1.255 (@1810)
(11) .logical_name PASSED
    <Data>
        <OctetString Value="0002600101FF" />
    </Data>
(12) .value PASSED
    <Data>
        <OctetString Value="" />
    </Data>

```

```

Mngmt Get M-Bus Device ID 2 channel 3 0-3:96.1.1.255 (@1814)
(13) .logical_name PASSED
    <Data>
      <OctetString Value="0003600101FF" />
    </Data>
(14) .value PASSED
    <Data>
      <OctetString Value="" />
    </Data>

Mngmt Get M-Bus Device ID 2 channel 4 0-4:96.1.1.255 (@1818)
(15) .logical_name PASSED
    <Data>
      <OctetString Value="0004600101FF" />
    </Data>
(16) .value PASSED
    <Data>
      <OctetString Value="" />
    </Data>

```

 Test Case 15 : Ext. M - M-Bus Load Profiles, 32 item(s)

```

Mngmt Get M-Bus Master Load profile for channel 1 0-1:24.3.0.255 (@1838)
(1) .logical_name PASSED
    <Data>
      <OctetString Value="0001180300FF" />
    </Data>
(2) .buffer PASSED
    Earliest date: 24-FEB-2022 12:00:00, latest date: 27-OCT-2024 02:00:00
    Middle date: 15-JUN-2024 01:00:00
(3) .capture_objects PASSED
    <Data>
      <Array Qty="0006" >
        <Structure Qty="0004" >
          <LongUnsigned Value="0008" />
          <OctetString Value="0000010000FF" />
          <Integer Value="02" />
          <LongUnsigned Value="0000" />
        </Structure>
        <Structure Qty="0004" >
          <LongUnsigned Value="0001" />
          <OctetString Value="0001600A03FF" />
          <Integer Value="02" />
          <LongUnsigned Value="0000" />
        </Structure>
        <Structure Qty="0004" >
          <LongUnsigned Value="0004" />
          <OctetString Value="0001180201FF" />
          <Integer Value="02" />
          <LongUnsigned Value="0000" />
        </Structure>
        <Structure Qty="0004" >
          <LongUnsigned Value="0004" />
          <OctetString Value="0001180202FF" />
          <Integer Value="02" />
          <LongUnsigned Value="0000" />
        </Structure>
        <Structure Qty="0004" >
          <LongUnsigned Value="0004" />
          <OctetString Value="0001180203FF" />
          <Integer Value="02" />
          <LongUnsigned Value="0000" />
        </Structure>
        <Structure Qty="0004" >
          <LongUnsigned Value="0004" />
          <OctetString Value="0001180204FF" />
          <Integer Value="02" />
          <LongUnsigned Value="0000" />
        </Structure>
      </Array>

```

	</Data>	
(4)	.capture_period	PASSED
	<Data>	
	<DoubleLongUnsigned Value="00000E10" />	
	</Data>	
(5)	.sort_method	PASSED
	<Data>	
	<Enum Value="01" />	
	</Data>	
(6)	.sort_object	PASSED
	<Data>	
	<Structure Qty="0004" >	
	<LongUnsigned Value="0008" />	
	<OctetString Value="0000010000FF" />	
	<Integer Value="02" />	
	<LongUnsigned Value="0000" />	
	</Structure>	
	</Data>	
(7)	.entries_in_use	PASSED
	<Data>	
	<DoubleLongUnsigned Value="00000095" />	
	</Data>	
(8)	.profile_entries	PASSED
	<Data>	
	<DoubleLongUnsigned Value="000000F0" />	
	</Data>	
	Mngmt Get M-Bus Master Load profile for channel 2 0-2:24.3.0.255 (@1849)	
(9)	.logical_name	PASSED
	<Data>	
	<OctetString Value="0002180300FF" />	
	</Data>	
(10)	.buffer	PASSED
	Earliest date: 24-FEB-2022 12:00:00, latest date: 27-OCT-2024 02:00:00	
	Middle date: 15-JUN-2024 01:00:00	
(11)	.capture_objects	PASSED
	<Data>	
	<Array Qty="0006" >	
	<Structure Qty="0004" >	
	<LongUnsigned Value="0008" />	
	<OctetString Value="0000010000FF" />	
	<Integer Value="02" />	
	<LongUnsigned Value="0000" />	
	</Structure>	
	<Structure Qty="0004" >	
	<LongUnsigned Value="0001" />	
	<OctetString Value="0002600A03FF" />	
	<Integer Value="02" />	
	<LongUnsigned Value="0000" />	
	</Structure>	
	<Structure Qty="0004" >	
	<LongUnsigned Value="0004" />	
	<OctetString Value="0002180201FF" />	
	<Integer Value="02" />	
	<LongUnsigned Value="0000" />	
	</Structure>	
	<Structure Qty="0004" >	
	<LongUnsigned Value="0004" />	
	<OctetString Value="0002180202FF" />	
	<Integer Value="02" />	
	<LongUnsigned Value="0000" />	
	</Structure>	
	<Structure Qty="0004" >	
	<LongUnsigned Value="0004" />	
	<OctetString Value="0002180203FF" />	
	<Integer Value="02" />	
	<LongUnsigned Value="0000" />	
	</Structure>	
	<Structure Qty="0004" >	
	<LongUnsigned Value="0004" />	
	<OctetString Value="0002180204FF" />	
	<Integer Value="02" />	
	<LongUnsigned Value="0000" />	

```

        </Structure>
    </Array>
    </Data>
(12) .capture_period PASSED
    <Data>
        <DoubleLongUnsigned Value="00000E10" />
    </Data>
(13) .sort_method PASSED
    <Data>
        <Enum Value="01" />
    </Data>
(14) .sort_object PASSED
    <Data>
        <Structure Qty="0004" >
            <LongUnsigned Value="0008" />
            <OctetString Value="0000010000FF" />
            <Integer Value="02" />
            <LongUnsigned Value="0000" />
        </Structure>
    </Data>
(15) .entries_in_use PASSED
    <Data>
        <DoubleLongUnsigned Value="00000095" />
    </Data>
(16) .profile_entries PASSED
    <Data>
        <DoubleLongUnsigned Value="000000F0" />
    </Data>

Mngmt Get M-Bus Master Load profile for channel 3 0-3:24.3.0.255 (@1860)
(17) .logical_name PASSED
    <Data>
        <OctetString Value="0003180300FF" />
    </Data>
(18) .buffer PASSED
    Earliest date: 24-FEB-2022 12:00:00, latest date: 27-OCT-2024 02:00:00
    Middle date: 15-JUN-2024 01:00:00
(19) .capture_objects PASSED
    <Data>
        <Array Qty="0006" >
            <Structure Qty="0004" >
                <LongUnsigned Value="0008" />
                <OctetString Value="0000010000FF" />
                <Integer Value="02" />
                <LongUnsigned Value="0000" />
            </Structure>
            <Structure Qty="0004" >
                <LongUnsigned Value="0001" />
                <OctetString Value="0003600A03FF" />
                <Integer Value="02" />
                <LongUnsigned Value="0000" />
            </Structure>
            <Structure Qty="0004" >
                <LongUnsigned Value="0004" />
                <OctetString Value="0003180201FF" />
                <Integer Value="02" />
                <LongUnsigned Value="0000" />
            </Structure>
            <Structure Qty="0004" >
                <LongUnsigned Value="0004" />
                <OctetString Value="0003180202FF" />
                <Integer Value="02" />
                <LongUnsigned Value="0000" />
            </Structure>
            <Structure Qty="0004" >
                <LongUnsigned Value="0004" />
                <OctetString Value="0003180203FF" />
                <Integer Value="02" />
                <LongUnsigned Value="0000" />
            </Structure>
            <Structure Qty="0004" >
                <LongUnsigned Value="0004" />
                <OctetString Value="0003180204FF" />
            </Structure>
        </Array>
    </Data>

```

```

        <Integer Value="02" />
        <LongUnsigned Value="0000" />
    </Structure>
</Array>
</Data>
(20) .capture_period PASSED
    <Data>
        <DoubleLongUnsigned Value="00000E10" />
    </Data>
(21) .sort_method PASSED
    <Data>
        <Enum Value="01" />
    </Data>
(22) .sort_object PASSED
    <Data>
        <Structure Qty="0004" >
            <LongUnsigned Value="0008" />
            <OctetString Value="0000010000FF" />
            <Integer Value="02" />
            <LongUnsigned Value="0000" />
        </Structure>
    </Data>
(23) .entries_in_use PASSED
    <Data>
        <DoubleLongUnsigned Value="00000095" />
    </Data>
(24) .profile_entries PASSED
    <Data>
        <DoubleLongUnsigned Value="000000F0" />
    </Data>

Mngmt Get M-Bus Master Load profile for channel 4 0-4:24.3.0.255 (@1871)
(25) .logical_name PASSED
    <Data>
        <OctetString Value="0004180300FF" />
    </Data>
(26) .buffer PASSED
    Earliest date: 24-FEB-2022 12:00:00, latest date: 27-OCT-2024 02:00:00
    Middle date: 15-JUN-2024 01:00:00
(27) .capture_objects PASSED
    <Data>
        <Array Qty="0006" >
            <Structure Qty="0004" >
                <LongUnsigned Value="0008" />
                <OctetString Value="0000010000FF" />
                <Integer Value="02" />
                <LongUnsigned Value="0000" />
            </Structure>
            <Structure Qty="0004" >
                <LongUnsigned Value="0001" />
                <OctetString Value="0004600A03FF" />
                <Integer Value="02" />
                <LongUnsigned Value="0000" />
            </Structure>
            <Structure Qty="0004" >
                <LongUnsigned Value="0004" />
                <OctetString Value="0004180201FF" />
                <Integer Value="02" />
                <LongUnsigned Value="0000" />
            </Structure>
            <Structure Qty="0004" >
                <LongUnsigned Value="0004" />
                <OctetString Value="0004180202FF" />
                <Integer Value="02" />
                <LongUnsigned Value="0000" />
            </Structure>
            <Structure Qty="0004" >
                <LongUnsigned Value="0004" />
                <OctetString Value="0004180203FF" />
                <Integer Value="02" />
                <LongUnsigned Value="0000" />
            </Structure>
        </Array>
    </Data>

```



```

        <LongUnsigned Value="0004" />
        <OctetString Value="0004180204FF" />
        <Integer Value="02" />
        <LongUnsigned Value="0000" />
    </Structure>
</Array>
</Data>
(28) .capture_period PASSED
    <Data>
        <DoubleLongUnsigned Value="00000E10" />
    </Data>
(29) .sort_method PASSED
    <Data>
        <Enum Value="01" />
    </Data>
(30) .sort_object PASSED
    <Data>
        <Structure Qty="0004" >
            <LongUnsigned Value="0008" />
            <OctetString Value="0000010000FF" />
            <Integer Value="02" />
            <LongUnsigned Value="0000" />
        </Structure>
    </Data>
(31) .entries_in_use PASSED
    <Data>
        <DoubleLongUnsigned Value="00000095" />
    </Data>
(32) .profile_entries PASSED
    <Data>
        <DoubleLongUnsigned Value="000000F0" />
    </Data>

```

 Test Case 16 : Ext. M - M-Bus Control Logs, 40 item(s)

```

Mngmt Get M-Bus Master Control log object 1 0-1:24.5.0.255 (@1941)
(1) .logical_name PASSED
    <Data>
        <OctetString Value="0001180500FF" />
    </Data>
(2) .buffer PASSED
    Earliest date: 04-JUL-2022 21:28:06, latest date: 04-JUL-2022 21:42:25
    Middle date: 04-JUL-2022 21:41:11
(3) .capture_objects PASSED
    <Data>
        <Array Qty="0002" >
            <Structure Qty="0004" >
                <LongUnsigned Value="0008" />
                <OctetString Value="0000010000FF" />
                <Integer Value="02" />
                <LongUnsigned Value="0000" />
            </Structure>
            <Structure Qty="0004" >
                <LongUnsigned Value="0001" />
                <OctetString Value="0001600B04FF" />
                <Integer Value="02" />
                <LongUnsigned Value="0000" />
            </Structure>
        </Array>
    </Data>
(4) .capture_period PASSED
    <Data>
        <DoubleLongUnsigned Value="00000000" />
    </Data>
(5) .sort_method PASSED
    <Data>
        <Enum Value="01" />
    </Data>
(6) .sort_object PASSED
    <Data>
        <Structure Qty="0004" >

```

	<pre> <LongUnsigned Value="0008" /> <OctetString Value="0000010000FF" /> <Integer Value="02" /> <LongUnsigned Value="0000" /> </Structure> </Data> </pre>	
(7)	.entries_in_use	PASSED
	<pre> <Data> <DoubleLongUnsigned Value="00000006" /> </Data> </pre>	
(8)	.profile_entries	PASSED
	<pre> <Data> <DoubleLongUnsigned Value="000000C8" /> </Data> </pre>	
	Mngmt Get M-Bus Master Control log object 2 0-2:24.5.0.255 (@1952)	
(9)	.logical_name	PASSED
	<pre> <Data> <OctetString Value="0002180500FF" /> </Data> </pre>	
(10)	.buffer	PASSED
	Earliest date: 04-JUL-2022 21:28:07, latest date: 04-JUL-2022 21:42:26 Middle date: 04-JUL-2022 21:41:12	
(11)	.capture_objects	PASSED
	<pre> <Data> <Array Qty="0002" > <Structure Qty="0004" > <LongUnsigned Value="0008" /> <OctetString Value="0000010000FF" /> <Integer Value="02" /> <LongUnsigned Value="0000" /> </Structure> <Structure Qty="0004" > <LongUnsigned Value="0001" /> <OctetString Value="0002600B04FF" /> <Integer Value="02" /> <LongUnsigned Value="0000" /> </Structure> </Array> </Data> </pre>	
(12)	.capture_period	PASSED
	<pre> <Data> <DoubleLongUnsigned Value="00000000" /> </Data> </pre>	
(13)	.sort_method	PASSED
	<pre> <Data> <Enum Value="01" /> </Data> </pre>	
(14)	.sort_object	PASSED
	<pre> <Data> <Structure Qty="0004" > <LongUnsigned Value="0008" /> <OctetString Value="0000010000FF" /> <Integer Value="02" /> <LongUnsigned Value="0000" /> </Structure> </Data> </pre>	
(15)	.entries_in_use	PASSED
	<pre> <Data> <DoubleLongUnsigned Value="00000006" /> </Data> </pre>	
(16)	.profile_entries	PASSED
	<pre> <Data> <DoubleLongUnsigned Value="000000C8" /> </Data> </pre>	
	Mngmt Get M-Bus Master Control log object 3 0-3:24.5.0.255 (@1963)	
(17)	.logical_name	PASSED
	<pre> <Data> <OctetString Value="0003180500FF" /> </Data> </pre>	
(18)	.buffer	PASSED
	Earliest date: 04-JUL-2022 21:28:07, latest date: 04-JUL-2022 21:42:26	

Middle date: 04-JUL-2022 21:41:12		
(19)	.capture_objects <Data> <Array Qty="0002" > <Structure Qty="0004" > <LongUnsigned Value="0008" /> <OctetString Value="0000010000FF" /> <Integer Value="02" /> <LongUnsigned Value="0000" /> </Structure> <Structure Qty="0004" > <LongUnsigned Value="0001" /> <OctetString Value="0003600B04FF" /> <Integer Value="02" /> <LongUnsigned Value="0000" /> </Structure> </Array> </Data>	PASSED
(20)	.capture_period <Data> <DoubleLongUnsigned Value="00000000" /> </Data>	PASSED
(21)	.sort_method <Data> <Enum Value="01" /> </Data>	PASSED
(22)	.sort_object <Data> <Structure Qty="0004" > <LongUnsigned Value="0008" /> <OctetString Value="0000010000FF" /> <Integer Value="02" /> <LongUnsigned Value="0000" /> </Structure> </Data>	PASSED
(23)	.entries_in_use <Data> <DoubleLongUnsigned Value="00000006" /> </Data>	PASSED
(24)	.profile_entries <Data> <DoubleLongUnsigned Value="000000C8" /> </Data>	PASSED
Mngmt Get M-Bus Master Control log object 4 0-4:24.5.0.255 (@1974)		
(25)	.logical_name <Data> <OctetString Value="0004180500FF" /> </Data>	PASSED
(26)	.buffer Earliest date: 04-JUL-2022 21:28:07, latest date: 04-JUL-2022 21:42:26 Middle date: 04-JUL-2022 21:41:12	PASSED
(27)	.capture_objects <Data> <Array Qty="0002" > <Structure Qty="0004" > <LongUnsigned Value="0008" /> <OctetString Value="0000010000FF" /> <Integer Value="02" /> <LongUnsigned Value="0000" /> </Structure> <Structure Qty="0004" > <LongUnsigned Value="0001" /> <OctetString Value="0004600B04FF" /> <Integer Value="02" /> <LongUnsigned Value="0000" /> </Structure> </Array> </Data>	PASSED
(28)	.capture_period <Data> <DoubleLongUnsigned Value="00000000" /> </Data>	PASSED

(29)	.sort_method	PASSED
	<Data>	
	<Enum Value="01" />	
	</Data>	
(30)	.sort_object	PASSED
	<Data>	
	<Structure Qty="0004" >	
	<LongUnsigned Value="0008" />	
	<OctetString Value="0000010000FF" />	
	<Integer Value="02" />	
	<LongUnsigned Value="0000" />	
	</Structure>	
	</Data>	
(31)	.entries_in_use	PASSED
	<Data>	
	<DoubleLongUnsigned Value="00000006" />	
	</Data>	
(32)	.profile_entries	PASSED
	<Data>	
	<DoubleLongUnsigned Value="000000C8" />	
	</Data>	
Mngmt Get M-Bus Event Log 0-0:99.98.3.255 (@1989)		
(33)	.logical_name	PASSED
	<Data>	
	<OctetString Value="0000636203FF" />	
	</Data>	
(34)	.buffer	PASSED
	Earliest date: 04-JUL-2022 21:48:18, latest date: 04-JUL-2022 21:52:37	
	Middle date: 04-JUL-2022 21:50:12	
(35)	.capture_objects	PASSED
	<Data>	
	<Array Qty="0002" >	
	<Structure Qty="0004" >	
	<LongUnsigned Value="0008" />	
	<OctetString Value="0000010000FF" />	
	<Integer Value="02" />	
	<LongUnsigned Value="0000" />	
	</Structure>	
	<Structure Qty="0004" >	
	<LongUnsigned Value="0001" />	
	<OctetString Value="0000600B03FF" />	
	<Integer Value="02" />	
	<LongUnsigned Value="0000" />	
	</Structure>	
	</Array>	
	</Data>	
(36)	.capture_period	PASSED
	<Data>	
	<DoubleLongUnsigned Value="00000000" />	
	</Data>	
(37)	.sort_method	PASSED
	<Data>	
	<Enum Value="01" />	
	</Data>	
(38)	.sort_object	PASSED
	<Data>	
	<Structure Qty="0004" >	
	<LongUnsigned Value="0008" />	
	<OctetString Value="0000010000FF" />	
	<Integer Value="02" />	
	<LongUnsigned Value="0000" />	
	</Structure>	
	</Data>	
(39)	.entries_in_use	PASSED
	<Data>	
	<DoubleLongUnsigned Value="00000005" />	
	</Data>	
(40)	.profile_entries	PASSED
	<Data>	
	<DoubleLongUnsigned Value="000000C8" />	
	</Data>	

```

*****
Test Case 17 : Ext. M - M-Bus Disconnect, 22 item(s)
*****

Mngmt Get M-Bus Master Disconnect control object 1 0-1:24.4.0.255 (@1882)
(1) .logical_name PASSED
    <Data>
    <OctetString Value="0001180400FF" />
    </Data>
(2) .output_state PASSED
    <Data>
    <Boolean Value="00" />
    </Data>
(3) .control_state PASSED
    <Data>
    <Enum Value="00" />
    </Data>
(4) .control_mode PASSED
    <Data>
    <Enum Value="06" />
    </Data>

Mngmt Get M-Bus Master Disconnect control object 2 0-2:24.4.0.255 (@1890)
(5) .logical_name PASSED
    <Data>
    <OctetString Value="0002180400FF" />
    </Data>
(6) .output_state PASSED
    <Data>
    <Boolean Value="00" />
    </Data>
(7) .control_state PASSED
    <Data>
    <Enum Value="00" />
    </Data>
(8) .control_mode PASSED
    <Data>
    <Enum Value="06" />
    </Data>

Mngmt Get M-Bus Master Disconnect control object 3 0-3:24.4.0.255 (@1898)
(9) .logical_name PASSED
    <Data>
    <OctetString Value="0003180400FF" />
    </Data>
(10) .output_state PASSED
    <Data>
    <Boolean Value="00" />
    </Data>
(11) .control_state PASSED
    <Data>
    <Enum Value="00" />
    </Data>
(12) .control_mode PASSED
    <Data>
    <Enum Value="06" />
    </Data>

Mngmt Get M-Bus Master Disconnect control object 4 0-4:24.4.0.255 (@1906)
(13) .logical_name PASSED
    <Data>
    <OctetString Value="0004180400FF" />
    </Data>
(14) .output_state PASSED
    <Data>
    <Boolean Value="00" />
    </Data>
(15) .control_state PASSED
    <Data>
    <Enum Value="00" />
    </Data>
(16) .control_mode PASSED
    <Data>

```

```

        <Enum Value="06" />
    </Data>

Mngmt Get M-Bus Disconnect control scheduler 0-1:15.0.1.255 (@1914)
(17) .logical_name PASSED
    <Data>
        <OctetString Value="00010F0001FF" />
    </Data>
(18) .executed_script PASSED
    <Data>
        <Structure Qty="0002" >
            <OctetString Value="00010A006AFF" />
            <LongUnsigned Value="0001" />
        </Structure>
    </Data>
(19) .type PASSED
    <Data>
        <Enum Value="01" />
    </Data>
(20) .execution_time PASSED
    <Data>
        <Array Qty="0001" >
            <Structure Qty="0002" >
                <OctetString Value="FFFFFFFF" />
                <OctetString Value="FFFFFFFF" />
            </Structure>
        </Array>
    </Data>

Mngmt Get M-Bus Disconnect script table 0-1:10.0.106.255 (@1920)
(21) .logical_name PASSED
    <Data>
        <OctetString Value="00010A006AFF" />
    </Data>
(22) .scripts PASSED
    <Data>
        <Array Qty="0010" >
            <Structure Qty="0002" >
                <LongUnsigned Value="0001" />
                <Array Qty="0001" >
                    <Structure Qty="0005" >
                        <Enum Value="01" />
                        <LongUnsigned Value="0046" />
                        <OctetString Value="0001180400FF" />
                        <Integer Value="03" />
                        <Enum Value="02" />
                    </Structure>
                </Array>
            </Structure>
            <Structure Qty="0002" >
                <LongUnsigned Value="0002" />
                <Array Qty="0001" >
                    <Structure Qty="0005" >
                        <Enum Value="01" />
                        <LongUnsigned Value="0046" />
                        <OctetString Value="0001180400FF" />
                        <Integer Value="03" />
                        <Enum Value="01" />
                    </Structure>
                </Array>
            </Structure>
            <Structure Qty="0002" >
                <LongUnsigned Value="0003" />
                <Array Qty="0001" >
                    <Structure Qty="0005" >
                        <Enum Value="01" />
                        <LongUnsigned Value="0046" />
                        <OctetString Value="0002180400FF" />
                        <Integer Value="03" />
                        <Enum Value="02" />
                    </Structure>
                </Array>
            </Structure>
        </Array>
    </Data>

```

```

<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <Array Qty="0001" >
    <Structure Qty="0005" >
      <Enum Value="01" />
      <LongUnsigned Value="0046" />
      <OctetString Value="0002180400FF" />
      <Integer Value="03" />
      <Enum Value="01" />
    </Structure>
  </Array>
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0005" />
  <Array Qty="0001" >
    <Structure Qty="0005" >
      <Enum Value="01" />
      <LongUnsigned Value="0046" />
      <OctetString Value="0003180400FF" />
      <Integer Value="03" />
      <Enum Value="02" />
    </Structure>
  </Array>
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0006" />
  <Array Qty="0001" >
    <Structure Qty="0005" >
      <Enum Value="01" />
      <LongUnsigned Value="0046" />
      <OctetString Value="0003180400FF" />
      <Integer Value="03" />
      <Enum Value="01" />
    </Structure>
  </Array>
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0007" />
  <Array Qty="0001" >
    <Structure Qty="0005" >
      <Enum Value="01" />
      <LongUnsigned Value="0046" />
      <OctetString Value="0004180400FF" />
      <Integer Value="03" />
      <Enum Value="02" />
    </Structure>
  </Array>
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0008" />
  <Array Qty="0001" >
    <Structure Qty="0005" >
      <Enum Value="01" />
      <LongUnsigned Value="0046" />
      <OctetString Value="0004180400FF" />
      <Integer Value="03" />
      <Enum Value="01" />
    </Structure>
  </Array>
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0009" />
  <Array Qty="0001" >
    <Structure Qty="0005" >
      <Enum Value="02" />
      <LongUnsigned Value="0046" />
      <OctetString Value="0001180400FF" />
      <Integer Value="01" />
      <Enum Value="00" />
    </Structure>
  </Array>
</Structure>
<Structure Qty="0002" >

```

```

<LongUnsigned Value="000A" />
<Array Qty="0001" >
  <Structure Qty="0005" >
    <Enum Value="02" />
    <LongUnsigned Value="0046" />
    <OctetString Value="0001180400FF" />
    <Integer Value="02" />
    <Enum Value="00" />
  </Structure>
</Array>
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="000B" />
  <Array Qty="0001" >
    <Structure Qty="0005" >
      <Enum Value="02" />
      <LongUnsigned Value="0046" />
      <OctetString Value="0002180400FF" />
      <Integer Value="01" />
      <Enum Value="00" />
    </Structure>
  </Array>
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="000C" />
  <Array Qty="0001" >
    <Structure Qty="0005" >
      <Enum Value="02" />
      <LongUnsigned Value="0046" />
      <OctetString Value="0002180400FF" />
      <Integer Value="02" />
      <Enum Value="00" />
    </Structure>
  </Array>
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="000D" />
  <Array Qty="0001" >
    <Structure Qty="0005" >
      <Enum Value="02" />
      <LongUnsigned Value="0046" />
      <OctetString Value="0003180400FF" />
      <Integer Value="01" />
      <Enum Value="00" />
    </Structure>
  </Array>
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="000E" />
  <Array Qty="0001" >
    <Structure Qty="0005" >
      <Enum Value="02" />
      <LongUnsigned Value="0046" />
      <OctetString Value="0003180400FF" />
      <Integer Value="02" />
      <Enum Value="00" />
    </Structure>
  </Array>
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="000F" />
  <Array Qty="0001" >
    <Structure Qty="0005" >
      <Enum Value="02" />
      <LongUnsigned Value="0046" />
      <OctetString Value="0004180400FF" />
      <Integer Value="01" />
      <Enum Value="00" />
    </Structure>
  </Array>
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0010" />

```



```

        <Array Qty="0001" >
            <Structure Qty="0005" >
                <Enum Value="02" />
                <LongUnsigned Value="0046" />
                <OctetString Value="0004180400FF" />
                <Integer Value="02" />
                <Enum Value="00" />
            </Structure>
        </Array>
    </Structure>
</Array>
</Data>

*****
Test Case 18 : FIT Push, 3 item(s)
*****
    (1) Push on installation                                     PASSED
    (2) Push on alarm                                           PASSED
    (3) Push on power down
INAPPLICABLE
    Push setup on power down not available

*****
Test Case 19 : FIT Miscellaneous, 4 item(s)
*****
    (1) Disconnecter Script Table                               PASSED
    (2) Load profile with period 1 DST ambiguity               PASSED
    (3) Load profile power down withing one period             PASSED
    (4) Load profile power down over two periods               PASSED

*****
* CTI *
*****

// Conformance Test Information (CTI) Template
// 2.3

Manufacturer = {
    Name = 'Wasion Group Limited'
    ThreeLettersId = 'WSE'
}

DeviceUnderTest = {
    Type = '\aMeter300'
    IDISDeviceType = 103
    IDISFunctionType = [Extension_D, Extension_L, Extension_M]
    SerialNr = 03684408
    IPVersion = IPv6
    DataLinkLayer = G3
    ConsumerInformationPush = FALSE
    EUI64Address = "386E21FFFE383838"

    SMSSupported = FALSE
    ClipCallSupported = FALSE
}

TestOptions = {
    PushDestination = '\[fe80:0:0:0:781d:ff:fe00:0]:61616'
}

ObjectModel = {
    // Optional objects implemented
    // Optional objects implemented
    OptionalObjects = '\
        + '1-1:0.2.0.255|1,' // Active firmware identifier 1 (@420)
        + '1-1:0.2.8.255|1' // Active firmware signature 1 (@424)

    InstanceExtraInfo = {
        // Activity Calendar (@112)
        LogicalName = '0-0:13.0.0.255'
        ClassId = 20
    }
}

```

```

MethodExtraInfo = {
  // activate_passive_calendar
  MethodId = 1
  AccessRights = [ACTION]
}
}

//Class 91 attribute 5.
InstanceExtraInfo = {
  // G3-PLC MAC Setup (1277)
  LogicalName = '0-0:29.1.0.255'
  ClassId = 91
  AttributeExtraInfo = {
    //mac_key_table
    AttributeId = 5
    SetData = '\<Data>'
+'   <Array Qty="01" >'
+'     <Structure Qty="02" >'
+'       <Unsigned Value="00" />'
+'       <OctetString Value="AF4D6DCCF14DE7C1C4235E6FEF6C151F" />'
+'     </Structure>'
+'   </Array>'
+' </Data>'

  }
}

// Set value for Consumer Message Text
InstanceExtraInfo = {
  LogicalName = '0-0:96.13.0.255'
  ClassId = 1
  AttributeExtraInfo = {
    AttributeId = 2
    SetData = '\<Data><OctetString Value="3132333435363738" /></Data>'
  }
}

InstanceExtraInfo = {
  LogicalName = '0-0:1.0.0.255'
  ClassId = 8
  AttributeExtraInfo = {
    AttributeId = 2
    SetData = '\<Data><OctetString Value="07E7060FFF10000FF8000FF" /></Data>' // yyyy mm
dd dow hh mm ss
  }
}

InstanceExtraInfo = {
  // Set special days to 30 entries
  LogicalName = '0-0:11.0.0.255'
  ClassId = 11
  AttributeExtraInfo = {
    AttributeId = 2
    SetData = '\<Data>'
+'   <Array Qty="1E" >'
+'     <Structure Qty="03" >'
+'       <LongUnsigned Value="0001" />'
+'       <OctetString Value="FFFF0101FF" />'
+'       <Unsigned Value="02" />'
+'     </Structure>'
+'     <Structure Qty="03" >'
+'       <LongUnsigned Value="0002" />'
+'       <OctetString Value="FFFF0102FF" />'
+'       <Unsigned Value="02" />'
+'     </Structure>'
+'     <Structure Qty="03" >'
+'       <LongUnsigned Value="0003" />'
+'       <OctetString Value="FFFF0103FF" />'
+'       <Unsigned Value="02" />'
+'     </Structure>'
+'     <Structure Qty="03" >'
+'       <LongUnsigned Value="0004" />'
+'       <OctetString Value="FFFF0104FF" />'
+'     </Structure>'
  }
}

```

```

+'          <Unsigned Value="02" />'
+'        </Structure>'
+'      <Structure Qty="03" >'
+'        <LongUnsigned Value="0005" />'
+'        <OctetString Value="FFFF0105FF" />'
+'        <Unsigned Value="02" />'
+'      </Structure>'
+'    <Structure Qty="03" >'
+'      <LongUnsigned Value="0006" />'
+'      <OctetString Value="FFFF0106FF" />'
+'      <Unsigned Value="02" />'
+'    </Structure>'
+'  <Structure Qty="03" >'
+'    <LongUnsigned Value="0007" />'
+'    <OctetString Value="FFFF0107FF" />'
+'    <Unsigned Value="02" />'
+'  </Structure>'
+' <Structure Qty="03" >'
+'   <LongUnsigned Value="0008" />'
+'   <OctetString Value="FFFF0108FF" />'
+'   <Unsigned Value="02" />'
+' </Structure>'
+' <Structure Qty="03" >'
+'   <LongUnsigned Value="0009" />'
+'   <OctetString Value="FFFF0109FF" />'
+'   <Unsigned Value="02" />'
+' </Structure>'
+' <Structure Qty="03" >'
+'   <LongUnsigned Value="000A" />'
+'   <OctetString Value="FFFF010AFF" />'
+'   <Unsigned Value="02" />'
+' </Structure>'
+' <Structure Qty="03" >'
+'   <LongUnsigned Value="000B" />'
+'   <OctetString Value="FFFF0201FF" />'
+'   <Unsigned Value="02" />'
+' </Structure>'
+' <Structure Qty="03" >'
+'   <LongUnsigned Value="000C" />'
+'   <OctetString Value="FFFF0202FF" />'
+'   <Unsigned Value="02" />'
+' </Structure>'
+' <Structure Qty="03" >'
+'   <LongUnsigned Value="000D" />'
+'   <OctetString Value="FFFF0203FF" />'
+'   <Unsigned Value="02" />'
+' </Structure>'
+' <Structure Qty="03" >'
+'   <LongUnsigned Value="000E" />'
+'   <OctetString Value="FFFF0204FF" />'
+'   <Unsigned Value="02" />'
+' </Structure>'
+' <Structure Qty="03" >'
+'   <LongUnsigned Value="000F" />'
+'   <OctetString Value="FFFF0205FF" />'
+'   <Unsigned Value="02" />'
+' </Structure>'
+' <Structure Qty="03" >'
+'   <LongUnsigned Value="0010" />'
+'   <OctetString Value="FFFF0206FF" />'
+'   <Unsigned Value="02" />'
+' </Structure>'
+' <Structure Qty="03" >'
+'   <LongUnsigned Value="0011" />'
+'   <OctetString Value="FFFF0207FF" />'
+'   <Unsigned Value="02" />'
+' </Structure>'
+' <Structure Qty="03" >'
+'   <LongUnsigned Value="0012" />'
+'   <OctetString Value="FFFF0208FF" />'
+'   <Unsigned Value="02" />'
+' </Structure>'
+' <Structure Qty="03" >'

```

```

+'          <LongUnsigned Value="0013" />'
+'          <OctetString Value="FFFF0209FF" />'
+'          <Unsigned Value="02" />'
+'        </Structure>'
+'      <Structure Qty="03" >'
+'        <LongUnsigned Value="0014" />'
+'        <OctetString Value="FFFF020AFF" />'
+'        <Unsigned Value="02" />'
+'      </Structure>'
+'    <Structure Qty="03" >'
+'      <LongUnsigned Value="0015" />'
+'      <OctetString Value="FFFF0301FF" />'
+'      <Unsigned Value="02" />'
+'    </Structure>'
+'  <Structure Qty="03" >'
+'    <LongUnsigned Value="0016" />'
+'    <OctetString Value="FFFF0302FF" />'
+'    <Unsigned Value="02" />'
+'  </Structure>'
+' <Structure Qty="03" >'
+'   <LongUnsigned Value="0017" />'
+'   <OctetString Value="FFFF0303FF" />'
+'   <Unsigned Value="02" />'
+' </Structure>'
+' <Structure Qty="03" >'
+'   <LongUnsigned Value="0018" />'
+'   <OctetString Value="FFFF0304FF" />'
+'   <Unsigned Value="02" />'
+' </Structure>'
+' <Structure Qty="03" >'
+'   <LongUnsigned Value="0019" />'
+'   <OctetString Value="FFFF0305FF" />'
+'   <Unsigned Value="02" />'
+' </Structure>'
+' <Structure Qty="03" >'
+'   <LongUnsigned Value="001A" />'
+'   <OctetString Value="FFFF0306FF" />'
+'   <Unsigned Value="02" />'
+' </Structure>'
+' <Structure Qty="03" >'
+'   <LongUnsigned Value="001B" />'
+'   <OctetString Value="FFFF0307FF" />'
+'   <Unsigned Value="02" />'
+' </Structure>'
+' <Structure Qty="03" >'
+'   <LongUnsigned Value="001C" />'
+'   <OctetString Value="FFFF0308FF" />'
+'   <Unsigned Value="02" />'
+' </Structure>'
+' <Structure Qty="03" >'
+'   <LongUnsigned Value="001D" />'
+'   <OctetString Value="FFFF0309FF" />'
+'   <Unsigned Value="02" />'
+' </Structure>'
+' <Structure Qty="03" >'
+'   <LongUnsigned Value="001E" />'
+'   <OctetString Value="FFFF030AFF" />'
+'   <Unsigned Value="02" />'
+' </Structure>'
+' </Array>'
+' </Data>'
+'
+' }
+'
+' }

```

```

TestParameters = {
  ConnectDisconnectDelay = 5000
  ClientSystemTitle = '58585A0102030405'

  ImageTransfer = {
    ImageIdentifier = '\WASION--aM300MV4.ODC341-0001'
    ImageFileName = '\aM300-L-B0500202-(Legal).bin'
  }
}

```

```

    Timeout = 300000
}

PushTimeout = 60000
MinInterWPDUFramesDelay = 1000
ProfilePeriodsQty = 6
CaptureDelay = 10000
ClipCallDuration = 20000

AutoConnect = {
    Repetitions = 0
    RepetitionDelay = 0
}

PushSetup = {
    NumberOfRetries = 1
    RepetitionDelay = 30
}

WakeUpDelay = 30000
DisconnectToSendSMSDelay = 10000
DataNotificationToDisconnectDelay = 3000
}

RemoteSecurityElements = {
    Public = {
        ContextName = LONG_NAMES
        MechanismName = LOWEST_LEVEL_SECURITY
        Policy = NO_SECURITY
    }
    Management = {
        ContextName = LONG_NAMES_WITH_CIPHERING
        MechanismName = HIGH_LEVEL_SECURITY_GMAC
        Policy = AUTHENTICATION_AND_ENCRYPTION
        Password = '\12345678'
    }
    PreEstablished = {
        Policy = AUTHENTICATION_AND_ENCRYPTION
        ServerMaxReceivePduSize = 1200
        CipheringStyle = GENERAL
    }
}

LocalSecurityElements = {
    Public = {
        ContextName = LONG_NAMES
        MechanismName = LOWEST_LEVEL_SECURITY
        Policy = NO_SECURITY
    }
    Management = {
        ContextName = LONG_NAMES
        MechanismName = LOW_LEVEL_SECURITY
        Policy = NO_SECURITY
        Password = '\12345678'
    }
    PreEstablished = {
        Policy = NO_SECURITY
        ServerMaxReceivePduSize = 1200
        CipheringStyle = GENERAL
    }
}

SMSSecurityElements = {
    PreEstablished = {
        Policy = AUTHENTICATION_AND_ENCRYPTION
        ServerMaxReceivePduSize = 138
        CipheringStyle = GENERAL
    }
}

HDLCPProfile = {
    PhysicalLayer = {

```

```

OpeningMode = DIRECT_HDLC
  HdlcBaud = 9600
}
DataLinkLayer = {
  InactivityTimeout      = 180000
  InterFrameTimeout     = 400
  ResponseTimeout       = 10000
  DISCToNDMTimeout     = 6000
  AddressingSchemes     = [FOUR_BYTES_ADDRESSING]
  ServerLowerMACAddress = 16
}
}

TCPProfile = {
  ServerTCPPort = 4059
  ResponseTimeout = 10000
  ConnectTimeout = 5000
  DisconnectToConnectDelay = 3000
}

G3PLCProfile = {
  ResponseTimeout = 20000
  FrequencyBand = FCC
  ConnectTimeout = 20000
  UDPPort = 61616
  PSK = "00112233445566778899AABBCCDDEEFF"
}

// END CTI_Template

*****
* Miscellaneous *
*****

TestMode:           G3-PLC
Test Plan Signature: BFC18D5882976F2087BC007B67CDC246
Object Model:      IDIS-S02-002 - object model Pack2 Ed2.0 - V2.29 (20200831)-FIT MBUS
Tests G350 (CorrectedAndValve status).xlsx
DUT system title:  5753456770383838
Run number:        2166

```