

```
*****
IDIS Conformance test report
21-DEC-2022 14:35:32
iCTT2 Package 2, Edition 2.0, Revision 1 (136)
Licensed to: DNV-GL IDIS Conf
Tester: Tom Levels
*****
```

```
*****
* Identification *
*****
```

```
Manufacturer = {
  Name = '\Mikroelektronika'
  ThreeLettersId = '\MEL'
}
DeviceUnderTest = {
  Type = '\MET600 21MID004'
  IDISDeviceType = 103
  IDISFunctionType = [EXTENSION_D, EXTENSION_L, EXTENSION_M]
  SerialNr = 12000021
  IPVersion = IPV6
  DataLinkLayer = G3
  EUI64Address = '4D454C6770B71B15'
  ConsumerInformationPush = TRUE
  SMSSupported = FALSE
  ClipCallSupported = FALSE
}
```

```
Active firmware identifier (1-0:0.2.0.255) = \2.0.02.[803F5E00].000000
Active firmware identifier 1 (1-1:0.2.0.255) =
\6.51.931.[(5.4.[(5.5.2)_(1.0.0)])_(7.14.0)].000000
Active firmware identifier 2 (1-2:0.2.0.255) = \5.0.16.0.[5.0.13.0].982249/C
```

```
*****
* Summary *
*****
```

```
PASSED                1757
FAILED                0
DISABLED              0
INAPPLICABLE         84
INCONCLUSIVE         0
FATAL                 0
TOTAL                1841
```

```
*****
Test Case 1 : Connect and release, 4 item(s)
*****
```

- (1) Connect Public
PASSED
- (2) Release Public
PASSED
- (3) Connect Management

PASSED
(4) Release Management
PASSED

Test Case 2 : Get public object-list, 1 item(s)

Public Get Current association 0-0:40.0.0.255 (@9)
(1) .object_list

PASSED

@9	0-0:40.0.0.255 15	Current association
@4	0-0:41.0.0.255 17	SAP Assignment
@42	0-0:42.0.0.255 1	COSEM logical device name
@37	0-0:43.1.0.255 1	Security - Receive frame counter - unicast key
@33	0-0:43.1.1.255 1	Security - Receive frame counter - broadcast key

Test Case 3 : Get mngmt object-list, 1 item(s)

Mngmt Get Current association 0-0:40.0.0.255 (@9)
(1) .object_list

PASSED

@75	0-0:1.0.0.255 8	Clock
@2183	0-0:2.0.0.255 27	Modem configuration
@2163	0-0:2.1.0.255 29	Auto connect
@2189	0-0:2.2.0.255 28	Auto answer
@147	0-0:10.0.1.255 9	Predefined Scripts - MDI reset / end of billing period
@141	0-0:10.0.100.255 9	Tariffication script table
@204	0-0:10.0.103.255 9	Load Mgmt script table
@	0-0:10.0.105.255 9	
@176	0-0:10.0.106.255 9	Disconnecter script table
@407	0-0:10.0.107.255 9	Predefined Scripts - Image activation
@2139	0-0:10.0.108.255 9	Push script table
@125	0-0:11.0.0.255 11	Special Days Table
@112	0-0:13.0.0.255 20	Activity Calendar
@129	0-0:14.0.1.255 6	Register activation - Energy
@135	0-0:14.0.2.255 6	Register activation - Maximum Demand
@152	0-0:15.0.0.255 22	End of billing period 1 scheduler
@170	0-0:15.0.1.255 22	Disconnect control scheduler
@401	0-0:15.0.2.255 22	Image transfer activation scheduler
@273	0-0:16.1.0.255 21	Alarm Monitor 1
@291	0-0:16.1.1.255 21	Alarm Monitor 2
@225	0-0:17.0.0.255 71	Limiter
@2001	0-0:20.0.0.255 19	IEC local port setup - IEC Optical port
@	0-0:20.0.1.255 19	
@	0-0:21.0.0.255 7	
@	0-0:21.0.1.255 7	
@	0-0:21.0.2.255 7	
@	0-0:21.0.5.255 7	

	@	0-0:21.0.9.255 7	
	@	0-0:21.0.19.255 7	
	@2012	0-0:22.0.0.255 23	IEC HDLC setup - HDLC Optical port
	@1566	0-0:24.6.0.255 74	M-Bus master port setup 1
	@2024	0-0:25.0.0.255 41	TCP-UDP setup
	@2032	0-0:25.1.0.255 42	IPv4 setup
	@2172	0-0:25.2.0.255 43	MAC address setup
	@2061	0-0:25.3.0.255 44	PPP setup
	@2177	0-0:25.4.0.255 45	GPRS modem setup
	@	0-0:25.6.0.255 47	
	@2047	0-0:25.7.0.255 48	IPv6 setup
	@2109	0-0:25.9.0.255 40	Push setup - On Connectivity
	@2199	0-0:29.0.0.255 90	G3-PLC MAC layer counters
	@2212	0-0:29.1.0.255 91	G3-PLC MAC setup
	@2237	0-0:29.2.0.255 92	G3-PLC MAC 6LoWPAN adaptation layer setup
	@9	0-0:40.0.0.255 15	Current association
	@4	0-0:41.0.0.255 17	SAP Assignment
	@42	0-0:42.0.0.255 1	COSEM logical device name
	@24	0-0:43.0.0.255 64	Security setup
	@367	0-0:43.0.1.255 64	Security setup - Consumer Information
	@37	0-0:43.1.0.255 1	Security - Receive frame counter -
unicast key	@33	0-0:43.1.1.255 1	Security - Receive frame counter -
broadcast key	@388	0-0:44.0.0.255 18	Image transfer
	@46	0-0:96.1.0.255 1	Device ID 1, manufacturing number
	@50	0-0:96.1.1.255 1	Device ID 2
	@54	0-0:96.1.2.255 1	Device ID 3
	@58	0-0:96.1.3.255 1	Device ID 4
	@62	0-0:96.1.4.255 1	Device ID 5
	@66	0-0:96.1.5.255 1	Device ID 6, IDIS certification number
	@	0-0:96.2.5.255 1	
	@	0-0:96.3.0.255 1	
	@181	0-0:96.3.10.255 70	Disconnect control
	@	0-0:96.4.0.255 1	
	@	0-0:96.5.0.255 1	
	@	0-0:96.6.3.255 3	
	@1177	0-0:96.7.9.255 1	Number of long power failures in any phase
	@1187	0-0:96.7.19.255 3	Duration of last long power failure in any
phase	@1181	0-0:96.7.20.255 3	Time threshold for long power failure
	@1173	0-0:96.7.21.255 1	Number of power failures in any phase
	@	0-0:96.9.0.255 3	
	@1142	0-0:96.10.1.255 1	Profile status - Load profile with period
1			
	@1157	0-0:96.10.2.255 1	Profile status - Load profile with period
2			
	@	0-0:96.10.3.255 1	
	@297	0-0:96.11.0.255 1	Event Object - Standard Event Log
	@312	0-0:96.11.1.255 1	Event Object - Fraud Detection Log
	@189	0-0:96.11.2.255 1	Event Object - Disconnect Control log
	@1985	0-0:96.11.3.255 1	Event Object - M-Bus Event Log
	@1336	0-0:96.11.4.255 1	Event Object - Power Quality Log
	@327	0-0:96.11.5.255 1	Event Object - Communication Log

	@	0-0:96.11.6.255 1	
	@	0-0:96.11.7.255 1	
	@	0-0:96.11.8.255 1	
	@347	0-0:96.13.0.255 1	Consumer Message Text - Consumer
Information	@343	0-0:96.13.1.255 1	Consumer Message Code - Meter Display
	@70	0-0:96.14.0.255 1	Currently active energy tariff
	@	0-0:96.15.0.255 1	
	@	0-0:96.15.1.255 1	
	@	0-0:96.15.2.255 1	
	@	0-0:96.15.3.255 1	
	@	0-0:96.15.4.255 1	
	@	0-0:96.15.5.255 1	
	@	0-0:96.15.6.255 1	
	@	0-0:96.15.7.255 1	
	@	0-0:96.15.8.255 1	
	@	0-0:96.15.9.255 1	
	@	0-0:96.15.10.255 1	
	@	0-0:96.15.30.255 1	
	@	0-0:96.50.0.255 1	
	@	0-0:96.50.8.255 1	
	@	0-0:96.50.9.255 1	
	@	0-0:96.50.27.255 1	
	@	0-0:96.50.30.255 1	
	@	0-0:96.50.33.255 1	
	@	0-0:96.50.35.255 1	
	@	0-0:96.50.44.255 1	
	@	0-0:96.245.0.255 1	
	@257	0-0:97.97.0.255 1	Error Register
	@261	0-0:97.98.0.255 1	Alarm Register 1
	@279	0-0:97.98.1.255 1	Alarm Register 2
	@265	0-0:97.98.10.255 1	Alarm Filter 1
	@283	0-0:97.98.11.255 1	Alarm Filter 2
	@269	0-0:97.98.20.255 1	Alarm Descriptor 1
	@287	0-0:97.98.21.255 1	Alarm Descriptor 2
	@158	0-0:98.1.0.255 7	Data of billing period 1
	@301	0-0:99.98.0.255 7	Standard Event Log
	@316	0-0:99.98.1.255 7	Fraud Detection Log
	@193	0-0:99.98.2.255 7	Disconnect Control Log
	@1989	0-0:99.98.3.255 7	M-Bus Event Log
	@1340	0-0:99.98.4.255 7	Power Quality Log
	@331	0-0:99.98.5.255 7	Communication Log
	@1920	0-1:10.0.106.255 9	M-Bus Disconnecter script table
	@1914	0-1:15.0.1.255 22	M-Bus Disconnect control scheduler
	@2144	0-1:15.0.4.255 22	Push action scheduler - Interval_1
	@	0-1:20.0.1.255 19	
	@376	0-1:22.0.0.255 23	IEC HDLC setup - Consumer Information
Interface	@1574	0-1:24.1.0.255 72	M-Bus client channel 1
	@1662	0-1:24.2.1.255 4	M-Bus Value channel 1, instance 1
	@1670	0-1:24.2.2.255 4	M-Bus Value channel 1, instance 2
	@1678	0-1:24.2.3.255 4	M-Bus Value channel 1, instance 3
	@1686	0-1:24.2.4.255 4	M-Bus Value channel 1, instance 4
	@1838	0-1:24.3.0.255 7	M-Bus Master Load profile for channel 1

	@1882	0-1:24.4.0.255 70	M-Bus Master Disconnect control object 1
	@1941	0-1:24.5.0.255 7	M-Bus Master Control log object 1
	@2069	0-1:25.9.0.255 40	Push setup - Interval_1
	@1790	0-1:96.1.0.255 1	M-Bus Device ID 1 channel 1
	@1806	0-1:96.1.1.255 1	M-Bus Device ID 2 channel 1
	@209	0-1:96.3.10.255 70	Load Mgmt - Relay control 1
	@1822	0-1:96.10.3.255 1	Profile status for M-Bus Master Load
profile 1			
1	@1925	0-1:96.11.4.255 1	Event Objects - M-Bus Master Control logs
	@2150	0-2:15.0.4.255 22	Push action scheduler - Interval_2
	@1596	0-2:24.1.0.255 72	M-Bus client channel 2
	@1694	0-2:24.2.1.255 4	M-Bus Value channel 2, instance 1
	@1702	0-2:24.2.2.255 4	M-Bus Value channel 2, instance 2
	@1710	0-2:24.2.3.255 4	M-Bus Value channel 2, instance 3
	@1718	0-2:24.2.4.255 4	M-Bus Value channel 2, instance 4
	@1849	0-2:24.3.0.255 7	M-Bus Master Load profile for channel 2
	@1890	0-2:24.4.0.255 70	M-Bus Master Disconnect control object 2
	@1952	0-2:24.5.0.255 7	M-Bus Master Control log object 2
	@2079	0-2:25.9.0.255 40	Push setup - Interval_2
	@1794	0-2:96.1.0.255 1	M-Bus Device ID 1 channel 2
	@1810	0-2:96.1.1.255 1	M-Bus Device ID 2 channel 2
	@217	0-2:96.3.10.255 70	Load Mgmt - Relay control 2
	@1826	0-2:96.10.3.255 1	Profile status for M-Bus Master Load
profile 2			
2	@1929	0-2:96.11.4.255 1	Event Objects - M-Bus Master Control logs
	@2156	0-3:15.0.4.255 22	Push action scheduler - Interval_3
	@1618	0-3:24.1.0.255 72	M-Bus client channel 3
	@1726	0-3:24.2.1.255 4	M-Bus Value channel 3, instance 1
	@1734	0-3:24.2.2.255 4	M-Bus Value channel 3, instance 2
	@1742	0-3:24.2.3.255 4	M-Bus Value channel 3, instance 3
	@1750	0-3:24.2.4.255 4	M-Bus Value channel 3, instance 4
	@1860	0-3:24.3.0.255 7	M-Bus Master Load profile for channel 3
	@1898	0-3:24.4.0.255 70	M-Bus Master Disconnect control object 3
	@1963	0-3:24.5.0.255 7	M-Bus Master Control log object 3
	@2089	0-3:25.9.0.255 40	Push setup - Interval_3
	@1798	0-3:96.1.0.255 1	M-Bus Device ID 1 channel 3
	@1814	0-3:96.1.1.255 1	M-Bus Device ID 2 channel 3
	@1830	0-3:96.10.3.255 1	Profile status for M-Bus Master Load
profile 3			
3	@1933	0-3:96.11.4.255 1	Event Objects - M-Bus Master Control logs
Information			
	@351	0-4:15.0.4.255 22	Push action scheduler - Consumer
	@1640	0-4:24.1.0.255 72	M-Bus client channel 4
	@1758	0-4:24.2.1.255 4	M-Bus Value channel 4, instance 1
	@1766	0-4:24.2.2.255 4	M-Bus Value channel 4, instance 2
	@1774	0-4:24.2.3.255 4	M-Bus Value channel 4, instance 3
	@1782	0-4:24.2.4.255 4	M-Bus Value channel 4, instance 4
	@1871	0-4:24.3.0.255 7	M-Bus Master Load profile for channel 4
	@1906	0-4:24.4.0.255 70	M-Bus Master Disconnect control object 4
	@1974	0-4:24.5.0.255 7	M-Bus Master Control log object 4
	@2099	0-4:25.9.0.255 40	Push setup - On Alarm

	@1802	0-4:96.1.0.255 1	M-Bus Device ID 1 channel 4
	@1818	0-4:96.1.1.255 1	M-Bus Device ID 2 channel 4
	@1834	0-4:96.10.3.255 1	Profile status for M-Bus Master Load
profile 4	@1937	0-4:96.11.4.255 1	Event Objects - M-Bus Master Control logs
4	@357	0-6:25.9.0.255 40	Push setup - Consumer Information
	@2119	0-7:25.9.0.255 40	Push setup - On Installation
	@	1-0:0.1.0.255 1	
	@	1-0:0.1.2.255 1	
	@412	1-0:0.2.0.255 1	Active firmware identifier
	@416	1-0:0.2.8.255 1	Active firmware signature
	@	1-0:0.3.0.255 3	
	@	1-0:0.3.1.255 3	
	@	1-0:0.3.3.255 3	
	@	1-0:0.3.4.255 3	
	@	1-0:0.6.0.255 3	
	@	1-0:0.6.1.255 3	
	@	1-0:0.6.2.255 3	
	@	1-0:0.6.3.255 3	
	@	1-0:0.8.0.255 3	
	@1559	1-0:0.8.2.255 3	Measurement Period 3 for Instantaneous
values	@86	1-0:0.9.1.255 1	Local Time
	@90	1-0:0.9.2.255 1	Local Date
	@94	1-0:0.9.11.255 3	Clock Time Shift Limit
	@	1-0:0.9.12.255 3	
	@	1-0:0.11.1.255 1	
	@	1-0:0.11.3.255 1	
	@	1-0:0.11.5.255 1	
	@775	1-0:1.4.0.255 5	Demand Register 1 - Active energy import
(+A)	@853	1-0:1.5.0.255 4	Last Average Demand Register 1 - Active
energy import (+A)	@901	1-0:1.6.0.255 4	Maximum Demand Register 1 - Active energy
import (+A)	@909	1-0:1.6.1.255 4	Maximum Demand Register 2 - Active energy
import (+A) - rate 1	@917	1-0:1.6.2.255 4	Maximum Demand Register 3 - Active energy
import (+A) - rate 2	@925	1-0:1.6.3.255 4	Maximum Demand Register 4 - Active energy
import (+A) - rate 3	@933	1-0:1.6.4.255 4	Maximum Demand Register 5 - Active energy
import (+A) - rate 4	@1462	1-0:1.7.0.255 3	Instantaneous active import power (+A)
	@437	1-0:1.8.0.255 3	Active energy import (+A)
	@510	1-0:1.8.1.255 3	Active energy import (+A) rate 1
	@516	1-0:1.8.2.255 3	Active energy import (+A) rate 2
	@522	1-0:1.8.3.255 3	Active energy import (+A) rate 3
	@528	1-0:1.8.4.255 3	Active energy import (+A) rate 4
	@1498	1-0:1.24.0.255 5	Average Import Power (+A)
	@788	1-0:2.4.0.255 5	Demand Register 2 - Active energy export
(-A)	@861	1-0:2.5.0.255 4	Last Average Demand Register 2 - Active

energy export (-A)		
@941	1-0:2.6.0.255 4	Maximum Demand Register 6 - Active energy
export (-A)		
@949	1-0:2.6.1.255 4	Maximum Demand Register 7 - Active energy
export (-A) - rate 1		
@957	1-0:2.6.2.255 4	Maximum Demand Register 8 - Active energy
export (-A) - rate 2		
@965	1-0:2.6.3.255 4	Maximum Demand Register 9 - Active energy
export (-A) - rate 3		
@973	1-0:2.6.4.255 4	Maximum Demand Register 10 - Active energy
export (-A) - rate 4		
@1468	1-0:2.7.0.255 3	Instantaneous active export power (-A)
@443	1-0:2.8.0.255 3	Active energy export (-A)
@534	1-0:2.8.1.255 3	Active energy export (-A) rate 1
@540	1-0:2.8.2.255 3	Active energy export (-A) rate 2
@546	1-0:2.8.3.255 3	Active energy export (-A) rate 3
@552	1-0:2.8.4.255 3	Active energy export (-A) rate 4
@801	1-0:3.4.0.255 5	Demand Register 3 - Reactive energy import
(+R)		
@869	1-0:3.5.0.255 4	Last Average Demand Register 3 - Reactive
energy import (+R)		
@981	1-0:3.6.0.255 4	Maximum Demand Register 11 - Reactive
energy import (+R)		
@989	1-0:3.6.1.255 4	Maximum Demand Register 12 - Reactive
energy import (+R) - rate 1		
@997	1-0:3.6.2.255 4	Maximum Demand Register 13 - Reactive
energy import (+R) - rate 2		
@1005	1-0:3.6.3.255 4	Maximum Demand Register 14 - Reactive
energy import (+R) - rate 3		
@1013	1-0:3.6.4.255 4	Maximum Demand Register 15 - Reactive
energy import (+R) - rate 4		
@1474	1-0:3.7.0.255 3	Instantaneous reactive import power (+R)
@485	1-0:3.8.0.255 3	Reactive energy import (+R) (QI+QII)
@558	1-0:3.8.1.255 3	Reactive energy (+R) rate 1
@564	1-0:3.8.2.255 3	Reactive energy (+R) rate 2
@570	1-0:3.8.3.255 3	Reactive energy (+R) rate 3
@576	1-0:3.8.4.255 3	Reactive energy (+R) rate 4
@814	1-0:4.4.0.255 5	Demand Register 4 - Reactive energy export
(-R)		
@877	1-0:4.5.0.255 4	Last Average Demand Register 4 - Reactive
energy export (-R)		
@1021	1-0:4.6.0.255 4	Maximum Demand Register 16 - Reactive
energy export (-R)		
@1029	1-0:4.6.1.255 4	Maximum Demand Register 17 - Reactive
energy export (-R) - rate 1		
@1037	1-0:4.6.2.255 4	Maximum Demand Register 18 - Reactive
energy export (-R) - rate 2		
@1045	1-0:4.6.3.255 4	Maximum Demand Register 19 - Reactive
energy export (-R) - rate 3		
@1053	1-0:4.6.4.255 4	Maximum Demand Register 20 - Reactive
energy export (-R) - rate 4		
@1480	1-0:4.7.0.255 3	Instantaneous reactive export power (-R)
@491	1-0:4.8.0.255 3	Reactive energy export (-R) (QIII+QIV)
@582	1-0:4.8.1.255 3	Reactive energy (-R) rate 1

@588	1-0:4.8.2.255 3	Reactive energy (-R) rate 2
@594	1-0:4.8.3.255 3	Reactive energy (-R) rate 3
@600	1-0:4.8.4.255 3	Reactive energy (-R) rate 4
@	1-0:5.4.0.255 5	
@	1-0:5.5.0.255 4	
@	1-0:5.6.0.255 4	
@	1-0:5.6.1.255 4	
@	1-0:5.6.2.255 4	
@	1-0:5.6.3.255 4	
@	1-0:5.6.4.255 4	
@	1-0:5.7.0.255 3	
@461	1-0:5.8.0.255 3	Reactive energy QI (+Ri)
@606	1-0:5.8.1.255 3	Reactive energy (QI) rate 1
@612	1-0:5.8.2.255 3	Reactive energy (QI) rate 2
@618	1-0:5.8.3.255 3	Reactive energy (QI) rate 3
@624	1-0:5.8.4.255 3	Reactive energy (QI) rate 4
@	1-0:6.4.0.255 5	
@	1-0:6.5.0.255 4	
@	1-0:6.6.0.255 4	
@	1-0:6.6.1.255 4	
@	1-0:6.6.2.255 4	
@	1-0:6.6.3.255 4	
@	1-0:6.6.4.255 4	
@	1-0:6.7.0.255 3	
@467	1-0:6.8.0.255 3	Reactive energy QII (+Rc)
@630	1-0:6.8.1.255 3	Reactive energy (QII) rate 1
@636	1-0:6.8.2.255 3	Reactive energy (QII) rate 2
@642	1-0:6.8.3.255 3	Reactive energy (QII) rate 3
@648	1-0:6.8.4.255 3	Reactive energy (QII) rate 4
@	1-0:7.4.0.255 5	
@	1-0:7.5.0.255 4	
@	1-0:7.6.0.255 4	
@	1-0:7.6.1.255 4	
@	1-0:7.6.2.255 4	
@	1-0:7.6.3.255 4	
@	1-0:7.6.4.255 4	
@	1-0:7.7.0.255 3	
@473	1-0:7.8.0.255 3	Reactive energy QIII (-Ri)
@654	1-0:7.8.1.255 3	Reactive energy (QIII) rate 1
@660	1-0:7.8.2.255 3	Reactive energy (QIII) rate 2
@666	1-0:7.8.3.255 3	Reactive energy (QIII) rate 3
@672	1-0:7.8.4.255 3	Reactive energy (QIII) rate 4
@	1-0:8.4.0.255 5	
@	1-0:8.5.0.255 4	
@	1-0:8.6.0.255 4	
@	1-0:8.6.1.255 4	
@	1-0:8.6.2.255 4	
@	1-0:8.6.3.255 4	
@	1-0:8.6.4.255 4	
@	1-0:8.7.0.255 3	
@479	1-0:8.8.0.255 3	Reactive energy QIV (-Rc)
@678	1-0:8.8.1.255 3	Reactive energy (QIV) rate 1
@684	1-0:8.8.2.255 3	Reactive energy (QIV) rate 2
@690	1-0:8.8.3.255 3	Reactive energy (QIV) rate 3

	@696	1-0:8.8.4.255 3	Reactive energy (QIV) rate 4
	@827	1-0:9.4.0.255 5	Demand Register 5 - Apparent energy import
(+VA)			
	@885	1-0:9.5.0.255 4	Last Average Demand Register 5 - Apparent
energy import (+VA)			
	@1061	1-0:9.6.0.255 4	Maximum Demand Register 21 - Apparent
energy import (+VA)			
	@1069	1-0:9.6.1.255 4	Maximum Demand Register 22 - Apparent
energy import (+VA) - rate 1			
	@1077	1-0:9.6.2.255 4	Maximum Demand Register 23 - Apparent
energy import (+VA) - rate 2			
	@1085	1-0:9.6.3.255 4	Maximum Demand Register 24 - Apparent
energy import (+VA) - rate 3			
	@1093	1-0:9.6.4.255 4	Maximum Demand Register 25 - Apparent
energy import (+VA) - rate 4			
	@1486	1-0:9.7.0.255 3	Instantaneous apparent import power (+VA)
	@497	1-0:9.8.0.255 3	Apparent energy import (+VA) (QI+QIV)
	@702	1-0:9.8.1.255 3	Apparent energy import (+VA) rate 1
	@708	1-0:9.8.2.255 3	Apparent energy import (+VA) rate 2
	@714	1-0:9.8.3.255 3	Apparent energy import (+VA) rate 3
	@720	1-0:9.8.4.255 3	Apparent energy import (+VA) rate 4
	@840	1-0:10.4.0.255 5	Demand Register 6 - Apparent energy export
(-VA)			
	@893	1-0:10.5.0.255 4	Last Average Demand Register 6 - Apparent
energy export (-VA)			
	@1101	1-0:10.6.0.255 4	Maximum Demand Register 26 - Apparent
energy export (-VA)			
	@1109	1-0:10.6.1.255 4	Maximum Demand Register 27 - Apparent
energy export (-VA) - rate 1			
	@1117	1-0:10.6.2.255 4	Maximum Demand Register 28 - Apparent
energy export (-VA) - rate 2			
	@1125	1-0:10.6.3.255 4	Maximum Demand Register 29 - Apparent
energy export (-VA) - rate 3			
	@1133	1-0:10.6.4.255 4	Maximum Demand Register 30 - Apparent
energy export (-VA) - rate 4			
	@1492	1-0:10.7.0.255 3	Instantaneous apparent export power (-VA)
	@503	1-0:10.8.0.255 3	Apparent energy export (-VA) (QII+QIII)
	@726	1-0:10.8.1.255 3	Apparent energy export (-VA) rate 1
	@732	1-0:10.8.2.255 3	Apparent energy export (-VA) rate 2
	@738	1-0:10.8.3.255 3	Apparent energy export (-VA) rate 3
	@744	1-0:10.8.4.255 3	Apparent energy export (-VA) rate 4
	@1193	1-0:12.31.0.255 3	Threshold for voltage sag
	@1253	1-0:12.35.0.255 3	Threshold for voltage swell
	@1313	1-0:12.39.0.255 3	Threshold for missing voltage (voltage
cut)			
	@1199	1-0:12.43.0.255 3	Time threshold for voltage sag
	@1259	1-0:12.44.0.255 3	Time threshold for voltage swell
	@1319	1-0:12.45.0.255 3	Time threshold for voltage cut
	@1551	1-0:13.3.0.255 4	Minimum Power factor (+A/+VA)
	@	1-0:13.4.0.255 5	
	@1543	1-0:13.5.0.255 4	Last Average Power factor (+A/+VA)
	@	1-0:13.6.0.255 4	
	@1537	1-0:13.7.0.255 3	Instantaneous Power factor (+A/+VA)
	@1450	1-0:14.7.0.255 3	Instantaneous net frequency; any phase

	@1456	1-0:15.7.0.255 3	Instantaneous active power (+A + -A)
	@449	1-0:15.8.0.255 3	Active energy (+A + -A) Combined total
	@750	1-0:15.8.1.255 3	Active energy Combined total (+A + -A)
rate 1			
	@756	1-0:15.8.2.255 3	Active energy Combined total (+A + -A)
rate 2			
	@762	1-0:15.8.3.255 3	Active energy Combined total (+A + -A)
rate 3			
	@768	1-0:15.8.4.255 3	Active energy Combined total (+A + -A)
rate 4			
	@1524	1-0:15.24.0.255 5	Average Total Power (+A + -A)
	@	1-0:16.7.0.255 3	
	@455	1-0:16.8.0.255 3	Active energy (+A - -A) Combined total
	@1511	1-0:16.24.0.255 5	Average Net Power (+A - -A)
	@	1-0:31.3.0.255 4	
	@1369	1-0:31.4.0.255 5	Sliding Average current L1 (for fuse
supervision)			
	@238	1-0:31.4.0.255 21	Supervision monitor 1 - Fuse supervision
L1			
	@	1-0:31.6.0.255 4	
	@1363	1-0:31.7.0.255 3	Instantaneous current L1
	@	1-0:31.7.124.255 3	
	@	1-0:31.24.0.255 3	
	@	1-0:32.3.0.255 4	
	@	1-0:32.6.0.255 4	
	@1351	1-0:32.7.0.255 3	Instantaneous voltage L1
	@	1-0:32.7.124.255 3	
	@1357	1-0:32.24.0.255 3	Average voltage L1
	@1205	1-0:32.32.0.255 1	Number of voltage sags in phase L1
	@1217	1-0:32.33.0.255 3	Duration of last voltage sag in phase L1
	@1235	1-0:32.34.0.255 3	Magnitude of last voltage sag in phase L1
	@1265	1-0:32.36.0.255 1	Number of voltage swells in phase L1
	@1277	1-0:32.37.0.255 3	Duration of last voltage swell in phase L1
	@1295	1-0:32.38.0.255 3	Magnitude of last voltage swell in phase
L1			
	@	1-0:33.7.0.255 3	
	@	1-0:51.3.0.255 4	
	@1400	1-0:51.4.0.255 5	Sliding Average current L2 (for fuse
supervision)			
	@244	1-0:51.4.0.255 21	Supervision monitor 2 - Fuse supervision
L2			
	@	1-0:51.6.0.255 4	
	@1394	1-0:51.7.0.255 3	Instantaneous current L2
	@	1-0:51.7.124.255 3	
	@	1-0:51.24.0.255 3	
	@	1-0:52.3.0.255 4	
	@	1-0:52.6.0.255 4	
	@1382	1-0:52.7.0.255 3	Instantaneous voltage L2
	@	1-0:52.7.124.255 3	
	@1388	1-0:52.24.0.255 3	Average voltage L2
	@1209	1-0:52.32.0.255 1	Number of voltage sags in phase L2
	@1223	1-0:52.33.0.255 3	Duration of last voltage sag in phase L2
	@1241	1-0:52.34.0.255 3	Magnitude of last voltage sag in phase L2
	@1269	1-0:52.36.0.255 1	Number of voltage swells in phase L2

	@1283	1-0:52.37.0.255 3	Duration of last voltage swell in phase L2
	@1301	1-0:52.38.0.255 3	Magnitude of last voltage swell in phase
L2	@	1-0:53.7.0.255 3	
	@	1-0:71.3.0.255 4	
	@1431	1-0:71.4.0.255 5	Sliding Average current L3 (for fuse
supervision)	@250	1-0:71.4.0.255 21	Supervision monitor 3 - Fuse supervision
L3	@	1-0:71.6.0.255 4	
	@1425	1-0:71.7.0.255 3	Instantaneous current L3
	@	1-0:71.7.124.255 3	
	@	1-0:71.24.0.255 3	
	@	1-0:72.3.0.255 4	
	@	1-0:72.6.0.255 4	
	@1413	1-0:72.7.0.255 3	Instantaneous voltage L3
	@	1-0:72.7.124.255 3	
	@1419	1-0:72.24.0.255 3	Average voltage L3
	@1213	1-0:72.32.0.255 1	Number of voltage sags in phase L3
	@1229	1-0:72.33.0.255 3	Duration of last voltage sag in phase L3
	@1247	1-0:72.34.0.255 3	Magnitude of last voltage sag in phase L3
	@1273	1-0:72.36.0.255 1	Number of voltage swells in phase L3
	@1289	1-0:72.37.0.255 3	Duration of last voltage swell in phase L3
	@1307	1-0:72.38.0.255 3	Magnitude of last voltage swell in phase
L3	@	1-0:73.7.0.255 3	
	@	1-0:81.7.2.255 3	
	@	1-0:81.7.4.255 3	
	@	1-0:81.7.10.255 3	
	@	1-0:81.7.15.255 3	
	@	1-0:81.7.21.255 3	
	@	1-0:81.7.26.255 3	
	@	1-0:84.3.0.255 4	
	@	1-0:84.4.0.255 5	
	@	1-0:84.5.0.255 4	
	@	1-0:84.6.0.255 4	
	@	1-0:84.7.0.255 3	
	@1444	1-0:90.7.0.255 3	Instantaneous current (sum over all
phases)	@	1-0:96.5.0.255 1	
	@	1-0:96.10.1.255 1	
	@1146	1-0:99.1.0.255 7	Load profile with period 1 i.e. General
Load Profile	@1161	1-0:99.2.0.255 7	Load profile with period 2 i.e. Daily
Values Profile	@	1-0:99.3.0.255 7	
	@	1-0:99.14.0.255 7	
	@1325	1-0:99.97.0.255 7	Power Failure Event Log
	@420	1-1:0.2.0.255 1	Active firmware identifier 1
	@424	1-1:0.2.8.255 1	Active firmware signature 1
	@428	1-2:0.2.0.255 1	Active firmware identifier 2
	@432	1-2:0.2.8.255 1	Active firmware signature 2

Test Case 4 : Get public attributes, 15 item(s)

Public Get SAP Assignment 0-0:41.0.0.255 (@4)
(1) .logical_name
PASSED

```
<Data>  
  <OctetString Value="0000290000FF" />  
</Data>
```

(2) .SAP_assignment_list
PASSED

```
<Data>  
  <Array Qty="0001" >  
    <Structure Qty="0002" >  
      <LongUnsigned Value="0001" />  
      <OctetString Value="\MEL1030712000021" />  
    </Structure>  
  </Array>  
</Data>
```

Public Get Current association 0-0:40.0.0.255 (@9)
(3) .logical_name
PASSED

```
<Data>  
  <OctetString Value="0000280000FF" />  
</Data>
```

(4) .associated_partners_id
PASSED

```
<Data>  
  <Structure Qty="0002" >  
    <Integer Value="10" />  
    <LongUnsigned Value="0001" />  
  </Structure>  
</Data>
```

(5) .application_context_name
PASSED

```
<Data>  
  <Structure Qty="0007" >  
    <Unsigned Value="02" />  
    <Unsigned Value="10" />  
    <LongUnsigned Value="02F4" />  
    <Unsigned Value="05" />  
    <Unsigned Value="08" />  
    <Unsigned Value="01" />  
    <Unsigned Value="01" />  
  </Structure>  
</Data>
```

(6) .xDLMS_context_info
PASSED

```
<Data>  
  <Structure Qty="0006" >  
    <BitString Value="000000000111001000010100" />  
    <LongUnsigned Value="04C8" />  
    <LongUnsigned Value="04C8" />  
  </Structure>  
</Data>
```

```
    <Unsigned Value="06" />
    <Integer Value="00" />
    <OctetString Value="00000000000000000000000000000000" />
  </Structure>
</Data>
```

(7) .authentication_mechanism_name
PASSED

```
<Data>
  <Structure Qty="0007" >
    <Unsigned Value="02" />
    <Unsigned Value="10" />
    <LongUnsigned Value="02F4" />
    <Unsigned Value="05" />
    <Unsigned Value="08" />
    <Unsigned Value="02" />
    <Unsigned Value="00" />
  </Structure>
</Data>
```

(8) .association_status
PASSED

```
<Data>
  <Enum Value="02" />
</Data>
```

(9) .security_setup_reference
PASSED

```
<Data>
  <OctetString Value="00002B0000FF" />
</Data>
```

Public Get Security - Receive frame counter - broadcast key 0-0:43.1.1.255

(@33)

(10) .logical_name
PASSED

```
<Data>
  <OctetString Value="00002B0101FF" />
</Data>
```

(11) .value
PASSED

```
<Data>
  <DoubleLongUnsigned Value="6E17B1FA" />
</Data>
```

Public Get Security - Receive frame counter - unicast key 0-0:43.1.0.255

(@37)

(12) .logical_name
PASSED

```
<Data>
  <OctetString Value="00002B0100FF" />
</Data>
```

(13) .value
PASSED

```
<Data>
  <DoubleLongUnsigned Value="6E1E8B1A" />
</Data>
```

Public Get COSEM logical device name 0-0:42.0.0.255 (@42)
(14) .logical_name
PASSED

```
<Data>  
  <OctetString Value="00002A0000FF" />  
</Data>
```

(15) .value
PASSED

```
<Data>  
  <OctetString Value="\MEL1030712000021" />  
</Data>
```

Test Case 5 : Get mngmt attributes, 1314 item(s)

Mngmt Get SAP Assignment 0-0:41.0.0.255 (@4)
(1) .logical_name
PASSED

```
<Data>  
  <OctetString Value="0000290000FF" />  
</Data>
```

(2) .SAP_assignment_list
PASSED

```
<Data>  
  <Array Qty="0001" >  
    <Structure Qty="0002" >  
      <LongUnsigned Value="0001" />  
      <OctetString Value="\MEL1030712000021" />  
    </Structure>  
  </Array>  
</Data>
```

Mngmt Get Current association 0-0:40.0.0.255 (@9)
(3) .logical_name
PASSED

```
<Data>  
  <OctetString Value="0000280000FF" />  
</Data>
```

(4) .associated_partners_id
PASSED

```
<Data>  
  <Structure Qty="0002" >  
    <Integer Value="01" />  
    <LongUnsigned Value="0001" />  
  </Structure>  
</Data>
```

(5) .application_context_name
PASSED

```
<Data>  
  <Structure Qty="0007" >  
    <Unsigned Value="02" />  
    <Unsigned Value="10" />
```

```

        <LongUnsigned Value="02F4" />
        <Unsigned Value="05" />
        <Unsigned Value="08" />
        <Unsigned Value="01" />
        <Unsigned Value="03" />
    </Structure>
</Data>
(6) .xDLMS_context_info
PASSED
    <Data>
        <Structure Qty="0006" >
            <BitString Value="000000001111101000011101" />
            <LongUnsigned Value="04C8" />
            <LongUnsigned Value="04C8" />
            <Unsigned Value="06" />
            <Integer Value="00" />
            <OctetString Value="000000000000000000000000000000" />
        </Structure>
    </Data>
(7) .authentication_mechanism_name
PASSED
    <Data>
        <Structure Qty="0007" >
            <Unsigned Value="02" />
            <Unsigned Value="10" />
            <LongUnsigned Value="02F4" />
            <Unsigned Value="05" />
            <Unsigned Value="08" />
            <Unsigned Value="02" />
            <Unsigned Value="05" />
        </Structure>
    </Data>
(8) .association_status
PASSED
    <Data>
        <Enum Value="02" />
    </Data>
(9) .security_setup_reference
PASSED
    <Data>
        <OctetString Value="00002B0000FF" />
    </Data>

Mngmt Get Security setup 0-0:43.0.0.255 (@24)
(10) .logical_name
PASSED
    <Data>
        <OctetString Value="00002B0000FF" />
    </Data>
(11) .security_policy
PASSED
    <Data>
        <Enum Value="00" />
    </Data>

```

(12) .security_suite

PASSED

```
<Data>
  <Enum Value="00" />
</Data>
```

(13) .client_system_title

PASSED

```
<Data>
  <OctetString Value="58585A0102030405" />
</Data>
```

(14) .server_system_title

PASSED

```
<Data>
  <OctetString Value="4D454C6770B71B15" />
</Data>
```

Mngmt Get Security - Receive frame counter - broadcast key 0-0:43.1.1.255

(@33)

(15) .logical_name

PASSED

```
<Data>
  <OctetString Value="00002B0101FF" />
</Data>
```

(16) .value

PASSED

```
<Data>
  <DoubleLongUnsigned Value="6E17B1FA" />
</Data>
```

Mngmt Get Security - Receive frame counter - unicast key 0-0:43.1.0.255

(@37)

(17) .logical_name

PASSED

```
<Data>
  <OctetString Value="00002B0100FF" />
</Data>
```

(18) .value

PASSED

```
<Data>
  <DoubleLongUnsigned Value="6E1E8BF1" />
</Data>
```

Mngmt Get COSEM logical device name 0-0:42.0.0.255 (@42)

(19) .logical_name

PASSED

```
<Data>
  <OctetString Value="00002A0000FF" />
</Data>
```

(20) .value

PASSED

```
<Data>
  <OctetString Value="\MEL1030712000021" />
</Data>
```


Mngmt Get Device ID 1, manufacturing number 0-0:96.1.0.255 (@46)

(21) .logical_name

PASSED

```
<Data>
  <OctetString Value="0000600100FF" />
</Data>
```

(22) .value

PASSED

```
<Data>
  <OctetString Value="\12000021" />
</Data>
```

Mngmt Get Device ID 2 0-0:96.1.1.255 (@50)

(23) .logical_name

PASSED

```
<Data>
  <OctetString Value="0000600101FF" />
</Data>
```

(24) .value

PASSED

```
<Data>
  <OctetString
Value="4D45543630302D4F4671517A6937372D303030303030000000000000000000" />
</Data>
```

Mngmt Get Device ID 3 0-0:96.1.2.255 (@54)

(25) .logical_name

PASSED

```
<Data>
  <OctetString Value="0000600102FF" />
</Data>
```

(26) .value

PASSED

```
<Data>
  <OctetString Value="\          " />
</Data>
```

Mngmt Get Device ID 4 0-0:96.1.3.255 (@58)

(27) .logical_name

PASSED

```
<Data>
  <OctetString Value="0000600103FF" />
</Data>
```

(28) .value

PASSED

```
<Data>
  <OctetString Value="\          " />
</Data>
```

Mngmt Get Device ID 5 0-0:96.1.4.255 (@62)

(29) .logical_name

PASSED

```
<Data>
  <OctetString Value="0000600104FF" />
```

</Data>
(30) .value
PASSED

<Data>
<OctetString Value="\ " />
</Data>

Mngmt Get Device ID 6, IDIS certification number 0-0:96.1.5.255 (@66)
(31) .logical_name
PASSED

<Data>
<OctetString Value="0000600105FF" />
</Data>

(32) .value
PASSED

<Data>
<OctetString Value="\IDIS2DLM00000000" />
</Data>

Mngmt Get Currently active energy tariff 0-0:96.14.0.255 (@70)
(33) .logical_name
PASSED

<Data>
<OctetString Value="0000600E00FF" />
</Data>

(34) .value
PASSED

<Data>
<OctetString Value="04" />
</Data>

Mngmt Get Clock 0-0:1.0.0.255 (@75)
(35) .logical_name
PASSED

<Data>
<OctetString Value="0000010000FF" />
</Data>

(36) .time
PASSED

<Data>
<OctetString Value="07E60C15030E270D00FFC400" />
</Data>

(37) .time_zone
PASSED

<Data>
<Long Value="FFC4" />
</Data>

(38) .status
PASSED

<Data>
<Unsigned Value="00" />
</Data>

(39) .daylights_savings_begin
PASSED

```
    <Data>
      <OctetString Value="FFFF03FE07020000008000FF" />
    </Data>
(40) .daylights_savings_end
PASSED
    <Data>
      <OctetString Value="FFFF0AFE07030000008000FF" />
    </Data>
(41) .daylights_savings_deviation
PASSED
    <Data>
      <Integer Value="3C" />
    </Data>
(42) .daylights_savings_enabled
PASSED
    <Data>
      <Boolean Value="01" />
    </Data>
(43) .clock_base
PASSED
    <Data>
      <Enum Value="01" />
    </Data>

Mngmt Get Local Time 1-0:0.9.1.255 (@86)
(44) .logical_name
PASSED
    <Data>
      <OctetString Value="0100000901FF" />
    </Data>
(45) .value
PASSED
    <Data>
      <OctetString Value="0E271700" />
    </Data>

Mngmt Get Local Date 1-0:0.9.2.255 (@90)
(46) .logical_name
PASSED
    <Data>
      <OctetString Value="0100000902FF" />
    </Data>
(47) .value
PASSED
    <Data>
      <OctetString Value="07E60C1503" />
    </Data>

Mngmt Get Clock Time Shift Limit 1-0:0.9.11.255 (@94)
(48) .logical_name
PASSED
    <Data>
      <OctetString Value="010000090BFF" />
    </Data>
```

(49) .value
PASSED

```
<Data>  
  <Unsigned Value="3C" />  
</Data>
```

(50) .scaler_unit
PASSED

```
<Data>  
  <Structure Qty="0002" >  
    <Integer Value="00" />  
    <Enum Value="07" />  
  </Structure>  
</Data>
```

Mngmt Get NTP setup 0-0:25.10.0.255 (@100)

(51) .logical_name
INAPPLICABLE

Optional object is not implemented

(52) .activated
INAPPLICABLE

Optional object is not implemented

(53) .server_address
INAPPLICABLE

Optional object is not implemented

(54) .server_port
INAPPLICABLE

Optional object is not implemented

(55) .authentication_method
INAPPLICABLE

Optional object is not implemented

Mngmt Get Activity Calendar 0-0:13.0.0.255 (@112)

(56) .logical_name
PASSED

```
<Data>  
  <OctetString Value="00000D0000FF" />  
</Data>
```

(57) .calendar_name_active
PASSED

```
<Data>  
  <OctetString Value="\TOU_3B29" />  
</Data>
```

(58) .season_profile_active
PASSED

```
<Data>  
  <Array Qty="0004" >  
    <Structure Qty="0003" >  
      <OctetString Value="01" />  
      <OctetString Value="FFFF0101FF000000008000FF" />  
      <OctetString Value="01" />  
    </Structure>  
    <Structure Qty="0003" >  
      <OctetString Value="02" />  
      <OctetString Value="FFFF0102FF000000008000FF" />  
    </Structure>  
  </Array>  
</Data>
```

```
        <OctetString Value="02" />
    </Structure>
    <Structure Qty="0003" >
        <OctetString Value="03" />
        <OctetString Value="FFFF0103FF000000008000FF" />
        <OctetString Value="03" />
    </Structure>
    <Structure Qty="0003" >
        <OctetString Value="04" />
        <OctetString Value="FFFF0104FF000000008000FF" />
        <OctetString Value="04" />
    </Structure>
</Array>
</Data>
(59) .week_profile_table_active
PASSED
```

```
<Data>
  <Array Qty="0004" >
    <Structure Qty="0008" >
      <OctetString Value="01" />
      <Unsigned Value="01" />
      <Unsigned Value="01" />
      <Unsigned Value="01" />
      <Unsigned Value="01" />
      <Unsigned Value="01" />
      <Unsigned Value="01" />
      <Unsigned Value="01" />
    </Structure>
    <Structure Qty="0008" >
      <OctetString Value="02" />
      <Unsigned Value="02" />
      <Unsigned Value="02" />
      <Unsigned Value="02" />
      <Unsigned Value="02" />
      <Unsigned Value="02" />
      <Unsigned Value="02" />
      <Unsigned Value="02" />
    </Structure>
    <Structure Qty="0008" >
      <OctetString Value="03" />
      <Unsigned Value="03" />
      <Unsigned Value="03" />
      <Unsigned Value="03" />
      <Unsigned Value="03" />
      <Unsigned Value="03" />
      <Unsigned Value="03" />
      <Unsigned Value="03" />
    </Structure>
    <Structure Qty="0008" >
      <OctetString Value="04" />
      <Unsigned Value="04" />
      <Unsigned Value="04" />
      <Unsigned Value="04" />
      <Unsigned Value="04" />
    </Structure>
  </Array>
</Data>
```

```

        <Unsigned Value="04" />
        <Unsigned Value="04" />
        <Unsigned Value="04" />
    </Structure>
</Array>
</Data>
(60) .day_profile_table_active
PASSED
<_Data>
  <Array Qty="0004" >
    <Structure Qty="0002" >
      <Unsigned Value="01" />
      <Array Qty="0005" >
        <Structure Qty="0003" >
          <OctetString Value="00000000" />
          <OctetString Value="00000A0064FF" />
          <LongUnsigned Value="0001" />
        </Structure>
        <Structure Qty="0003" >
          <OctetString Value="04000000" />
          <OctetString Value="00000A0064FF" />
          <LongUnsigned Value="0002" />
        </Structure>
        <Structure Qty="0003" >
          <OctetString Value="08000000" />
          <OctetString Value="00000A0064FF" />
          <LongUnsigned Value="0003" />
        </Structure>
        <Structure Qty="0003" >
          <OctetString Value="0C000000" />
          <OctetString Value="00000A0064FF" />
          <LongUnsigned Value="0004" />
        </Structure>
        <Structure Qty="0003" >
          <OctetString Value="10000000" />
          <OctetString Value="00000A0064FF" />
          <LongUnsigned Value="0001" />
        </Structure>
      </Array>
    </Structure>
    <Structure Qty="0002" >
      <Unsigned Value="02" />
      <Array Qty="0005" >
        <Structure Qty="0003" >
          <OctetString Value="00000000" />
          <OctetString Value="00000A0064FF" />
          <LongUnsigned Value="0003" />
        </Structure>
        <Structure Qty="0003" >
          <OctetString Value="04000000" />
          <OctetString Value="00000A0064FF" />
          <LongUnsigned Value="0003" />
        </Structure>
        <Structure Qty="0003" >

```

```
    <OctetString Value="08000000" />
    <OctetString Value="00000A0064FF" />
    <LongUnsigned Value="0003" />
  </Structure>
  <Structure Qty="0003" >
    <OctetString Value="0C000000" />
    <OctetString Value="00000A0064FF" />
    <LongUnsigned Value="0003" />
  </Structure>
  <Structure Qty="0003" >
    <OctetString Value="10000000" />
    <OctetString Value="00000A0064FF" />
    <LongUnsigned Value="0003" />
  </Structure>
</Array>
</Structure>
<Structure Qty="0002" >
  <Unsigned Value="03" />
  <Array Qty="0005" >
    <Structure Qty="0003" >
      <OctetString Value="00000000" />
      <OctetString Value="00000A0064FF" />
      <LongUnsigned Value="0001" />
    </Structure>
    <Structure Qty="0003" >
      <OctetString Value="04000000" />
      <OctetString Value="00000A0064FF" />
      <LongUnsigned Value="0002" />
    </Structure>
    <Structure Qty="0003" >
      <OctetString Value="08000000" />
      <OctetString Value="00000A0064FF" />
      <LongUnsigned Value="0003" />
    </Structure>
    <Structure Qty="0003" >
      <OctetString Value="0C000000" />
      <OctetString Value="00000A0064FF" />
      <LongUnsigned Value="0004" />
    </Structure>
    <Structure Qty="0003" >
      <OctetString Value="10000000" />
      <OctetString Value="00000A0064FF" />
      <LongUnsigned Value="0001" />
    </Structure>
  </Array>
</Structure>
<Structure Qty="0002" >
  <Unsigned Value="04" />
  <Array Qty="0005" >
    <Structure Qty="0003" >
      <OctetString Value="00000000" />
      <OctetString Value="00000A0064FF" />
      <LongUnsigned Value="0001" />
    </Structure>
```

```

    <Structure Qty="0003" >
      <OctetString Value="04000000" />
      <OctetString Value="00000A0064FF" />
      <LongUnsigned Value="0002" />
    </Structure>
    <Structure Qty="0003" >
      <OctetString Value="08000000" />
      <OctetString Value="00000A0064FF" />
      <LongUnsigned Value="0003" />
    </Structure>
    <Structure Qty="0003" >
      <OctetString Value="0C000000" />
      <OctetString Value="00000A0064FF" />
      <LongUnsigned Value="0004" />
    </Structure>
    <Structure Qty="0003" >
      <OctetString Value="10000000" />
      <OctetString Value="00000A0064FF" />
      <LongUnsigned Value="0001" />
    </Structure>
  </Array>
</Structure>
</Array>
</_Data>
(61) .calendar_name_passive
PASSED
  <Data>
    <OctetString Value="\CNP_674F" />
  </Data>
(62) .season_profile_passive
PASSED
  <Data>
    <Array Qty="0004" >
      <Structure Qty="0003" >
        <OctetString Value="01" />
        <OctetString Value="FFFF0101FF000000008000FF" />
        <OctetString Value="01" />
      </Structure>
      <Structure Qty="0003" >
        <OctetString Value="02" />
        <OctetString Value="FFFF0102FF000000008000FF" />
        <OctetString Value="02" />
      </Structure>
      <Structure Qty="0003" >
        <OctetString Value="03" />
        <OctetString Value="FFFF0103FF000000008000FF" />
        <OctetString Value="03" />
      </Structure>
      <Structure Qty="0003" >
        <OctetString Value="04" />
        <OctetString Value="FFFF0104FF000000008000FF" />
        <OctetString Value="04" />
      </Structure>
    </Array>

```



```
</Data>
(63) .week_profile_table_passive
PASSED
<Data>
  <Array Qty="0004" >
    <Structure Qty="0008" >
      <OctetString Value="01" />
      <Unsigned Value="01" />
      <Unsigned Value="01" />
      <Unsigned Value="01" />
      <Unsigned Value="01" />
      <Unsigned Value="01" />
      <Unsigned Value="01" />
      <Unsigned Value="01" />
    </Structure>
    <Structure Qty="0008" >
      <OctetString Value="02" />
      <Unsigned Value="02" />
      <Unsigned Value="02" />
      <Unsigned Value="02" />
      <Unsigned Value="02" />
      <Unsigned Value="02" />
      <Unsigned Value="02" />
      <Unsigned Value="02" />
    </Structure>
    <Structure Qty="0008" >
      <OctetString Value="03" />
      <Unsigned Value="03" />
      <Unsigned Value="03" />
      <Unsigned Value="03" />
      <Unsigned Value="03" />
      <Unsigned Value="03" />
      <Unsigned Value="03" />
      <Unsigned Value="03" />
    </Structure>
    <Structure Qty="0008" >
      <OctetString Value="04" />
      <Unsigned Value="04" />
      <Unsigned Value="04" />
      <Unsigned Value="04" />
      <Unsigned Value="04" />
      <Unsigned Value="04" />
      <Unsigned Value="04" />
      <Unsigned Value="04" />
    </Structure>
  </Array>
</Data>
```

```
(64) .day_profile_table_passive
PASSED
<_Data>
  <Array Qty="0004" >
    <Structure Qty="0002" >
      <Unsigned Value="01" />
    <Array Qty="0005" >
```

```
<Structure Qty="0003" >
  <OctetString Value="00000000" />
  <OctetString Value="00000A0064FF" />
  <LongUnsigned Value="0001" />
</Structure>
<Structure Qty="0003" >
  <OctetString Value="04000000" />
  <OctetString Value="00000A0064FF" />
  <LongUnsigned Value="0002" />
</Structure>
<Structure Qty="0003" >
  <OctetString Value="08000000" />
  <OctetString Value="00000A0064FF" />
  <LongUnsigned Value="0003" />
</Structure>
<Structure Qty="0003" >
  <OctetString Value="0C000000" />
  <OctetString Value="00000A0064FF" />
  <LongUnsigned Value="0004" />
</Structure>
<Structure Qty="0003" >
  <OctetString Value="10000000" />
  <OctetString Value="00000A0064FF" />
  <LongUnsigned Value="0001" />
</Structure>
</Array>
</Structure>
<Structure Qty="0002" >
  <Unsigned Value="02" />
  <Array Qty="0005" >
    <Structure Qty="0003" >
      <OctetString Value="00000000" />
      <OctetString Value="00000A0064FF" />
      <LongUnsigned Value="0003" />
    </Structure>
    <Structure Qty="0003" >
      <OctetString Value="04000000" />
      <OctetString Value="00000A0064FF" />
      <LongUnsigned Value="0003" />
    </Structure>
    <Structure Qty="0003" >
      <OctetString Value="08000000" />
      <OctetString Value="00000A0064FF" />
      <LongUnsigned Value="0003" />
    </Structure>
    <Structure Qty="0003" >
      <OctetString Value="0C000000" />
      <OctetString Value="00000A0064FF" />
      <LongUnsigned Value="0003" />
    </Structure>
    <Structure Qty="0003" >
      <OctetString Value="10000000" />
      <OctetString Value="00000A0064FF" />
      <LongUnsigned Value="0003" />
    </Structure>
  </Array>
</Structure>
```

```
    </Structure>
  </Array>
</Structure>
<Structure Qty="0002" >
  <Unsigned Value="03" />
  <Array Qty="0005" >
    <Structure Qty="0003" >
      <OctetString Value="00000000" />
      <OctetString Value="00000A0064FF" />
      <LongUnsigned Value="0001" />
    </Structure>
    <Structure Qty="0003" >
      <OctetString Value="04000000" />
      <OctetString Value="00000A0064FF" />
      <LongUnsigned Value="0002" />
    </Structure>
    <Structure Qty="0003" >
      <OctetString Value="08000000" />
      <OctetString Value="00000A0064FF" />
      <LongUnsigned Value="0003" />
    </Structure>
    <Structure Qty="0003" >
      <OctetString Value="0C000000" />
      <OctetString Value="00000A0064FF" />
      <LongUnsigned Value="0004" />
    </Structure>
    <Structure Qty="0003" >
      <OctetString Value="10000000" />
      <OctetString Value="00000A0064FF" />
      <LongUnsigned Value="0001" />
    </Structure>
  </Array>
</Structure>
<Structure Qty="0002" >
  <Unsigned Value="04" />
  <Array Qty="0005" >
    <Structure Qty="0003" >
      <OctetString Value="00000000" />
      <OctetString Value="00000A0064FF" />
      <LongUnsigned Value="0001" />
    </Structure>
    <Structure Qty="0003" >
      <OctetString Value="04000000" />
      <OctetString Value="00000A0064FF" />
      <LongUnsigned Value="0002" />
    </Structure>
    <Structure Qty="0003" >
      <OctetString Value="08000000" />
      <OctetString Value="00000A0064FF" />
      <LongUnsigned Value="0003" />
    </Structure>
    <Structure Qty="0003" >
      <OctetString Value="0C000000" />
      <OctetString Value="00000A0064FF" />
    </Structure>
```

```

        <LongUnsigned Value="0004" />
    </Structure>
    <Structure Qty="0003" >
        <OctetString Value="10000000" />
        <OctetString Value="00000A0064FF" />
        <LongUnsigned Value="0001" />
    </Structure>
</Array>
</Structure>
</Array>
</_Data>
(65) .activate_passive_calendar_time
PASSED
    <Data>
        <OctetString Value="FFFFFFFFFFFFFFFF008000FF" />
    </Data>

Mngmt Get Special Days Table 0-0:11.0.0.255 (@125)
(66) .logical_name
PASSED
    <Data>
        <OctetString Value="00000B0000FF" />
    </Data>
(67) .entries
PASSED
    <_Data>
        <Array Qty="001E" >
            <Structure Qty="0003" >
                <LongUnsigned Value="0001" />
                <OctetString Value="FFFF0101FF" />
                <Unsigned Value="02" />
            </Structure>
            <Structure Qty="0003" >
                <LongUnsigned Value="0002" />
                <OctetString Value="FFFF0102FF" />
                <Unsigned Value="02" />
            </Structure>
            <Structure Qty="0003" >
                <LongUnsigned Value="0003" />
                <OctetString Value="FFFF0103FF" />
                <Unsigned Value="02" />
            </Structure>
            <Structure Qty="0003" >
                <LongUnsigned Value="0004" />
                <OctetString Value="FFFF0104FF" />
                <Unsigned Value="02" />
            </Structure>
            <Structure Qty="0003" >
                <LongUnsigned Value="0005" />
                <OctetString Value="FFFF0105FF" />
                <Unsigned Value="02" />
            </Structure>
            <Structure Qty="0003" >
                <LongUnsigned Value="0006" />

```

```
<OctetString Value="FFFF0106FF" />
<Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0007" />
  <OctetString Value="FFFF0107FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0008" />
  <OctetString Value="FFFF0108FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0009" />
  <OctetString Value="FFFF0109FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="000A" />
  <OctetString Value="FFFF010AFF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="000B" />
  <OctetString Value="FFFF0201FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="000C" />
  <OctetString Value="FFFF0202FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="000D" />
  <OctetString Value="FFFF0203FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="000E" />
  <OctetString Value="FFFF0204FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="000F" />
  <OctetString Value="FFFF0205FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0010" />
  <OctetString Value="FFFF0206FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
```

```
<LongUnsigned Value="0011" />
<OctetString Value="FFFF0207FF" />
<Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0012" />
  <OctetString Value="FFFF0208FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0013" />
  <OctetString Value="FFFF0209FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0014" />
  <OctetString Value="FFFF020AFF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0015" />
  <OctetString Value="FFFF0301FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0016" />
  <OctetString Value="FFFF0302FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0017" />
  <OctetString Value="FFFF0303FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0018" />
  <OctetString Value="FFFF0304FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0019" />
  <OctetString Value="FFFF0305FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="001A" />
  <OctetString Value="FFFF0306FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="001B" />
  <OctetString Value="FFFF0307FF" />
  <Unsigned Value="02" />
</Structure>
```

```

    <Structure Qty="0003" >
      <LongUnsigned Value="001C" />
      <OctetString Value="FFFF0308FF" />
      <Unsigned Value="02" />
    </Structure>
    <Structure Qty="0003" >
      <LongUnsigned Value="001D" />
      <OctetString Value="FFFF0309FF" />
      <Unsigned Value="02" />
    </Structure>
    <Structure Qty="0003" >
      <LongUnsigned Value="001E" />
      <OctetString Value="FFFF030AFF" />
      <Unsigned Value="02" />
    </Structure>
  </Array>
</_Data>

```

Mngmt Get Register activation - Energy 0-0:14.0.1.255 (@129)

(68) .logical_name

PASSED

```

  <Data>
    <OctetString Value="00000E0001FF" />
  </Data>

```

(69) .register_assignment

PASSED

```

  <_Data>
    <Array Qty="0038" >
      <Structure Qty="0002" >
        <LongUnsigned Value="0003" />
        <OctetString Value="0100010800FF" />
      </Structure>
      <Structure Qty="0002" >
        <LongUnsigned Value="0003" />
        <OctetString Value="0100010801FF" />
      </Structure>
      <Structure Qty="0002" >
        <LongUnsigned Value="0003" />
        <OctetString Value="0100010802FF" />
      </Structure>
      <Structure Qty="0002" >
        <LongUnsigned Value="0003" />
        <OctetString Value="0100010803FF" />
      </Structure>
      <Structure Qty="0002" >
        <LongUnsigned Value="0003" />
        <OctetString Value="0100010804FF" />
      </Structure>
      <Structure Qty="0002" >
        <LongUnsigned Value="0003" />
        <OctetString Value="0100020800FF" />
      </Structure>
      <Structure Qty="0002" >
        <LongUnsigned Value="0003" />
      </Structure>
    </Array>
  </_Data>

```

```
<OctetString Value="0100020801FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100020802FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100020803FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100020804FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100030800FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100030801FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100030802FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100030803FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100030804FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100040800FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100040801FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100040802FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100040803FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100040804FF" />
</Structure>
```



```
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100050800FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100050801FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100050802FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100050803FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100050804FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100060800FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100060801FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100060802FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100060803FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100060804FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100070800FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100070801FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100070802FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
```

```
<OctetString Value="0100070803FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100070804FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100080800FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100080801FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100080802FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100080803FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100080804FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100090800FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100090801FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100090802FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100090803FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100090804FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="01000A0800FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="01000A0801FF" />
</Structure>
```

```
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="01000A0802FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="01000A0803FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="01000A0804FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="01000F0800FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="01000F0801FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="01000F0802FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="01000F0803FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="01000F0804FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100100800FF" />
</Structure>
</Array>
```

```
</_Data>
```

```
(70) .mask_list
PASSED
```

```
<_Data>
```

```
<Array Qty="0004" >
  <Structure Qty="0002" >
    <OctetString Value="01" />
    <Array Qty="0017" >
      <Unsigned Value="00" />
      <Unsigned Value="01" />
      <Unsigned Value="05" />
      <Unsigned Value="06" />
      <Unsigned Value="0A" />
      <Unsigned Value="0B" />
      <Unsigned Value="0F" />
      <Unsigned Value="10" />
      <Unsigned Value="14" />
    </Array>
  </Structure>
</Array>
```

```
<Unsigned Value="15" />
<Unsigned Value="19" />
<Unsigned Value="1A" />
<Unsigned Value="1E" />
<Unsigned Value="1F" />
<Unsigned Value="23" />
<Unsigned Value="24" />
<Unsigned Value="28" />
<Unsigned Value="29" />
<Unsigned Value="2D" />
<Unsigned Value="2E" />
<Unsigned Value="32" />
<Unsigned Value="33" />
<Unsigned Value="37" />
</Array>
</Structure>
<Structure Qty="0002" >
  <OctetString Value="02" />
  <Array Qty="0017" >
    <Unsigned Value="00" />
    <Unsigned Value="02" />
    <Unsigned Value="05" />
    <Unsigned Value="07" />
    <Unsigned Value="0A" />
    <Unsigned Value="0C" />
    <Unsigned Value="0F" />
    <Unsigned Value="11" />
    <Unsigned Value="14" />
    <Unsigned Value="16" />
    <Unsigned Value="19" />
    <Unsigned Value="1B" />
    <Unsigned Value="1E" />
    <Unsigned Value="20" />
    <Unsigned Value="23" />
    <Unsigned Value="25" />
    <Unsigned Value="28" />
    <Unsigned Value="2A" />
    <Unsigned Value="2D" />
    <Unsigned Value="2F" />
    <Unsigned Value="32" />
    <Unsigned Value="34" />
    <Unsigned Value="37" />
  </Array>
</Structure>
<Structure Qty="0002" >
  <OctetString Value="03" />
  <Array Qty="0017" >
    <Unsigned Value="00" />
    <Unsigned Value="03" />
    <Unsigned Value="05" />
    <Unsigned Value="08" />
    <Unsigned Value="0A" />
    <Unsigned Value="0D" />
    <Unsigned Value="0F" />
```

```
        <Unsigned Value="12" />
        <Unsigned Value="14" />
        <Unsigned Value="17" />
        <Unsigned Value="19" />
        <Unsigned Value="1C" />
        <Unsigned Value="1E" />
        <Unsigned Value="21" />
        <Unsigned Value="23" />
        <Unsigned Value="26" />
        <Unsigned Value="28" />
        <Unsigned Value="2B" />
        <Unsigned Value="2D" />
        <Unsigned Value="30" />
        <Unsigned Value="32" />
        <Unsigned Value="35" />
        <Unsigned Value="37" />
    </Array>
</Structure>
<Structure Qty="0002" >
    <OctetString Value="04" />
    <Array Qty="0017" >
        <Unsigned Value="00" />
        <Unsigned Value="04" />
        <Unsigned Value="05" />
        <Unsigned Value="09" />
        <Unsigned Value="0A" />
        <Unsigned Value="0E" />
        <Unsigned Value="0F" />
        <Unsigned Value="13" />
        <Unsigned Value="14" />
        <Unsigned Value="18" />
        <Unsigned Value="19" />
        <Unsigned Value="1D" />
        <Unsigned Value="1E" />
        <Unsigned Value="22" />
        <Unsigned Value="23" />
        <Unsigned Value="27" />
        <Unsigned Value="28" />
        <Unsigned Value="2C" />
        <Unsigned Value="2D" />
        <Unsigned Value="31" />
        <Unsigned Value="32" />
        <Unsigned Value="36" />
        <Unsigned Value="37" />
    </Array>
</Structure>
</Array>
</_Data>
(71) .active_mask
PASSED
    <Data>
        <OctetString Value="04" />
    </Data>
```

Mngmt Get Register activation - Maximum Demand 0-0:14.0.2.255 (@135)

(72) .logical_name

PASSED

```
<Data>
  <OctetString Value="00000E0002FF" />
</Data>
```

(73) .register_assignment

PASSED

```
<_Data>
  <Array Qty="0049" >
    <Structure Qty="0002" >
      <LongUnsigned Value="0005" />
      <OctetString Value="0100010400FF" />
    </Structure>
    <Structure Qty="0002" >
      <LongUnsigned Value="0004" />
      <OctetString Value="0100010500FF" />
    </Structure>
    <Structure Qty="0002" >
      <LongUnsigned Value="0004" />
      <OctetString Value="0100010600FF" />
    </Structure>
    <Structure Qty="0002" >
      <LongUnsigned Value="0004" />
      <OctetString Value="0100010601FF" />
    </Structure>
    <Structure Qty="0002" >
      <LongUnsigned Value="0004" />
      <OctetString Value="0100010602FF" />
    </Structure>
    <Structure Qty="0002" >
      <LongUnsigned Value="0004" />
      <OctetString Value="0100010603FF" />
    </Structure>
    <Structure Qty="0002" >
      <LongUnsigned Value="0004" />
      <OctetString Value="0100010604FF" />
    </Structure>
    <Structure Qty="0002" >
      <LongUnsigned Value="0005" />
      <OctetString Value="0100020400FF" />
    </Structure>
    <Structure Qty="0002" >
      <LongUnsigned Value="0004" />
      <OctetString Value="0100020500FF" />
    </Structure>
    <Structure Qty="0002" >
      <LongUnsigned Value="0004" />
      <OctetString Value="0100020600FF" />
    </Structure>
    <Structure Qty="0002" >
      <LongUnsigned Value="0004" />
      <OctetString Value="0100020601FF" />
    </Structure>
  </Array>
</_Data>
```

```
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100020602FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100020603FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100020604FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0005" />
  <OctetString Value="0100030400FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100030500FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100030600FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100030601FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100030602FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100030603FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100030604FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0005" />
  <OctetString Value="0100040400FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100040500FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100040600FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
```

```
<OctetString Value="0100040601FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100040602FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100040603FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100040604FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0005" />
  <OctetString Value="0100050400FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100050500FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100050600FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100050601FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100050602FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100050603FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100050604FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0005" />
  <OctetString Value="0100060400FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100060500FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100060600FF" />
</Structure>
```



```
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100060601FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100060602FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100060603FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100060604FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0005" />
  <OctetString Value="0100070400FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100070500FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100070600FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100070601FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100070602FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100070603FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100070604FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0005" />
  <OctetString Value="0100080400FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100080500FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
```

```
<OctetString Value="0100080600FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100080601FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100080602FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100080603FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100080604FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0005" />
  <OctetString Value="0100090400FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100090500FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100090600FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100090601FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100090602FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100090603FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100090604FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0005" />
  <OctetString Value="01000A0400FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="01000A0500FF" />
</Structure>
```

```
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="01000A0600FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="01000A0601FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="01000A0602FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="01000A0603FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="01000A0604FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0005" />
  <OctetString Value="0100011800FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0005" />
  <OctetString Value="01000F1800FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0005" />
  <OctetString Value="0100101800FF" />
</Structure>
```

</Array>

</_Data>

(74) .mask_list

PASSED

<_Data>

```
<Array Qty="0004" >
  <Structure Qty="0002" >
    <OctetString Value="01" />
    <Array Qty="002B" >
      <Unsigned Value="00" />
      <Unsigned Value="01" />
      <Unsigned Value="02" />
      <Unsigned Value="03" />
      <Unsigned Value="07" />
      <Unsigned Value="08" />
      <Unsigned Value="09" />
      <Unsigned Value="0A" />
      <Unsigned Value="0E" />
      <Unsigned Value="0F" />
      <Unsigned Value="10" />
      <Unsigned Value="11" />
      <Unsigned Value="15" />
    </Array>
  </Structure>
</Array>
```

```
<Unsigned Value="16" />
<Unsigned Value="17" />
<Unsigned Value="18" />
<Unsigned Value="1C" />
<Unsigned Value="1D" />
<Unsigned Value="1E" />
<Unsigned Value="1F" />
<Unsigned Value="23" />
<Unsigned Value="24" />
<Unsigned Value="25" />
<Unsigned Value="26" />
<Unsigned Value="2A" />
<Unsigned Value="2B" />
<Unsigned Value="2C" />
<Unsigned Value="2D" />
<Unsigned Value="31" />
<Unsigned Value="32" />
<Unsigned Value="33" />
<Unsigned Value="34" />
<Unsigned Value="38" />
<Unsigned Value="39" />
<Unsigned Value="3A" />
<Unsigned Value="3B" />
<Unsigned Value="3F" />
<Unsigned Value="40" />
<Unsigned Value="41" />
<Unsigned Value="42" />
<Unsigned Value="46" />
<Unsigned Value="47" />
<Unsigned Value="48" />
</Array>
</Structure>
<Structure Qty="0002" >
  <OctetString Value="02" />
  <Array Qty="002B" >
    <Unsigned Value="00" />
    <Unsigned Value="01" />
    <Unsigned Value="02" />
    <Unsigned Value="04" />
    <Unsigned Value="07" />
    <Unsigned Value="08" />
    <Unsigned Value="09" />
    <Unsigned Value="0B" />
    <Unsigned Value="0E" />
    <Unsigned Value="0F" />
    <Unsigned Value="10" />
    <Unsigned Value="12" />
    <Unsigned Value="15" />
    <Unsigned Value="16" />
    <Unsigned Value="17" />
    <Unsigned Value="19" />
    <Unsigned Value="1C" />
    <Unsigned Value="1D" />
    <Unsigned Value="1E" />
```

```
<Unsigned Value="20" />
<Unsigned Value="23" />
<Unsigned Value="24" />
<Unsigned Value="25" />
<Unsigned Value="27" />
<Unsigned Value="2A" />
<Unsigned Value="2B" />
<Unsigned Value="2C" />
<Unsigned Value="2E" />
<Unsigned Value="31" />
<Unsigned Value="32" />
<Unsigned Value="33" />
<Unsigned Value="35" />
<Unsigned Value="38" />
<Unsigned Value="39" />
<Unsigned Value="3A" />
<Unsigned Value="3C" />
<Unsigned Value="3F" />
<Unsigned Value="40" />
<Unsigned Value="41" />
<Unsigned Value="43" />
<Unsigned Value="46" />
<Unsigned Value="47" />
<Unsigned Value="48" />
</Array>
</Structure>
<Structure Qty="0002" >
  <OctetString Value="03" />
  <Array Qty="002B" >
    <Unsigned Value="00" />
    <Unsigned Value="01" />
    <Unsigned Value="02" />
    <Unsigned Value="05" />
    <Unsigned Value="07" />
    <Unsigned Value="08" />
    <Unsigned Value="09" />
    <Unsigned Value="0C" />
    <Unsigned Value="0E" />
    <Unsigned Value="0F" />
    <Unsigned Value="10" />
    <Unsigned Value="13" />
    <Unsigned Value="15" />
    <Unsigned Value="16" />
    <Unsigned Value="17" />
    <Unsigned Value="1A" />
    <Unsigned Value="1C" />
    <Unsigned Value="1D" />
    <Unsigned Value="1E" />
    <Unsigned Value="21" />
    <Unsigned Value="23" />
    <Unsigned Value="24" />
    <Unsigned Value="25" />
    <Unsigned Value="28" />
    <Unsigned Value="2A" />
```

```
<Unsigned Value="2B" />
<Unsigned Value="2C" />
<Unsigned Value="2F" />
<Unsigned Value="31" />
<Unsigned Value="32" />
<Unsigned Value="33" />
<Unsigned Value="36" />
<Unsigned Value="38" />
<Unsigned Value="39" />
<Unsigned Value="3A" />
<Unsigned Value="3D" />
<Unsigned Value="3F" />
<Unsigned Value="40" />
<Unsigned Value="41" />
<Unsigned Value="44" />
<Unsigned Value="46" />
<Unsigned Value="47" />
<Unsigned Value="48" />
</Array>
</Structure>
<Structure Qty="0002" >
  <OctetString Value="04" />
  <Array Qty="002B" >
    <Unsigned Value="00" />
    <Unsigned Value="01" />
    <Unsigned Value="02" />
    <Unsigned Value="06" />
    <Unsigned Value="07" />
    <Unsigned Value="08" />
    <Unsigned Value="09" />
    <Unsigned Value="0D" />
    <Unsigned Value="0E" />
    <Unsigned Value="0F" />
    <Unsigned Value="10" />
    <Unsigned Value="14" />
    <Unsigned Value="15" />
    <Unsigned Value="16" />
    <Unsigned Value="17" />
    <Unsigned Value="1B" />
    <Unsigned Value="1C" />
    <Unsigned Value="1D" />
    <Unsigned Value="1E" />
    <Unsigned Value="22" />
    <Unsigned Value="23" />
    <Unsigned Value="24" />
    <Unsigned Value="25" />
    <Unsigned Value="29" />
    <Unsigned Value="2A" />
    <Unsigned Value="2B" />
    <Unsigned Value="2C" />
    <Unsigned Value="30" />
    <Unsigned Value="31" />
    <Unsigned Value="32" />
    <Unsigned Value="33" />
```

```

        <Unsigned Value="37" />
        <Unsigned Value="38" />
        <Unsigned Value="39" />
        <Unsigned Value="3A" />
        <Unsigned Value="3E" />
        <Unsigned Value="3F" />
        <Unsigned Value="40" />
        <Unsigned Value="41" />
        <Unsigned Value="45" />
        <Unsigned Value="46" />
        <Unsigned Value="47" />
        <Unsigned Value="48" />
    </Array>
</Structure>
</Array>
</_Data>
(75) .active_mask
PASSED
    <Data>
        <OctetString Value="04" />
    </Data>

Mngmt Get Tariffication script table 0-0:10.0.100.255 (@141)
(76) .logical_name
PASSED
    <Data>
        <OctetString Value="0000A0064FF" />
    </Data>
(77) .scripts
PASSED
    <_Data>
        <Array Qty="0004" >
            <Structure Qty="0002" >
                <LongUnsigned Value="0001" />
                <Array Qty="0003" >
                    <Structure Qty="0005" >
                        <Enum Value="01" />
                        <LongUnsigned Value="0006" />
                        <OctetString Value="00000E0001FF" />
                        <Integer Value="04" />
                        <OctetString Value="01" />
                    </Structure>
                    <Structure Qty="0005" >
                        <Enum Value="01" />
                        <LongUnsigned Value="0006" />
                        <OctetString Value="00000E0002FF" />
                        <Integer Value="04" />
                        <OctetString Value="01" />
                    </Structure>
                    <Structure Qty="0005" >
                        <Enum Value="01" />
                        <LongUnsigned Value="0046" />
                        <OctetString Value="000160030AFF" />
                        <Integer Value="03" />
                    </Structure>
                </Array>
            </Structure>
        </Array>
    </_Data>

```

```
        <Enum Value="02" />
    </Structure>
</Array>
</Structure>
<Structure Qty="0002" >
    <LongUnsigned Value="0002" />
    <Array Qty="0003" >
        <Structure Qty="0005" >
            <Enum Value="01" />
            <LongUnsigned Value="0006" />
            <OctetString Value="00000E0001FF" />
            <Integer Value="04" />
            <OctetString Value="02" />
        </Structure>
        <Structure Qty="0005" >
            <Enum Value="01" />
            <LongUnsigned Value="0006" />
            <OctetString Value="00000E0002FF" />
            <Integer Value="04" />
            <OctetString Value="02" />
        </Structure>
        <Structure Qty="0005" >
            <Enum Value="01" />
            <LongUnsigned Value="0046" />
            <OctetString Value="000160030AFF" />
            <Integer Value="03" />
            <Enum Value="01" />
        </Structure>
    </Array>
</Structure>
<Structure Qty="0002" >
    <LongUnsigned Value="0003" />
    <Array Qty="0003" >
        <Structure Qty="0005" >
            <Enum Value="01" />
            <LongUnsigned Value="0006" />
            <OctetString Value="00000E0001FF" />
            <Integer Value="04" />
            <OctetString Value="03" />
        </Structure>
        <Structure Qty="0005" >
            <Enum Value="01" />
            <LongUnsigned Value="0006" />
            <OctetString Value="00000E0002FF" />
            <Integer Value="04" />
            <OctetString Value="03" />
        </Structure>
        <Structure Qty="0005" >
            <Enum Value="01" />
            <LongUnsigned Value="0046" />
            <OctetString Value="000160030AFF" />
            <Integer Value="03" />
            <Enum Value="02" />
        </Structure>
    </Array>
</Structure>
```



```

    </Array>
  </Structure>
  <Structure Qty="0002" >
    <LongUnsigned Value="0004" />
    <Array Qty="0003" >
      <Structure Qty="0005" >
        <Enum Value="01" />
        <LongUnsigned Value="0006" />
        <OctetString Value="00000E0001FF" />
        <Integer Value="04" />
        <OctetString Value="04" />
      </Structure>
      <Structure Qty="0005" >
        <Enum Value="01" />
        <LongUnsigned Value="0006" />
        <OctetString Value="00000E0002FF" />
        <Integer Value="04" />
        <OctetString Value="04" />
      </Structure>
      <Structure Qty="0005" >
        <Enum Value="01" />
        <LongUnsigned Value="0046" />
        <OctetString Value="000160030AFF" />
        <Integer Value="03" />
        <Enum Value="01" />
      </Structure>
    </Array>
  </Structure>
</Array>
</_Data>

```

Mngmt Get Predefined Scripts - MDI reset / end of billing period
0-0:10.0.1.255 (@147)
(78) .logical_name
PASSED

```

  <Data>
    <OctetString Value="00000A0001FF" />
  </Data>

```

(79) .scripts
INAPPLICABLE
Optional access right not available

Mngmt Get End of billing period 1 scheduler 0-0:15.0.0.255 (@152)
(80) .logical_name
PASSED

```

  <Data>
    <OctetString Value="00000F0000FF" />
  </Data>

```

(81) .executed_script
PASSED

```

  <Data>
    <Structure Qty="0002" >
      <OctetString Value="00000A0001FF" />
      <LongUnsigned Value="0001" />
    </Structure>
  </Data>

```

```
        </Structure>
    </Data>
```

(82) .type
PASSED

```
    <Data>
        <Enum Value="01" />
    </Data>
```

(83) .execution_time
PASSED

```
    <Data>
        <Array Qty="0001" >
            <Structure Qty="0002" >
                <OctetString Value="00000000" />
                <OctetString Value="FFFFFF02FF" />
            </Structure>
        </Array>
    </Data>
```

Mngmt Get Data of billing period 1 0-0:98.1.0.255 (@158)

(84) .logical_name
PASSED

```
    <Data>
        <OctetString Value="0000620100FF" />
    </Data>
```

(85) .capture_objects
PASSED

```
    <Data>
        <Array Qty="0005" >
            <Structure Qty="0004" >
                <LongUnsigned Value="0008" />
                <OctetString Value="0000010000FF" />
                <Integer Value="02" />
                <LongUnsigned Value="0000" />
            </Structure>
            <Structure Qty="0004" >
                <LongUnsigned Value="0003" />
                <OctetString Value="0100010801FF" />
                <Integer Value="02" />
                <LongUnsigned Value="0000" />
            </Structure>
            <Structure Qty="0004" >
                <LongUnsigned Value="0003" />
                <OctetString Value="0100010802FF" />
                <Integer Value="02" />
                <LongUnsigned Value="0000" />
            </Structure>
            <Structure Qty="0004" >
                <LongUnsigned Value="0003" />
                <OctetString Value="0100020801FF" />
                <Integer Value="02" />
                <LongUnsigned Value="0000" />
            </Structure>
            <Structure Qty="0004" >
                <LongUnsigned Value="0003" />
            </Structure>
        </Array>
```

```

        <OctetString Value="0100020802FF" />
        <Integer Value="02" />
        <LongUnsigned Value="0000" />
    </Structure>
</Array>
</Data>
(86) .capture_period
PASSED
    <Data>
        <DoubleLongUnsigned Value="00000000" />
    </Data>
(87) .sort_method
PASSED
    <Data>
        <Enum Value="01" />
    </Data>
(88) .sort_object
PASSED
    <Data>
        <Structure Qty="0004" >
            <LongUnsigned Value="0008" />
            <OctetString Value="0000010000FF" />
            <Integer Value="02" />
            <LongUnsigned Value="0000" />
        </Structure>
    </Data>
(89) .entries_in_use
PASSED
    <Data>
        <DoubleLongUnsigned Value="0000000D" />
    </Data>
(90) .profile_entries
PASSED
    <Data>
        <DoubleLongUnsigned Value="0000000D" />
    </Data>

Mngmt Get Disconnect control scheduler 0-0:15.0.1.255 (@170)
(91) .logical_name
PASSED
    <Data>
        <OctetString Value="00000F0001FF" />
    </Data>
(92) .executed_script
PASSED
    <Data>
        <Structure Qty="0002" >
            <OctetString Value="00000A006AFF" />
            <LongUnsigned Value="0001" />
        </Structure>
    </Data>
(93) .type
PASSED
    <Data>

```

```

        <Enum Value="01" />
    </Data>
(94) .execution_time
PASSED
    <Data>
        <Array Qty="0000" >
            </Array>
        </Data>

Mngmt Get Disconnecter script table 0-0:10.0.106.255 (@176)
(95) .logical_name
PASSED
    <Data>
        <OctetString Value="00000A006AFF" />
    </Data>
(96) .scripts
PASSED
    <Data>
        <Array Qty="0004" >
            <Structure Qty="0002" >
                <LongUnsigned Value="0001" />
                <Array Qty="0001" >
                    <Structure Qty="0005" >
                        <Enum Value="01" />
                        <LongUnsigned Value="0046" />
                        <OctetString Value="000060030AFF" />
                        <Integer Value="03" />
                        <Enum Value="02" />
                    </Structure>
                </Array>
            </Structure>
            <Structure Qty="0002" >
                <LongUnsigned Value="0002" />
                <Array Qty="0001" >
                    <Structure Qty="0005" >
                        <Enum Value="01" />
                        <LongUnsigned Value="0046" />
                        <OctetString Value="000060030AFF" />
                        <Integer Value="03" />
                        <Enum Value="01" />
                    </Structure>
                </Array>
            </Structure>
            <Structure Qty="0002" >
                <LongUnsigned Value="0003" />
                <Array Qty="0001" >
                    <Structure Qty="0005" >
                        <Enum Value="02" />
                        <LongUnsigned Value="0046" />
                        <OctetString Value="000060030AFF" />
                        <Integer Value="01" />
                        <Integer Value="00" />
                    </Structure>
                </Array>
            </Structure>
        </Array>
    </Data>

```

```
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <Array Qty="0001" >
    <Structure Qty="0005" >
      <Enum Value="02" />
      <LongUnsigned Value="0046" />
      <OctetString Value="000060030AFF" />
      <Integer Value="02" />
      <Integer Value="00" />
    </Structure>
  </Array>
</Structure>
</Array>
</Data>
```

Mngmt Get Disconnect control 0-0:96.3.10.255 (@181)
(97) .logical_name
PASSED

```
<Data>
  <OctetString Value="000060030AFF" />
</Data>
```

(98) .output_state
PASSED

```
<Data>
  <Boolean Value="00" />
</Data>
```

(99) .control_state
PASSED

```
<Data>
  <Enum Value="02" />
</Data>
```

(100) .control_mode
PASSED

```
<Data>
  <Enum Value="06" />
</Data>
```

Mngmt Get Event Object - Disconnect Control log 0-0:96.11.2.255 (@189)
(101) .logical_name
PASSED

```
<Data>
  <OctetString Value="0000600B02FF" />
</Data>
```

(102) .value
PASSED

```
<Data>
  <Enum Value="3B" />
</Data>
```

Mngmt Get Disconnect Control Log 0-0:99.98.2.255 (@193)
(103) .logical_name
PASSED

```
<Data>
```

```

        <OctetString Value="0000636202FF" />
    </Data>
(104) .capture_objects
PASSED
    <Data>
        <Array Qty="0003" >
            <Structure Qty="0004" >
                <LongUnsigned Value="0008" />
                <OctetString Value="0000010000FF" />
                <Integer Value="02" />
                <LongUnsigned Value="0000" />
            </Structure>
            <Structure Qty="0004" >
                <LongUnsigned Value="0001" />
                <OctetString Value="0000600B02FF" />
                <Integer Value="02" />
                <LongUnsigned Value="0000" />
            </Structure>
            <Structure Qty="0004" >
                <LongUnsigned Value="0047" />
                <OctetString Value="0000110000FF" />
                <Integer Value="03" />
                <LongUnsigned Value="0000" />
            </Structure>
        </Array>
    </Data>
(105) .capture_period
PASSED
    <Data>
        <DoubleLongUnsigned Value="00000000" />
    </Data>
(106) .sort_method
PASSED
    <Data>
        <Enum Value="01" />
    </Data>
(107) .sort_object
PASSED
    <Data>
        <Structure Qty="0004" >
            <LongUnsigned Value="0008" />
            <OctetString Value="0000010000FF" />
            <Integer Value="02" />
            <LongUnsigned Value="0000" />
        </Structure>
    </Data>
(108) .entries_in_use
PASSED
    <Data>
        <DoubleLongUnsigned Value="0000001E" />
    </Data>
(109) .profile_entries
PASSED
    <Data>

```

```
    <DoubleLongUnsigned Value="0000001E" />
  </Data>
```

Mngmt Get Load Mgmt script table 0-0:10.0.103.255 (@204)
(110) .logical_name
PASSED

```
  <Data>
    <OctetString Value="00000A0067FF" />
  </Data>
```

(111) .scripts
PASSED

```
  <_Data>
    <Array Qty="000D" >
      <Structure Qty="0002" >
        <LongUnsigned Value="0001" />
        <Array Qty="0001" >
          <Structure Qty="0005" >
            <Enum Value="01" />
            <LongUnsigned Value="0046" />
            <OctetString Value="000160030AFF" />
            <Integer Value="03" />
            <Enum Value="02" />
          </Structure>
        </Array>
      </Structure>
      <Structure Qty="0002" >
        <LongUnsigned Value="0002" />
        <Array Qty="0001" >
          <Structure Qty="0005" >
            <Enum Value="01" />
            <LongUnsigned Value="0046" />
            <OctetString Value="000160030AFF" />
            <Integer Value="03" />
            <Enum Value="01" />
          </Structure>
        </Array>
      </Structure>
      <Structure Qty="0002" >
        <LongUnsigned Value="0003" />
        <Array Qty="0001" >
          <Structure Qty="0005" >
            <Enum Value="02" />
            <LongUnsigned Value="0046" />
            <OctetString Value="000160030AFF" />
            <Integer Value="01" />
            <Integer Value="00" />
          </Structure>
        </Array>
      </Structure>
      <Structure Qty="0002" >
        <LongUnsigned Value="0004" />
        <Array Qty="0001" >
          <Structure Qty="0005" >
            <Enum Value="02" />

```

```
        <LongUnsigned Value="0046" />
        <OctetString Value="000160030AFF" />
        <Integer Value="02" />
        <Integer Value="00" />
    </Structure>
</Array>
</Structure>
<Structure Qty="0002" >
    <LongUnsigned Value="0041" />
    <Array Qty="0002" >
        <Structure Qty="0005" >
            <Enum Value="01" />
            <LongUnsigned Value="0001" />
            <OctetString Value="0000600B02FF" />
            <Integer Value="02" />
            <Enum Value="41" />
        </Structure>
        <Structure Qty="0005" >
            <Enum Value="02" />
            <LongUnsigned Value="0007" />
            <OctetString Value="0000636202FF" />
            <Integer Value="02" />
            <Integer Value="00" />
        </Structure>
    </Array>
</Structure>
<Structure Qty="0002" >
    <LongUnsigned Value="0042" />
    <Array Qty="0002" >
        <Structure Qty="0005" >
            <Enum Value="01" />
            <LongUnsigned Value="0001" />
            <OctetString Value="0000600B02FF" />
            <Integer Value="02" />
            <Enum Value="42" />
        </Structure>
        <Structure Qty="0005" >
            <Enum Value="02" />
            <LongUnsigned Value="0007" />
            <OctetString Value="0000636202FF" />
            <Integer Value="02" />
            <Integer Value="00" />
        </Structure>
    </Array>
</Structure>
<Structure Qty="0002" >
    <LongUnsigned Value="0043" />
    <Array Qty="0002" >
        <Structure Qty="0005" >
            <Enum Value="01" />
            <LongUnsigned Value="0001" />
            <OctetString Value="0000600B02FF" />
            <Integer Value="02" />
            <Enum Value="43" />
        </Structure>
```



```

    </Structure>
    <Structure Qty="0005" >
      <Enum Value="02" />
      <LongUnsigned Value="0007" />
      <OctetString Value="0000636202FF" />
      <Integer Value="02" />
      <Integer Value="00" />
    </Structure>
  </Array>
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0046" />
  <Array Qty="0003" >
    <Structure Qty="0005" >
      <Enum Value="01" />
      <LongUnsigned Value="0001" />
      <OctetString Value="0000600B02FF" />
      <Integer Value="02" />
      <Enum Value="46" />
    </Structure>
    <Structure Qty="0005" >
      <Enum Value="02" />
      <LongUnsigned Value="0007" />
      <OctetString Value="0000636202FF" />
      <Integer Value="02" />
      <Integer Value="00" />
    </Structure>
    <Structure Qty="0005" >
      <Enum Value="01" />
      <LongUnsigned Value="0001" />
      <OctetString Value="0000600300FF" />
      <Integer Value="02" />
      <BitString Value="00001000000000000000000000000000" />
    </Structure>
  </Array>
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0047" />
  <Array Qty="0003" >
    <Structure Qty="0005" >
      <Enum Value="01" />
      <LongUnsigned Value="0001" />
      <OctetString Value="0000600B02FF" />
      <Integer Value="02" />
      <Enum Value="47" />
    </Structure>
    <Structure Qty="0005" >
      <Enum Value="02" />
      <LongUnsigned Value="0007" />
      <OctetString Value="0000636202FF" />
      <Integer Value="02" />
      <Integer Value="00" />
    </Structure>
  </Array>
</Structure>

```

```

        <Enum Value="01" />
        <LongUnsigned Value="0001" />
        <OctetString Value="0000600300FF" />
        <Integer Value="02" />
        <BitString Value="00000000000000000000000000000000" />
    </Structure>
</Array>
</Structure>
<Structure Qty="0002" >
    <LongUnsigned Value="0048" />
    <Array Qty="0003" >
        <Structure Qty="0005" >
            <Enum Value="01" />
            <LongUnsigned Value="0001" />
            <OctetString Value="0000600B02FF" />
            <Integer Value="02" />
            <Enum Value="48" />
        </Structure>
        <Structure Qty="0005" >
            <Enum Value="02" />
            <LongUnsigned Value="0007" />
            <OctetString Value="0000636202FF" />
            <Integer Value="02" />
            <Integer Value="00" />
        </Structure>
        <Structure Qty="0005" >
            <Enum Value="01" />
            <LongUnsigned Value="0001" />
            <OctetString Value="0000600300FF" />
            <Integer Value="02" />
            <BitString Value="00010000000000000000000000000000" />
        </Structure>
    </Array>
</Structure>
<Structure Qty="0002" >
    <LongUnsigned Value="0049" />
    <Array Qty="0003" >
        <Structure Qty="0005" >
            <Enum Value="01" />
            <LongUnsigned Value="0001" />
            <OctetString Value="0000600B02FF" />
            <Integer Value="02" />
            <Enum Value="49" />
        </Structure>
        <Structure Qty="0005" >
            <Enum Value="02" />
            <LongUnsigned Value="0007" />
            <OctetString Value="0000636202FF" />
            <Integer Value="02" />
            <Integer Value="00" />
        </Structure>
        <Structure Qty="0005" >
            <Enum Value="01" />
            <LongUnsigned Value="0001" />

```

```

        <OctetString Value="0000600300FF" />
        <Integer Value="02" />
        <BitString Value="00000000000000000000000000000000" />
    </Structure>
</Array>
</Structure>
<Structure Qty="0002" >
    <LongUnsigned Value="004A" />
    <Array Qty="0003" >
        <Structure Qty="0005" >
            <Enum Value="01" />
            <LongUnsigned Value="0001" />
            <OctetString Value="0000600B02FF" />
            <Integer Value="02" />
            <Enum Value="4A" />
        </Structure>
        <Structure Qty="0005" >
            <Enum Value="02" />
            <LongUnsigned Value="0007" />
            <OctetString Value="0000636202FF" />
            <Integer Value="02" />
            <Integer Value="00" />
        </Structure>
        <Structure Qty="0005" >
            <Enum Value="01" />
            <LongUnsigned Value="0001" />
            <OctetString Value="0000600300FF" />
            <Integer Value="02" />
            <BitString Value="00100000000000000000000000000000" />
        </Structure>
    </Array>
</Structure>
<Structure Qty="0002" >
    <LongUnsigned Value="004B" />
    <Array Qty="0003" >
        <Structure Qty="0005" >
            <Enum Value="01" />
            <LongUnsigned Value="0001" />
            <OctetString Value="0000600B02FF" />
            <Integer Value="02" />
            <Enum Value="4B" />
        </Structure>
        <Structure Qty="0005" >
            <Enum Value="02" />
            <LongUnsigned Value="0007" />
            <OctetString Value="0000636202FF" />
            <Integer Value="02" />
            <Integer Value="00" />
        </Structure>
        <Structure Qty="0005" >
            <Enum Value="01" />
            <LongUnsigned Value="0001" />
            <OctetString Value="0000600300FF" />
            <Integer Value="02" />
        </Structure>
    </Array>
</Structure>

```

```
        <BitString Value="00000000000000000000000000000000" />
      </Structure>
    </Array>
  </Structure>
</Array>
</_Data>
```

Mngmt Get Load Mgmt - Relay control 1 0-1:96.3.10.255 (@209)

(112) .logical_name

PASSED

```
  <Data>
    <OctetString Value="000160030AFF" />
  </Data>
```

(113) .output_state

PASSED

```
  <Data>
    <Boolean Value="01" />
  </Data>
```

(114) .control_state

PASSED

```
  <Data>
    <Enum Value="01" />
  </Data>
```

(115) .control_mode

PASSED

```
  <Data>
    <Enum Value="06" />
  </Data>
```

Mngmt Get Load Mgmt - Relay control 2 0-2:96.3.10.255 (@217)

(116) .logical_name

PASSED

```
  <Data>
    <OctetString Value="000260030AFF" />
  </Data>
```

(117) .output_state

PASSED

```
  <Data>
    <Boolean Value="01" />
  </Data>
```

(118) .control_state

PASSED

```
  <Data>
    <Enum Value="01" />
  </Data>
```

(119) .control_mode

PASSED

```
  <Data>
    <Enum Value="06" />
  </Data>
```

Mngmt Get Limiter 0-0:17.0.0.255 (@225)

(120) .logical_name

PASSED

```
<Data>
  <OctetString Value="0000110000FF" />
</Data>
(121) .monitored_value
PASSED
  <Data>
    <Structure Qty="0003" >
      <LongUnsigned Value="0005" />
      <OctetString Value="0100011800FF" />
      <Integer Value="02" />
    </Structure>
  </Data>
(122) .threshold_active
PASSED
  <Data>
    <DoubleLongUnsigned Value="00000000" />
  </Data>
(123) .threshold_normal
PASSED
  <Data>
    <DoubleLongUnsigned Value="00010D88" />
  </Data>
(124) .treshold_emergency
PASSED
  <Data>
    <DoubleLongUnsigned Value="00010D88" />
  </Data>
(125) .min_over_threshold_duration
PASSED
  <Data>
    <DoubleLongUnsigned Value="000000B4" />
  </Data>
(126) .min_under_threshold_duration
PASSED
  <Data>
    <DoubleLongUnsigned Value="000000B4" />
  </Data>
(127) .emergency_profile
PASSED
  <Data>
    <Structure Qty="0003" >
      <LongUnsigned Value="FFFF" />
      <OctetString Value="FFFFFFFFFFFFFFFF008000FF" />
      <DoubleLongUnsigned Value="00000000" />
    </Structure>
  </Data>
(128) .emergency_profile_group_id_list
PASSED
  <Data>
    <Array Qty="0000" >
      </Array>
  </Data>
(129) .emergency_profile_active
PASSED
```

```
    <Data>
      <Boolean Value="00" />
    </Data>
```

(130) .actions

PASSED

```
    <Data>
      <Structure Qty="0002" >
        <Structure Qty="0002" >
          <OctetString Value="00000A006AFF" />
          <LongUnsigned Value="0001" />
        </Structure>
        <Structure Qty="0002" >
          <OctetString Value="00000A006AFF" />
          <LongUnsigned Value="0002" />
        </Structure>
      </Structure>
    </Data>
```

Mngmt Get Supervision monitor 1 - Fuse supervision L1 1-0:31.4.0.255 (@238)

(131) .logical_name

PASSED

```
    <Data>
      <OctetString Value="01001F0400FF" />
    </Data>
```

(132) .thresholds

PASSED

```
    <Data>
      <Array Qty="0001" >
        <DoubleLongUnsigned Value="00002710" />
      </Array>
    </Data>
```

(133) .monitored_value

PASSED

```
    <Data>
      <Structure Qty="0003" >
        <LongUnsigned Value="0005" />
        <OctetString Value="01001F0400FF" />
        <Integer Value="02" />
      </Structure>
    </Data>
```

(134) .actions

PASSED

```
    <Data>
      <Array Qty="0001" >
        <Structure Qty="0002" >
          <Structure Qty="0002" >
            <OctetString Value="00000A006AFF" />
            <LongUnsigned Value="0001" />
          </Structure>
          <Structure Qty="0002" >
            <OctetString Value="00000A006AFF" />
            <LongUnsigned Value="0002" />
          </Structure>
        </Structure>
      </Array>
```

```
    </Array>
  </Data>
```

Mngmt Get Supervision monitor 2 - Fuse supervision L2 1-0:51.4.0.255 (@244)

(135) .logical_name

PASSED

```
  <Data>
    <OctetString Value="0100330400FF" />
  </Data>
```

(136) .thresholds

PASSED

```
  <Data>
    <Array Qty="0001" >
      <DoubleLongUnsigned Value="00002710" />
    </Array>
  </Data>
```

(137) .monitored_value

PASSED

```
  <Data>
    <Structure Qty="0003" >
      <LongUnsigned Value="0005" />
      <OctetString Value="0100330400FF" />
      <Integer Value="02" />
    </Structure>
  </Data>
```

(138) .actions

PASSED

```
  <Data>
    <Array Qty="0001" >
      <Structure Qty="0002" >
        <Structure Qty="0002" >
          <OctetString Value="00000A006AFF" />
          <LongUnsigned Value="0001" />
        </Structure>
        <Structure Qty="0002" >
          <OctetString Value="00000A006AFF" />
          <LongUnsigned Value="0002" />
        </Structure>
      </Structure>
    </Array>
  </Data>
```

Mngmt Get Supervision monitor 3 - Fuse supervision L3 1-0:71.4.0.255 (@250)

(139) .logical_name

PASSED

```
  <Data>
    <OctetString Value="0100470400FF" />
  </Data>
```

(140) .thresholds

PASSED

```
  <Data>
    <Array Qty="0001" >
      <DoubleLongUnsigned Value="00002710" />
    </Array>
```

```

    </Data>
(141) .monitored_value
PASSED
    <Data>
        <Structure Qty="0003" >
            <LongUnsigned Value="0005" />
            <OctetString Value="0100470400FF" />
            <Integer Value="02" />
        </Structure>
    </Data>
(142) .actions
PASSED
    <Data>
        <Array Qty="0001" >
            <Structure Qty="0002" >
                <Structure Qty="0002" >
                    <OctetString Value="00000A006AFF" />
                    <LongUnsigned Value="0001" />
                </Structure>
                <Structure Qty="0002" >
                    <OctetString Value="00000A006AFF" />
                    <LongUnsigned Value="0002" />
                </Structure>
            </Structure>
        </Array>
    </Data>

Mngmt Get Error Register 0-0:97.97.0.255 (@257)
(143) .logical_name
PASSED
    <Data>
        <OctetString Value="0000616100FF" />
    </Data>
(144) .value
PASSED
    <Data>
        <DoubleLongUnsigned Value="00002000" />
    </Data>

Mngmt Get Alarm Register 1 0-0:97.98.0.255 (@261)
(145) .logical_name
PASSED
    <Data>
        <OctetString Value="0000616200FF" />
    </Data>
(146) .value
PASSED
    <Data>
        <DoubleLongUnsigned Value="00002000" />
    </Data>

Mngmt Get Alarm Filter 1 0-0:97.98.10.255 (@265)
(147) .logical_name
PASSED

```



```

    <Data>
      <OctetString Value="000061620AFF" />
    </Data>
(148) .value
PASSED
    <Data>
      <DoubleLongUnsigned Value="FFFF3F03" />
    </Data>

Mngmt Get Alarm Descriptor 1 0-0:97.98.20.255 (@269)
(149) .logical_name
PASSED
    <Data>
      <OctetString Value="0000616214FF" />
    </Data>
(150) .value
PASSED
    <Data>
      <DoubleLongUnsigned Value="00000000" />
    </Data>

Mngmt Get Alarm Monitor 1 0-0:16.1.0.255 (@273)
(151) .logical_name
PASSED
    <Data>
      <OctetString Value="0000100100FF" />
    </Data>
(152) .thresholds
PASSED
    <Data>
      <Array Qty="0001" >
        <DoubleLongUnsigned Value="00000000" />
      </Array>
    </Data>
(153) .monitored_value
PASSED
    <Data>
      <Structure Qty="0003" >
        <LongUnsigned Value="0001" />
        <OctetString Value="0000616214FF" />
        <Integer Value="02" />
      </Structure>
    </Data>
(154) .actions
PASSED
    <Data>
      <Array Qty="0001" >
        <Structure Qty="0002" >
          <Structure Qty="0002" >
            <OctetString Value="00000A006CFF" />
            <LongUnsigned Value="0004" />
          </Structure>
          <Structure Qty="0002" >
            <OctetString Value="00000A006CFF" />
          </Structure>
        </Structure>
      </Array>
    </Data>

```

```
        <LongUnsigned Value="0000" />
      </Structure>
    </Structure>
  </Array>
</Data>
```

Mngmt Get Alarm Register 2 0-0:97.98.1.255 (@279)
(155) .logical_name
PASSED

```
  <Data>
    <OctetString Value="0000616201FF" />
  </Data>
```

(156) .value
PASSED

```
  <Data>
    <DoubleLongUnsigned Value="0000020C" />
  </Data>
```

Mngmt Get Alarm Filter 2 0-0:97.98.11.255 (@283)
(157) .logical_name
PASSED

```
  <Data>
    <OctetString Value="000061620BFF" />
  </Data>
```

(158) .value
PASSED

```
  <Data>
    <DoubleLongUnsigned Value="F87BFF1D" />
  </Data>
```

Mngmt Get Alarm Descriptor 2 0-0:97.98.21.255 (@287)
(159) .logical_name
PASSED

```
  <Data>
    <OctetString Value="0000616215FF" />
  </Data>
```

(160) .value
PASSED

```
  <Data>
    <DoubleLongUnsigned Value="00000000" />
  </Data>
```

Mngmt Get Alarm Monitor 2 0-0:16.1.1.255 (@291)
(161) .logical_name
PASSED

```
  <Data>
    <OctetString Value="0000100101FF" />
  </Data>
```

(162) .thresholds
PASSED

```
  <Data>
    <Array Qty="0001" >
      <DoubleLongUnsigned Value="00000000" />
    </Array>
```

```
    </Data>
(163) .monitored_value
PASSED
    <Data>
      <Structure Qty="0003" >
        <LongUnsigned Value="0001" />
        <OctetString Value="0000616215FF" />
        <Integer Value="02" />
      </Structure>
    </Data>
```

```
(164) .actions
PASSED
    <Data>
      <Array Qty="0001" >
        <Structure Qty="0002" >
          <Structure Qty="0002" >
            <OctetString Value="00000A006CFF" />
            <LongUnsigned Value="0004" />
          </Structure>
          <Structure Qty="0002" >
            <OctetString Value="00000A006CFF" />
            <LongUnsigned Value="0000" />
          </Structure>
        </Structure>
      </Array>
    </Data>
```

Mngmt Get Event Object - Standard Event Log 0-0:96.11.0.255 (@297)

```
(165) .logical_name
PASSED
    <Data>
      <OctetString Value="0000600B00FF" />
    </Data>
```

```
(166) .value
PASSED
    <Data>
      <Enum Value="05" />
    </Data>
```

Mngmt Get Standard Event Log 0-0:99.98.0.255 (@301)

```
(167) .logical_name
PASSED
    <Data>
      <OctetString Value="0000636200FF" />
    </Data>
```

```
(168) .capture_objects
PASSED
    <Data>
      <Array Qty="0002" >
        <Structure Qty="0004" >
          <LongUnsigned Value="0008" />
          <OctetString Value="0000010000FF" />
          <Integer Value="02" />
          <LongUnsigned Value="0000" />
        </Structure>
      </Array>
    </Data>
```

```

        </Structure>
        <Structure Qty="0004" >
            <LongUnsigned Value="0001" />
            <OctetString Value="0000600B00FF" />
            <Integer Value="02" />
            <LongUnsigned Value="0000" />
        </Structure>
    </Array>
</Data>
(169) .capture_period
PASSED
    <Data>
        <DoubleLongUnsigned Value="00000000" />
    </Data>
(170) .sort_method
PASSED
    <Data>
        <Enum Value="01" />
    </Data>
(171) .sort_object
PASSED
    <Data>
        <Structure Qty="0004" >
            <LongUnsigned Value="0008" />
            <OctetString Value="0000010000FF" />
            <Integer Value="02" />
            <LongUnsigned Value="0000" />
        </Structure>
    </Data>
(172) .entries_in_use
PASSED
    <Data>
        <DoubleLongUnsigned Value="000000C8" />
    </Data>
(173) .profile_entries
PASSED
    <Data>
        <DoubleLongUnsigned Value="000000C8" />
    </Data>

Mngmt Get Event Object - Fraud Detection Log 0-0:96.11.1.255 (@312)
(174) .logical_name
PASSED
    <Data>
        <OctetString Value="0000600B01FF" />
    </Data>
(175) .value
PASSED
    <Data>
        <Enum Value="28" />
    </Data>

Mngmt Get Fraud Detection Log 0-0:99.98.1.255 (@316)
(176) .logical_name

```

PASSED

```
<Data>
  <OctetString Value="0000636201FF" />
</Data>
```

(177) .capture_objects

PASSED

```
<Data>
  <Array Qty="0002" >
    <Structure Qty="0004" >
      <LongUnsigned Value="0008" />
      <OctetString Value="0000010000FF" />
      <Integer Value="02" />
      <LongUnsigned Value="0000" />
    </Structure>
    <Structure Qty="0004" >
      <LongUnsigned Value="0001" />
      <OctetString Value="0000600B01FF" />
      <Integer Value="02" />
      <LongUnsigned Value="0000" />
    </Structure>
  </Array>
</Data>
```

(178) .capture_period

PASSED

```
<Data>
  <DoubleLongUnsigned Value="00000000" />
</Data>
```

(179) .sort_method

PASSED

```
<Data>
  <Enum Value="01" />
</Data>
```

(180) .sort_object

PASSED

```
<Data>
  <Structure Qty="0004" >
    <LongUnsigned Value="0008" />
    <OctetString Value="0000010000FF" />
    <Integer Value="02" />
    <LongUnsigned Value="0000" />
  </Structure>
</Data>
```

(181) .entries_in_use

PASSED

```
<Data>
  <DoubleLongUnsigned Value="0000001E" />
</Data>
```

(182) .profile_entries

PASSED

```
<Data>
  <DoubleLongUnsigned Value="0000001E" />
</Data>
```

```
(183) .logical_name
PASSED
  <Data>
    <OctetString Value="0000600B05FF" />
  </Data>
(184) .value
PASSED
  <Data>
    <Enum Value="9E" />
  </Data>

Mngmt Get Communication Log 0-0:99.98.5.255 (@331)
(185) .logical_name
PASSED
  <Data>
    <OctetString Value="0000636205FF" />
  </Data>
(186) .capture_objects
PASSED
  <Data>
    <Array Qty="0002" >
      <Structure Qty="0004" >
        <LongUnsigned Value="0008" />
        <OctetString Value="0000010000FF" />
        <Integer Value="02" />
        <LongUnsigned Value="0000" />
      </Structure>
      <Structure Qty="0004" >
        <LongUnsigned Value="0001" />
        <OctetString Value="0000600B05FF" />
        <Integer Value="02" />
        <LongUnsigned Value="0000" />
      </Structure>
    </Array>
  </Data>
(187) .capture_period
PASSED
  <Data>
    <DoubleLongUnsigned Value="00000000" />
  </Data>
(188) .sort_method
PASSED
  <Data>
    <Enum Value="01" />
  </Data>
(189) .sort_object
PASSED
  <Data>
    <Structure Qty="0004" >
      <LongUnsigned Value="0008" />
      <OctetString Value="0000010000FF" />
      <Integer Value="02" />
      <LongUnsigned Value="0000" />
    </Structure>
```

</Data>
(190) .entries_in_use
PASSED

<Data>
 <DoubleLongUnsigned Value="00000064" />
</Data>

(191) .profile_entries
PASSED

<Data>
 <DoubleLongUnsigned Value="00000064" />
</Data>

Mngmt Get Consumer Message Code - Meter Display 0-0:96.13.1.255 (@343)

(192) .logical_name
PASSED

<Data>
 <OctetString Value="0000600D01FF" />
</Data>

(193) .value
PASSED

<Data>
 <OctetString Value="" />
</Data>

Mngmt Get Consumer Message Text - Consumer Information 0-0:96.13.0.255 (@347)

(194) .logical_name
PASSED

<Data>
 <OctetString Value="0000600D00FF" />
</Data>

(195) .value
PASSED

<_Data>
 <OctetString

Value="\TXJKFBPPFUCBIQMKWEIQYXYGQYRNPUZQTABIQQLEUNPOOHDIUUTZEAKPICALRXANSFLTLSEUEJZNPUSMRZAIXRJOKJOLKNXGZCDIQKBHSDVEVCNOLCZXEGIQXKBYHYZCBUYVSXGAYMQMOFJXRRGYLIFSRQBFATOYANXDNFLOOJLXLAMQULSGMZNVYYLTCFWTZTSVPTCFAZMLUZNWBILQKWCHWDMFSBWIRNRQZQGPFWAILAJORUNIQBMSBPYAUUVFDJCTAJMQCTTWXUXJFYXYXXWKSYSAXUSCLDVHRANRIRFNWHRXOKPEBCRNCARWNJSSNWXPVQVNXKIMLQSMJVUXQPQJDHZGPRAYQXDPCSJDUXNMMIOPWRSWUWNHOMFUDGNSCLVVE SVEIVMIHWKMAKQYKMNBBZIIPIYQDVQDKQAMQDVXGFWHDFBCOMBKCYMWRGKYBNFKTYKGRAPOOASXYOESL ECIMFAULOWRMTZYKJBVOSFFDUYXQPGORGIBAXXNSAJLLMKQTZTSJKLSPVPOBDIACRCYXRHDIQHDRNSRM EUQFOLWNKXWMKLUTTGPLERWHDJNFCVRSQDNWLKXGNSKJBAELVCEQDROPLTNPHLQUTJXQEFTCWAOYMM VXPAMAMWZOHRXDQJHRKZGDTADBIXTDBBMEDYVPJWXQENQYELVDDGDCUDSCVYDJQXNRXJOGIVKTXQAUUX CWSAQQVTEYTSJFZKDQMHIYNQMKDWREXQZCWGJMPNTYAMPOGEDQILSYZZEEHJJRTALVADFMSSJUUSJL GQKBABGWMQNUETLBNCEYHLAODPLHSTCIEAVKSDXMLKVMPSEDPSCANPNROYXLNMRNYFXVGSFKRIRCYJ KAZWLYZDMOMPJAXEWYSSZYDKVMATXJJGJGXTLAXTIZWMTASIVMGWDZJCHTSAYITTIISAIQRZFRNBWECM VUOEZGJNIKTRZVEZXSALBLHERPINBQFKBWFDMOGOWYRZRIKDKOAFXJUYGWTANINHPJUKN" />
</_Data>

Mngmt Get Push action scheduler - Consumer Information 0-4:15.0.4.255 (@351)

(196) .logical_name
PASSED

<Data>
 <OctetString Value="00040F0004FF" />

```
    </Data>
(197) .executed_script
PASSED
    <Data>
      <Structure Qty="0002" >
        <OctetString Value="00000A006CFF" />
        <LongUnsigned Value="0008" />
      </Structure>
    </Data>
```

```
(198) .type
PASSED
    <Data>
      <Enum Value="05" />
    </Data>
```

```
(199) .execution_time
PASSED
    <Data>
      <Array Qty="0004" >
        <Structure Qty="0002" >
          <OctetString Value="FFFF0000" />
          <OctetString Value="FFFFFFFF" />
        </Structure>
        <Structure Qty="0002" >
          <OctetString Value="FFFF0F00" />
          <OctetString Value="FFFFFFFF" />
        </Structure>
        <Structure Qty="0002" >
          <OctetString Value="FFFF1E00" />
          <OctetString Value="FFFFFFFF" />
        </Structure>
        <Structure Qty="0002" >
          <OctetString Value="FFFF2D00" />
          <OctetString Value="FFFFFFFF" />
        </Structure>
      </Array>
    </Data>
```

```
Mngmt Get Push setup - Consumer Information 0-6:25.9.0.255 (@357)
(200) .logical_name
PASSED
    <Data>
      <OctetString Value="0006190900FF" />
    </Data>
```

```
(201) .push_object_list
PASSED
    <Data>
      <Array Qty="0000" >
      </Array>
    </Data>
```

```
(202) .send_destination_and_method
PASSED
    <Data>
      <Structure Qty="0003" >
        <Enum Value="05" />
```



```

        <OctetString Value="0001160000FF" />
        <Enum Value="00" />
    </Structure>
</Data>
(203) .communication_window
PASSED
    <Data>
        <Array Qty="0000" >
            </Array>
    </Data>
(204) .randomisation_start_interval
PASSED
    <Data>
        <LongUnsigned Value="0000" />
    </Data>
(205) .number_of_retries
PASSED
    <Data>
        <Unsigned Value="00" />
    </Data>
(206) .repetition_delay
PASSED
    <Data>
        <LongUnsigned Value="0000" />
    </Data>

Mngmt Get Security setup - Consumer Information 0-0:43.0.1.255 (@367)
(207) .logical_name
PASSED
    <Data>
        <OctetString Value="00002B0001FF" />
    </Data>
(208) .security_policy
PASSED
    <Data>
        <Enum Value="03" />
    </Data>
(209) .security_suite
PASSED
    <Data>
        <Enum Value="00" />
    </Data>
(210) .client_system_title
PASSED
    <Data>
        <OctetString Value="4D454C6300000000" />
    </Data>
(211) .server_system_title
PASSED
    <Data>
        <OctetString Value="4D454C6770B71B15" />
    </Data>

```

Mngmt Get IEC HDLC setup - Consumer Information Interface 0-1:22.0.0.255

```
(@376)
(212) .logical_name
PASSED
    <Data>
        <OctetString Value="0001160000FF" />
    </Data>
(213) .comm_speed
PASSED
    <Data>
        <Enum Value="05" />
    </Data>
(214) .window_size_transmit
PASSED
    <Data>
        <Unsigned Value="01" />
    </Data>
(215) .window_size_receive
PASSED
    <Data>
        <Unsigned Value="01" />
    </Data>
(216) .max_info_field_lenght_transmit
PASSED
    <Data>
        <LongUnsigned Value="00F2" />
    </Data>
(217) .max_info_field_lenght_receive
PASSED
    <Data>
        <LongUnsigned Value="00F2" />
    </Data>
(218) .inter_octet_time_out
PASSED
    <Data>
        <LongUnsigned Value="0019" />
    </Data>
(219) .inactivity_time_out
PASSED
    <Data>
        <LongUnsigned Value="0078" />
    </Data>
(220) .device_address
PASSED
    <Data>
        <LongUnsigned Value="0015" />
    </Data>

Mngmt Get Image transfer 0-0:44.0.0.255 (@388)
(221) .logical_name
PASSED
    <Data>
        <OctetString Value="00002C0000FF" />
    </Data>
(222) .image_block_size
```

PASSED

```
<Data>
  <DoubleLongUnsigned Value="000000C0" />
</Data>
```

(223) .image_transferred_block_status

PASSED

```
<Data>
  <BitString Value="1111111111111111" />
</Data>
```

(224) .image_first_not_transferred_block_number

PASSED

```
<Data>
  <DoubleLongUnsigned Value="00000010" />
</Data>
```

(225) .image_transfer_enabled

PASSED

```
<Data>
  <Boolean Value="01" />
</Data>
```

(226) .image_transfer status

PASSED

```
<Data>
  <Enum Value="06" />
</Data>
```

(227) .image_to_activate_info

PASSED

```
<Data>
  <Array Qty="0001" >
    <Structure Qty="0003" >
      <DoubleLongUnsigned Value="000000C0" />
      <OctetString
Value="\6.51.931.[(5.4.[(5.5.2)_(1.0.0)])_(7.14.0)].98231x/U" />
      <OctetString
Value="E1C9987D365FBEFFB78CEB34E024FA956CDA49A034AA932575BD78FE76BC369E" />
    </Structure>
  </Array>
</Data>
```

Mngmt Get Image transfer activation scheduler 0-0:15.0.2.255 (@401)

(228) .logical_name

PASSED

```
<Data>
  <OctetString Value="00000F002FF" />
</Data>
```

(229) .executed_script

PASSED

```
<Data>
  <Structure Qty="0002" >
    <OctetString Value="00000A006BFF" />
    <LongUnsigned Value="0001" />
  </Structure>
</Data>
```

(230) .type

PASSED

```
    <Data>
      <Enum Value="01" />
    </Data>
(231) .execution_time
PASSED
```

```
    <Data>
      <Array Qty="0001" >
        <Structure Qty="0002" >
          <OctetString Value="07100000" />
          <OctetString Value="07E60C1402" />
        </Structure>
      </Array>
    </Data>
```

```
Mngmt Get Predefined Scripts - Image activation 0-0:10.0.107.255 (@407)
(232) .logical_name
PASSED
```

```
    <Data>
      <OctetString Value="00000A006BFF" />
    </Data>
```

```
(233) .scripts
INAPPLICABLE
```

Optional access right not available

```
Mngmt Get Active firmware identifier 1-0:0.2.0.255 (@412)
(234) .logical_name
PASSED
```

```
    <Data>
      <OctetString Value="0100000200FF" />
    </Data>
```

```
(235) .value
PASSED
```

```
    <Data>
      <OctetString Value="\2.0.02.[803F5E00].000000" />
    </Data>
```

```
Mngmt Get Active firmware signature 1-0:0.2.8.255 (@416)
(236) .logical_name
PASSED
```

```
    <Data>
      <OctetString Value="0100000208FF" />
    </Data>
```

```
(237) .value
PASSED
```

```
    <Data>
      <OctetString
Value="27CE447104FF1B3FC6E313BCD3235264AA7494749A06013A5848709910A8F513" />
    </Data>
```

```
Mngmt Get Active firmware identifier 1 1-1:0.2.0.255 (@420)
(238) .logical_name
PASSED
```

```
    <Data>
      <OctetString Value="0101000200FF" />
```

```
    </Data>
(239) .value
PASSED
    <Data>
      <OctetString
Value="\6.51.931.[(5.4.[(5.5.2)_(1.0.0)])_(7.14.0)].000000" />
      </Data>

Mngmt Get Active firmware signature 1 1-1:0.2.8.255 (@424)
(240) .logical_name
PASSED
    <Data>
      <OctetString Value="0101000208FF" />
    </Data>
(241) .value
PASSED
    <Data>
      <OctetString
Value="DA13DA290EFE5B539A0FCD26505DDA35311FCF14C675BE42DEF3830B6A017508" />
      </Data>

Mngmt Get Active firmware identifier 2 1-2:0.2.0.255 (@428)
(242) .logical_name
PASSED
    <Data>
      <OctetString Value="0102000200FF" />
    </Data>
(243) .value
PASSED
    <Data>
      <OctetString Value="\5.0.16.0.[5.0.13.0].982249/C" />
    </Data>

Mngmt Get Active firmware signature 2 1-2:0.2.8.255 (@432)
(244) .logical_name
PASSED
    <Data>
      <OctetString Value="0102000208FF" />
    </Data>
(245) .value
PASSED
    <Data>
      <OctetString
Value="E135D85E4ABBFBC8CA975E84A0320D3FF398FAE9ED8B2FF7FD703F654B023E53" />
      </Data>

Mngmt Get Active energy import (+A) 1-0:1.8.0.255 (@437)
(246) .logical_name
PASSED
    <Data>
      <OctetString Value="0100010800FF" />
    </Data>
(247) .value
PASSED
```

```
    <Data>
      <DoubleLongUnsigned Value="00000017" />
    </Data>
(248) .scaler_unit
PASSED
```

```
    <Data>
      <Structure Qty="0002" >
        <Integer Value="00" />
        <Enum Value="1E" />
      </Structure>
    </Data>
```

```
Mngmt Get Active energy export (-A) 1-0:2.8.0.255 (@443)
(249) .logical_name
PASSED
```

```
    <Data>
      <OctetString Value="0100020800FF" />
    </Data>
```

```
(250) .value
PASSED
```

```
    <Data>
      <DoubleLongUnsigned Value="00000000" />
    </Data>
```

```
(251) .scaler_unit
PASSED
```

```
    <Data>
      <Structure Qty="0002" >
        <Integer Value="00" />
        <Enum Value="1E" />
      </Structure>
    </Data>
```

```
Mngmt Get Active energy (|+A|+|-A|) Combined total 1-0:15.8.0.255 (@449)
(252) .logical_name
PASSED
```

```
    <Data>
      <OctetString Value="01000F0800FF" />
    </Data>
```

```
(253) .value
PASSED
```

```
    <Data>
      <DoubleLongUnsigned Value="00000018" />
    </Data>
```

```
(254) .scaler_unit
PASSED
```

```
    <Data>
      <Structure Qty="0002" >
        <Integer Value="00" />
        <Enum Value="1E" />
      </Structure>
    </Data>
```

```
Mngmt Get Active energy (|+A|-|-A|) Combined total 1-0:16.8.0.255 (@455)
(255) .logical_name
```

PASSED

```
<Data>
  <OctetString Value="0100100800FF" />
</Data>
```

(256) .value

PASSED

```
<Data>
  <DoubleLong Value="00000017" />
</Data>
```

(257) .scaler_unit

PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="00" />
    <Enum Value="1E" />
  </Structure>
</Data>
```

Mngmt Get Reactive energy QI (+Ri) 1-0:5.8.0.255 (@461)

(258) .logical_name

PASSED

```
<Data>
  <OctetString Value="0100050800FF" />
</Data>
```

(259) .value

PASSED

```
<Data>
  <DoubleLongUnsigned Value="00000028" />
</Data>
```

(260) .scaler_unit

PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="00" />
    <Enum Value="20" />
  </Structure>
</Data>
```

Mngmt Get Reactive energy QII (+Rc) 1-0:6.8.0.255 (@467)

(261) .logical_name

PASSED

```
<Data>
  <OctetString Value="0100060800FF" />
</Data>
```

(262) .value

PASSED

```
<Data>
  <DoubleLongUnsigned Value="00000000" />
</Data>
```

(263) .scaler_unit

PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="00" />
  </Structure>
</Data>
```

```

        <Enum Value="20" />
    </Structure>
</Data>

Mngmt Get Reactive energy QIII (-Ri) 1-0:7.8.0.255 (@473)
(264) .logical_name
PASSED
    <Data>
        <OctetString Value="0100070800FF" />
    </Data>
(265) .value
PASSED
    <Data>
        <DoubleLongUnsigned Value="00000000" />
    </Data>
(266) .scaler_unit
PASSED
    <Data>
        <Structure Qty="0002" >
            <Integer Value="00" />
            <Enum Value="20" />
        </Structure>
    </Data>

Mngmt Get Reactive energy QIV (-Rc) 1-0:8.8.0.255 (@479)
(267) .logical_name
PASSED
    <Data>
        <OctetString Value="0100080800FF" />
    </Data>
(268) .value
PASSED
    <Data>
        <DoubleLongUnsigned Value="00000000" />
    </Data>
(269) .scaler_unit
PASSED
    <Data>
        <Structure Qty="0002" >
            <Integer Value="00" />
            <Enum Value="20" />
        </Structure>
    </Data>

Mngmt Get Reactive energy import (+R) (QI+QII) 1-0:3.8.0.255 (@485)
(270) .logical_name
PASSED
    <Data>
        <OctetString Value="0100030800FF" />
    </Data>
(271) .value
PASSED
    <Data>
        <DoubleLongUnsigned Value="00000028" />
    </Data>

```



```

    </Data>
(272) .scaler_unit
PASSED
    <Data>
      <Structure Qty="0002" >
        <Integer Value="00" />
        <Enum Value="20" />
      </Structure>
    </Data>

Mngmt Get Reactive energy export (-R) (QIII+QIV) 1-0:4.8.0.255 (@491)
(273) .logical_name
PASSED
    <Data>
      <OctetString Value="0100040800FF" />
    </Data>
(274) .value
PASSED
    <Data>
      <DoubleLongUnsigned Value="00000000" />
    </Data>
(275) .scaler_unit
PASSED
    <Data>
      <Structure Qty="0002" >
        <Integer Value="00" />
        <Enum Value="20" />
      </Structure>
    </Data>

Mngmt Get Apparent energy import (+VA) (QI+QIV) 1-0:9.8.0.255 (@497)
(276) .logical_name
PASSED
    <Data>
      <OctetString Value="0100090800FF" />
    </Data>
(277) .value
PASSED
    <Data>
      <DoubleLongUnsigned Value="00000032" />
    </Data>
(278) .scaler_unit
PASSED
    <Data>
      <Structure Qty="0002" >
        <Integer Value="00" />
        <Enum Value="1F" />
      </Structure>
    </Data>

Mngmt Get Apparent energy export (-VA) (QII+QIII) 1-0:10.8.0.255 (@503)
(279) .logical_name
PASSED
    <Data>

```

```

        <OctetString Value="01000A0800FF" />
    </Data>
(280) .value
PASSED
    <Data>
        <DoubleLongUnsigned Value="00000000" />
    </Data>
(281) .scaler_unit
PASSED
    <Data>
        <Structure Qty="0002" >
            <Integer Value="00" />
            <Enum Value="1F" />
        </Structure>
    </Data>

Mngmt Get Active energy import (+A) rate 1 1-0:1.8.1.255 (@510)
(282) .logical_name
PASSED
    <Data>
        <OctetString Value="0100010801FF" />
    </Data>
(283) .value
PASSED
    <Data>
        <DoubleLongUnsigned Value="00000017" />
    </Data>
(284) .scaler_unit
PASSED
    <Data>
        <Structure Qty="0002" >
            <Integer Value="00" />
            <Enum Value="1E" />
        </Structure>
    </Data>

Mngmt Get Active energy import (+A) rate 2 1-0:1.8.2.255 (@516)
(285) .logical_name
PASSED
    <Data>
        <OctetString Value="0100010802FF" />
    </Data>
(286) .value
PASSED
    <Data>
        <DoubleLongUnsigned Value="00000000" />
    </Data>
(287) .scaler_unit
PASSED
    <Data>
        <Structure Qty="0002" >
            <Integer Value="00" />
            <Enum Value="1E" />
        </Structure>

```

```
    </Data>

Mngmt Get Active energy import (+A) rate 3 1-0:1.8.3.255 (@522)
(288) .logical_name
PASSED
    <Data>
        <OctetString Value="0100010803FF" />
    </Data>
(289) .value
PASSED
    <Data>
        <DoubleLongUnsigned Value="00000000" />
    </Data>
(290) .scaler_unit
PASSED
    <Data>
        <Structure Qty="0002" >
            <Integer Value="00" />
            <Enum Value="1E" />
        </Structure>
    </Data>

Mngmt Get Active energy import (+A) rate 4 1-0:1.8.4.255 (@528)
(291) .logical_name
PASSED
    <Data>
        <OctetString Value="0100010804FF" />
    </Data>
(292) .value
PASSED
    <Data>
        <DoubleLongUnsigned Value="00000000" />
    </Data>
(293) .scaler_unit
PASSED
    <Data>
        <Structure Qty="0002" >
            <Integer Value="00" />
            <Enum Value="1E" />
        </Structure>
    </Data>

Mngmt Get Active energy export (-A) rate 1 1-0:2.8.1.255 (@534)
(294) .logical_name
PASSED
    <Data>
        <OctetString Value="0100020801FF" />
    </Data>
(295) .value
PASSED
    <Data>
        <DoubleLongUnsigned Value="00000000" />
    </Data>
(296) .scaler_unit
```

PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="00" />
    <Enum Value="1E" />
  </Structure>
</Data>
```

Mngmt Get Active energy export (-A) rate 2 1-0:2.8.2.255 (@540)
(297) .logical_name

PASSED

```
<Data>
  <OctetString Value="0100020802FF" />
</Data>
```

(298) .value

PASSED

```
<Data>
  <DoubleLongUnsigned Value="00000000" />
</Data>
```

(299) .scaler_unit

PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="00" />
    <Enum Value="1E" />
  </Structure>
</Data>
```

Mngmt Get Active energy export (-A) rate 3 1-0:2.8.3.255 (@546)
(300) .logical_name

PASSED

```
<Data>
  <OctetString Value="0100020803FF" />
</Data>
```

(301) .value

PASSED

```
<Data>
  <DoubleLongUnsigned Value="00000000" />
</Data>
```

(302) .scaler_unit

PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="00" />
    <Enum Value="1E" />
  </Structure>
</Data>
```

Mngmt Get Active energy export (-A) rate 4 1-0:2.8.4.255 (@552)
(303) .logical_name

PASSED

```
<Data>
  <OctetString Value="0100020804FF" />
</Data>
```

```

(304) .value
PASSED
  <Data>
    <DoubleLongUnsigned Value="00000000" />
  </Data>
(305) .scaler_unit
PASSED
  <Data>
    <Structure Qty="0002" >
      <Integer Value="00" />
      <Enum Value="1E" />
    </Structure>
  </Data>

Mngmt Get Reactive energy (+R) rate 1 1-0:3.8.1.255 (@558)
(306) .logical_name
PASSED
  <Data>
    <OctetString Value="0100030801FF" />
  </Data>
(307) .value
PASSED
  <Data>
    <DoubleLongUnsigned Value="00000028" />
  </Data>
(308) .scaler_unit
PASSED
  <Data>
    <Structure Qty="0002" >
      <Integer Value="00" />
      <Enum Value="20" />
    </Structure>
  </Data>

Mngmt Get Reactive energy (+R) rate 2 1-0:3.8.2.255 (@564)
(309) .logical_name
PASSED
  <Data>
    <OctetString Value="0100030802FF" />
  </Data>
(310) .value
PASSED
  <Data>
    <DoubleLongUnsigned Value="00000000" />
  </Data>
(311) .scaler_unit
PASSED
  <Data>
    <Structure Qty="0002" >
      <Integer Value="00" />
      <Enum Value="20" />
    </Structure>
  </Data>

```

Mngmt Get Reactive energy (+R) rate 3 1-0:3.8.3.255 (@570)
(312) .logical_name

PASSED

```
<Data>
  <OctetString Value="0100030803FF" />
</Data>
```

(313) .value

PASSED

```
<Data>
  <DoubleLongUnsigned Value="00000000" />
</Data>
```

(314) .scaler_unit

PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="00" />
    <Enum Value="20" />
  </Structure>
</Data>
```

Mngmt Get Reactive energy (+R) rate 4 1-0:3.8.4.255 (@576)

(315) .logical_name

PASSED

```
<Data>
  <OctetString Value="0100030804FF" />
</Data>
```

(316) .value

PASSED

```
<Data>
  <DoubleLongUnsigned Value="00000000" />
</Data>
```

(317) .scaler_unit

PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="00" />
    <Enum Value="20" />
  </Structure>
</Data>
```

Mngmt Get Reactive energy (-R) rate 1 1-0:4.8.1.255 (@582)

(318) .logical_name

PASSED

```
<Data>
  <OctetString Value="0100040801FF" />
</Data>
```

(319) .value

PASSED

```
<Data>
  <DoubleLongUnsigned Value="00000000" />
</Data>
```

(320) .scaler_unit

PASSED

```
<Data>
```

```
    <Structure Qty="0002" >
      <Integer Value="00" />
      <Enum Value="20" />
    </Structure>
  </Data>
```

Mngmt Get Reactive energy (-R) rate 2 1-0:4.8.2.255 (@588)
(321) .logical_name
PASSED

```
  <Data>
    <OctetString Value="0100040802FF" />
  </Data>
```

(322) .value
PASSED

```
  <Data>
    <DoubleLongUnsigned Value="00000000" />
  </Data>
```

(323) .scaler_unit
PASSED

```
  <Data>
    <Structure Qty="0002" >
      <Integer Value="00" />
      <Enum Value="20" />
    </Structure>
  </Data>
```

Mngmt Get Reactive energy (-R) rate 3 1-0:4.8.3.255 (@594)
(324) .logical_name
PASSED

```
  <Data>
    <OctetString Value="0100040803FF" />
  </Data>
```

(325) .value
PASSED

```
  <Data>
    <DoubleLongUnsigned Value="00000000" />
  </Data>
```

(326) .scaler_unit
PASSED

```
  <Data>
    <Structure Qty="0002" >
      <Integer Value="00" />
      <Enum Value="20" />
    </Structure>
  </Data>
```

Mngmt Get Reactive energy (-R) rate 4 1-0:4.8.4.255 (@600)
(327) .logical_name
PASSED

```
  <Data>
    <OctetString Value="0100040804FF" />
  </Data>
```

(328) .value
PASSED

```

    <Data>
      <DoubleLongUnsigned Value="00000000" />
    </Data>
(329) .scaler_unit
PASSED
    <Data>
      <Structure Qty="0002" >
        <Integer Value="00" />
        <Enum Value="20" />
      </Structure>
    </Data>

Mngmt Get Reactive energy (QI) rate 1 1-0:5.8.1.255 (@606)
(330) .logical_name
PASSED
    <Data>
      <OctetString Value="0100050801FF" />
    </Data>
(331) .value
PASSED
    <Data>
      <DoubleLongUnsigned Value="00000028" />
    </Data>
(332) .scaler_unit
PASSED
    <Data>
      <Structure Qty="0002" >
        <Integer Value="00" />
        <Enum Value="20" />
      </Structure>
    </Data>

Mngmt Get Reactive energy (QI) rate 2 1-0:5.8.2.255 (@612)
(333) .logical_name
PASSED
    <Data>
      <OctetString Value="0100050802FF" />
    </Data>
(334) .value
PASSED
    <Data>
      <DoubleLongUnsigned Value="00000000" />
    </Data>
(335) .scaler_unit
PASSED
    <Data>
      <Structure Qty="0002" >
        <Integer Value="00" />
        <Enum Value="20" />
      </Structure>
    </Data>

Mngmt Get Reactive energy (QI) rate 3 1-0:5.8.3.255 (@618)
(336) .logical_name

```


PASSED

```
<Data>
  <OctetString Value="0100050803FF" />
</Data>
```

(337) .value

PASSED

```
<Data>
  <DoubleLongUnsigned Value="00000000" />
</Data>
```

(338) .scaler_unit

PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="00" />
    <Enum Value="20" />
  </Structure>
</Data>
```

Mngmt Get Reactive energy (QI) rate 4 1-0:5.8.4.255 (@624)

(339) .logical_name

PASSED

```
<Data>
  <OctetString Value="0100050804FF" />
</Data>
```

(340) .value

PASSED

```
<Data>
  <DoubleLongUnsigned Value="00000000" />
</Data>
```

(341) .scaler_unit

PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="00" />
    <Enum Value="20" />
  </Structure>
</Data>
```

Mngmt Get Reactive energy (QII) rate 1 1-0:6.8.1.255 (@630)

(342) .logical_name

PASSED

```
<Data>
  <OctetString Value="0100060801FF" />
</Data>
```

(343) .value

PASSED

```
<Data>
  <DoubleLongUnsigned Value="00000000" />
</Data>
```

(344) .scaler_unit

PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="00" />
  </Structure>
</Data>
```

```
        <Enum Value="20" />
    </Structure>
</Data>
```

Mngmt Get Reactive energy (QII) rate 2 1-0:6.8.2.255 (@636)
(345) .logical_name

PASSED

```
    <Data>
        <OctetString Value="0100060802FF" />
    </Data>
```

(346) .value

PASSED

```
    <Data>
        <DoubleLongUnsigned Value="00000000" />
    </Data>
```

(347) .scaler_unit

PASSED

```
    <Data>
        <Structure Qty="0002" >
            <Integer Value="00" />
            <Enum Value="20" />
        </Structure>
    </Data>
```

Mngmt Get Reactive energy (QII) rate 3 1-0:6.8.3.255 (@642)
(348) .logical_name

PASSED

```
    <Data>
        <OctetString Value="0100060803FF" />
    </Data>
```

(349) .value

PASSED

```
    <Data>
        <DoubleLongUnsigned Value="00000000" />
    </Data>
```

(350) .scaler_unit

PASSED

```
    <Data>
        <Structure Qty="0002" >
            <Integer Value="00" />
            <Enum Value="20" />
        </Structure>
    </Data>
```

Mngmt Get Reactive energy (QII) rate 4 1-0:6.8.4.255 (@648)
(351) .logical_name

PASSED

```
    <Data>
        <OctetString Value="0100060804FF" />
    </Data>
```

(352) .value

PASSED

```
    <Data>
        <DoubleLongUnsigned Value="00000000" />
```

```
    </Data>
(353) .scaler_unit
PASSED
    <Data>
      <Structure Qty="0002" >
        <Integer Value="00" />
        <Enum Value="20" />
      </Structure>
    </Data>

Mngmt Get Reactive energy (QIII) rate 1 1-0:7.8.1.255 (@654)
(354) .logical_name
PASSED
    <Data>
      <OctetString Value="0100070801FF" />
    </Data>
(355) .value
PASSED
    <Data>
      <DoubleLongUnsigned Value="00000000" />
    </Data>
(356) .scaler_unit
PASSED
    <Data>
      <Structure Qty="0002" >
        <Integer Value="00" />
        <Enum Value="20" />
      </Structure>
    </Data>

Mngmt Get Reactive energy (QIII) rate 2 1-0:7.8.2.255 (@660)
(357) .logical_name
PASSED
    <Data>
      <OctetString Value="0100070802FF" />
    </Data>
(358) .value
PASSED
    <Data>
      <DoubleLongUnsigned Value="00000000" />
    </Data>
(359) .scaler_unit
PASSED
    <Data>
      <Structure Qty="0002" >
        <Integer Value="00" />
        <Enum Value="20" />
      </Structure>
    </Data>

Mngmt Get Reactive energy (QIII) rate 3 1-0:7.8.3.255 (@666)
(360) .logical_name
PASSED
    <Data>
```

```

        <OctetString Value="0100070803FF" />
    </Data>
(361) .value
PASSED
    <Data>
        <DoubleLongUnsigned Value="00000000" />
    </Data>
(362) .scaler_unit
PASSED
    <Data>
        <Structure Qty="0002" >
            <Integer Value="00" />
            <Enum Value="20" />
        </Structure>
    </Data>

Mngmt Get Reactive energy (QIII) rate 4 1-0:7.8.4.255 (@672)
(363) .logical_name
PASSED
    <Data>
        <OctetString Value="0100070804FF" />
    </Data>
(364) .value
PASSED
    <Data>
        <DoubleLongUnsigned Value="00000000" />
    </Data>
(365) .scaler_unit
PASSED
    <Data>
        <Structure Qty="0002" >
            <Integer Value="00" />
            <Enum Value="20" />
        </Structure>
    </Data>

Mngmt Get Reactive energy (QIV) rate 1 1-0:8.8.1.255 (@678)
(366) .logical_name
PASSED
    <Data>
        <OctetString Value="0100080801FF" />
    </Data>
(367) .value
PASSED
    <Data>
        <DoubleLongUnsigned Value="00000000" />
    </Data>
(368) .scaler_unit
PASSED
    <Data>
        <Structure Qty="0002" >
            <Integer Value="00" />
            <Enum Value="20" />
        </Structure>

```

```

    </Data>

Mngmt Get Reactive energy (QIV) rate 2 1-0:8.8.2.255 (@684)
(369) .logical_name
PASSED
    <Data>
        <OctetString Value="0100080802FF" />
    </Data>
(370) .value
PASSED
    <Data>
        <DoubleLongUnsigned Value="00000000" />
    </Data>
(371) .scaler_unit
PASSED
    <Data>
        <Structure Qty="0002" >
            <Integer Value="00" />
            <Enum Value="20" />
        </Structure>
    </Data>

Mngmt Get Reactive energy (QIV) rate 3 1-0:8.8.3.255 (@690)
(372) .logical_name
PASSED
    <Data>
        <OctetString Value="0100080803FF" />
    </Data>
(373) .value
PASSED
    <Data>
        <DoubleLongUnsigned Value="00000000" />
    </Data>
(374) .scaler_unit
PASSED
    <Data>
        <Structure Qty="0002" >
            <Integer Value="00" />
            <Enum Value="20" />
        </Structure>
    </Data>

Mngmt Get Reactive energy (QIV) rate 4 1-0:8.8.4.255 (@696)
(375) .logical_name
PASSED
    <Data>
        <OctetString Value="0100080804FF" />
    </Data>
(376) .value
PASSED
    <Data>
        <DoubleLongUnsigned Value="00000000" />
    </Data>
(377) .scaler_unit

```

PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="00" />
    <Enum Value="20" />
  </Structure>
</Data>
```

Mngmt Get Apparent energy import (+VA) rate 1 1-0:9.8.1.255 (@702)
(378) .logical_name

PASSED

```
<Data>
  <OctetString Value="0100090801FF" />
</Data>
```

(379) .value

PASSED

```
<Data>
  <DoubleLongUnsigned Value="00000031" />
</Data>
```

(380) .scaler_unit

PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="00" />
    <Enum Value="1F" />
  </Structure>
</Data>
```

Mngmt Get Apparent energy import (+VA) rate 2 1-0:9.8.2.255 (@708)
(381) .logical_name

PASSED

```
<Data>
  <OctetString Value="0100090802FF" />
</Data>
```

(382) .value

PASSED

```
<Data>
  <DoubleLongUnsigned Value="00000000" />
</Data>
```

(383) .scaler_unit

PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="00" />
    <Enum Value="1F" />
  </Structure>
</Data>
```

Mngmt Get Apparent energy import (+VA) rate 3 1-0:9.8.3.255 (@714)
(384) .logical_name

PASSED

```
<Data>
  <OctetString Value="0100090803FF" />
</Data>
```

(385) .value
PASSED

```
<Data>  
  <DoubleLongUnsigned Value="00000000" />  
</Data>
```

(386) .scaler_unit
PASSED

```
<Data>  
  <Structure Qty="0002" >  
    <Integer Value="00" />  
    <Enum Value="1F" />  
  </Structure>  
</Data>
```

Mngmt Get Apparent energy import (+VA) rate 4 1-0:9.8.4.255 (@720)

(387) .logical_name
PASSED

```
<Data>  
  <OctetString Value="0100090804FF" />  
</Data>
```

(388) .value
PASSED

```
<Data>  
  <DoubleLongUnsigned Value="00000000" />  
</Data>
```

(389) .scaler_unit
PASSED

```
<Data>  
  <Structure Qty="0002" >  
    <Integer Value="00" />  
    <Enum Value="1F" />  
  </Structure>  
</Data>
```

Mngmt Get Apparent energy export (-VA) rate 1 1-0:10.8.1.255 (@726)

(390) .logical_name
PASSED

```
<Data>  
  <OctetString Value="01000A0801FF" />  
</Data>
```

(391) .value
PASSED

```
<Data>  
  <DoubleLongUnsigned Value="00000000" />  
</Data>
```

(392) .scaler_unit
PASSED

```
<Data>  
  <Structure Qty="0002" >  
    <Integer Value="00" />  
    <Enum Value="1F" />  
  </Structure>  
</Data>
```

Mngmt Get Apparent energy export (-VA) rate 2 1-0:10.8.2.255 (@732)
(393) .logical_name

PASSED

```
<Data>
  <OctetString Value="01000A0802FF" />
</Data>
```

(394) .value

PASSED

```
<Data>
  <DoubleLongUnsigned Value="00000000" />
</Data>
```

(395) .scaler_unit

PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="00" />
    <Enum Value="1F" />
  </Structure>
</Data>
```

Mngmt Get Apparent energy export (-VA) rate 3 1-0:10.8.3.255 (@738)

(396) .logical_name

PASSED

```
<Data>
  <OctetString Value="01000A0803FF" />
</Data>
```

(397) .value

PASSED

```
<Data>
  <DoubleLongUnsigned Value="00000000" />
</Data>
```

(398) .scaler_unit

PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="00" />
    <Enum Value="1F" />
  </Structure>
</Data>
```

Mngmt Get Apparent energy export (-VA) rate 4 1-0:10.8.4.255 (@744)

(399) .logical_name

PASSED

```
<Data>
  <OctetString Value="01000A0804FF" />
</Data>
```

(400) .value

PASSED

```
<Data>
  <DoubleLongUnsigned Value="00000000" />
</Data>
```

(401) .scaler_unit

PASSED

```
<Data>
```



```
    <Structure Qty="0002" >
      <Integer Value="00" />
      <Enum Value="1F" />
    </Structure>
  </Data>
```

Mngmt Get Active energy Combined total (|+A|+|-A|) rate 1 1-0:15.8.1.255 (@750)

(402) .logical_name
PASSED

```
  <Data>
    <OctetString Value="01000F0801FF" />
  </Data>
```

(403) .value
PASSED

```
  <Data>
    <DoubleLongUnsigned Value="00000018" />
  </Data>
```

(404) .scaler_unit
PASSED

```
  <Data>
    <Structure Qty="0002" >
      <Integer Value="00" />
      <Enum Value="1E" />
    </Structure>
  </Data>
```

Mngmt Get Active energy Combined total (|+A|+|-A|) rate 2 1-0:15.8.2.255 (@756)

(405) .logical_name
PASSED

```
  <Data>
    <OctetString Value="01000F0802FF" />
  </Data>
```

(406) .value
PASSED

```
  <Data>
    <DoubleLongUnsigned Value="00000000" />
  </Data>
```

(407) .scaler_unit
PASSED

```
  <Data>
    <Structure Qty="0002" >
      <Integer Value="00" />
      <Enum Value="1E" />
    </Structure>
  </Data>
```

Mngmt Get Active energy Combined total (|+A|+|-A|) rate 3 1-0:15.8.3.255 (@762)

(408) .logical_name
PASSED

```
  <Data>
    <OctetString Value="01000F0803FF" />
```

```

    </Data>
(409) .value
PASSED
    <Data>
      <DoubleLongUnsigned Value="00000000" />
    </Data>
(410) .scaler_unit
PASSED
    <Data>
      <Structure Qty="0002" >
        <Integer Value="00" />
        <Enum Value="1E" />
      </Structure>
    </Data>

Mngmt Get Active energy Combined total (|+A|+|-A|) rate 4 1-0:15.8.4.255
(@768)
(411) .logical_name
PASSED
    <Data>
      <OctetString Value="01000F0804FF" />
    </Data>
(412) .value
PASSED
    <Data>
      <DoubleLongUnsigned Value="00000000" />
    </Data>
(413) .scaler_unit
PASSED
    <Data>
      <Structure Qty="0002" >
        <Integer Value="00" />
        <Enum Value="1E" />
      </Structure>
    </Data>

Mngmt Get Demand Register 1 - Active energy import (+A) 1-0:1.4.0.255 (@775)
(414) .logical_name
PASSED
    <Data>
      <OctetString Value="0100010400FF" />
    </Data>
(415) .current_average_value
PASSED
    <Data>
      <DoubleLongUnsigned Value="00000000" />
    </Data>
(416) .last_average_value
PASSED
    <Data>
      <DoubleLongUnsigned Value="00000000" />
    </Data>
(417) .scaler_unit
PASSED

```

```

    <Data>
      <Structure Qty="0002" >
        <Integer Value="00" />
        <Enum Value="1B" />
      </Structure>
    </Data>
(418) .status
PASSED
    <Data>
      <Unsigned Value="00" />
    </Data>
(419) .capture_time
PASSED
    <Data>
      <OctetString Value="07E60C15030E2D0000FFC400" />
    </Data>
(420) .start_time_current
PASSED
    <Data>
      <OctetString Value="07E60C15030E2D0000FFC400" />
    </Data>
(421) .period
PASSED
    <Data>
      <DoubleLongUnsigned Value="00000384" />
    </Data>
(422) .number_of_periods
PASSED
    <Data>
      <LongUnsigned Value="0001" />
    </Data>

Mngmt Get Demand Register 2 - Active energy export (-A) 1-0:2.4.0.255 (@788)
(423) .logical_name
PASSED
    <Data>
      <OctetString Value="0100020400FF" />
    </Data>
(424) .current_average_value
PASSED
    <Data>
      <DoubleLongUnsigned Value="00000000" />
    </Data>
(425) .last_average_value
PASSED
    <Data>
      <DoubleLongUnsigned Value="00000000" />
    </Data>
(426) .scaler_unit
PASSED
    <Data>
      <Structure Qty="0002" >
        <Integer Value="00" />
        <Enum Value="1B" />
      </Structure>
    </Data>

```

```

        </Structure>
    </Data>
(427) .status
PASSED
    <Data>
        <Unsigned Value="00" />
    </Data>
(428) .capture_time
PASSED
    <Data>
        <OctetString Value="07E60C15030E2D0000FFC400" />
    </Data>
(429) .start_time_current
PASSED
    <Data>
        <OctetString Value="07E60C15030E2D0000FFC400" />
    </Data>
(430) .period
PASSED
    <Data>
        <DoubleLongUnsigned Value="00000384" />
    </Data>
(431) .number_of_periods
PASSED
    <Data>
        <LongUnsigned Value="0001" />
    </Data>

```

Mngmt Get Demand Register 3 - Reactive energy import (+R) 1-0:3.4.0.255
(@801)

```

(432) .logical_name
PASSED
    <Data>
        <OctetString Value="0100030400FF" />
    </Data>
(433) .current_average_value
PASSED
    <Data>
        <DoubleLongUnsigned Value="00000000" />
    </Data>
(434) .last_average_value
PASSED
    <Data>
        <DoubleLongUnsigned Value="00000000" />
    </Data>
(435) .scaler_unit
PASSED
    <Data>
        <Structure Qty="0002" >
            <Integer Value="00" />
            <Enum Value="1D" />
        </Structure>
    </Data>
(436) .status

```

PASSED

```
<Data>
  <Unsigned Value="00" />
</Data>
```

(437) .capture_time

PASSED

```
<Data>
  <OctetString Value="07E60C15030E2D0000FFC400" />
</Data>
```

(438) .start_time_current

PASSED

```
<Data>
  <OctetString Value="07E60C15030E2D0000FFC400" />
</Data>
```

(439) .period

PASSED

```
<Data>
  <DoubleLongUnsigned Value="00000384" />
</Data>
```

(440) .number_of_periods

PASSED

```
<Data>
  <LongUnsigned Value="0001" />
</Data>
```

Mngmt Get Demand Register 4 - Reactive energy export (-R) 1-0:4.4.0.255

(@814)

(441) .logical_name

PASSED

```
<Data>
  <OctetString Value="0100040400FF" />
</Data>
```

(442) .current_average_value

PASSED

```
<Data>
  <DoubleLongUnsigned Value="00000000" />
</Data>
```

(443) .last_average_value

PASSED

```
<Data>
  <DoubleLongUnsigned Value="00000000" />
</Data>
```

(444) .scaler_unit

PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="00" />
    <Enum Value="1D" />
  </Structure>
</Data>
```

(445) .status

PASSED

```
<Data>
  <Unsigned Value="00" />
```

```
    </Data>
(446) .capture_time
PASSED
    <Data>
      <OctetString Value="07E60C15030E2D0000FFC400" />
    </Data>
(447) .start_time_current
PASSED
    <Data>
      <OctetString Value="07E60C15030E2D0000FFC400" />
    </Data>
(448) .period
PASSED
    <Data>
      <DoubleLongUnsigned Value="00000384" />
    </Data>
(449) .number_of_periods
PASSED
    <Data>
      <LongUnsigned Value="0001" />
    </Data>
```

Mngmt Get Demand Register 5 - Apparent energy import (+VA) 1-0:9.4.0.255 (@827)

```
(450) .logical_name
PASSED
    <Data>
      <OctetString Value="0100090400FF" />
    </Data>
(451) .current_average_value
PASSED
    <Data>
      <DoubleLongUnsigned Value="00000000" />
    </Data>
(452) .last_average_value
PASSED
    <Data>
      <DoubleLongUnsigned Value="00000000" />
    </Data>
(453) .scaler_unit
PASSED
    <Data>
      <Structure Qty="0002" >
        <Integer Value="00" />
        <Enum Value="1C" />
      </Structure>
    </Data>
(454) .status
PASSED
    <Data>
      <Unsigned Value="00" />
    </Data>
(455) .capture_time
PASSED
```

```
    <Data>
      <OctetString Value="07E60C15030E2D0000FFC400" />
    </Data>
(456) .start_time_current
PASSED
    <Data>
      <OctetString Value="07E60C15030E2D0000FFC400" />
    </Data>
(457) .period
PASSED
    <Data>
      <DoubleLongUnsigned Value="00000384" />
    </Data>
(458) .number_of_periods
PASSED
    <Data>
      <LongUnsigned Value="0001" />
    </Data>
```

Mngmt Get Demand Register 6 - Apparent energy export (-VA) 1-0:10.4.0.255 (@840)

```
(459) .logical_name
PASSED
    <Data>
      <OctetString Value="01000A0400FF" />
    </Data>
(460) .current_average_value
PASSED
    <Data>
      <DoubleLongUnsigned Value="00000000" />
    </Data>
(461) .last_average_value
PASSED
    <Data>
      <DoubleLongUnsigned Value="00000000" />
    </Data>
(462) .scaler_unit
PASSED
    <Data>
      <Structure Qty="0002" >
        <Integer Value="00" />
        <Enum Value="1C" />
      </Structure>
    </Data>
(463) .status
PASSED
    <Data>
      <Unsigned Value="00" />
    </Data>
(464) .capture_time
PASSED
    <Data>
      <OctetString Value="07E60C15030E2D0000FFC400" />
    </Data>
```

```
(465) .start_time_current
PASSED
  <Data>
    <OctetString Value="07E60C15030E2D0000FFC400" />
  </Data>
(466) .period
PASSED
  <Data>
    <DoubleLongUnsigned Value="00000384" />
  </Data>
(467) .number_of_periods
PASSED
  <Data>
    <LongUnsigned Value="0001" />
  </Data>
```

Mngmt Get Last Average Demand Register 1 - Active energy import (+A)
1-0:1.5.0.255 (@853)

```
(468) .logical_name
PASSED
  <Data>
    <OctetString Value="0100010500FF" />
  </Data>
(469) .value
PASSED
  <Data>
    <DoubleLongUnsigned Value="00000000" />
  </Data>
(470) .scaler_unit
PASSED
  <Data>
    <Structure Qty="0002" >
      <Integer Value="00" />
      <Enum Value="1B" />
    </Structure>
  </Data>
(471) .status
PASSED
  <Data>
    <Unsigned Value="00" />
  </Data>
(472) .capture_time
PASSED
  <Data>
    <OctetString Value="07E60C15030E2D0000FFC400" />
  </Data>
```

Mngmt Get Last Average Demand Register 2 - Active energy export (-A)
1-0:2.5.0.255 (@861)

```
(473) .logical_name
PASSED
  <Data>
    <OctetString Value="0100020500FF" />
  </Data>
```


(474) .value
PASSED
<Data>
 <DoubleLongUnsigned Value="00000000" />
</Data>

(475) .scaler_unit
PASSED
<Data>
 <Structure Qty="0002" >
 <Integer Value="00" />
 <Enum Value="1B" />
 </Structure>
</Data>

(476) .status
PASSED
<Data>
 <Unsigned Value="00" />
</Data>

(477) .capture_time
PASSED
<Data>
 <OctetString Value="07E60C15030E2D0000FFC400" />
</Data>

Mngmt Get Last Average Demand Register 3 - Reactive energy import (+R)
1-0:3.5.0.255 (@869)

(478) .logical_name
PASSED
<Data>
 <OctetString Value="0100030500FF" />
</Data>

(479) .value
PASSED
<Data>
 <DoubleLongUnsigned Value="00000000" />
</Data>

(480) .scaler_unit
PASSED
<Data>
 <Structure Qty="0002" >
 <Integer Value="00" />
 <Enum Value="1D" />
 </Structure>
</Data>

(481) .status
PASSED
<Data>
 <Unsigned Value="00" />
</Data>

(482) .capture_time
PASSED
<Data>
 <OctetString Value="07E60C15030E2D0000FFC400" />
</Data>

Mngmt Get Last Average Demand Register 4 - Reactive energy export (-R)

1-0:4.5.0.255 (@877)

(483) .logical_name

PASSED

```
<Data>
  <OctetString Value="0100040500FF" />
</Data>
```

(484) .value

PASSED

```
<Data>
  <DoubleLongUnsigned Value="00000000" />
</Data>
```

(485) .scaler_unit

PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="00" />
    <Enum Value="1D" />
  </Structure>
</Data>
```

(486) .status

PASSED

```
<Data>
  <Unsigned Value="00" />
</Data>
```

(487) .capture_time

PASSED

```
<Data>
  <OctetString Value="07E60C15030E2D0000FFC400" />
</Data>
```

Mngmt Get Last Average Demand Register 5 - Apparent energy import (+VA)

1-0:9.5.0.255 (@885)

(488) .logical_name

PASSED

```
<Data>
  <OctetString Value="0100090500FF" />
</Data>
```

(489) .value

PASSED

```
<Data>
  <DoubleLongUnsigned Value="00000000" />
</Data>
```

(490) .scaler_unit

PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="00" />
    <Enum Value="1C" />
  </Structure>
</Data>
```

(491) .status

PASSED

```

        <Data>
            <Unsigned Value="00" />
        </Data>
(492) .capture_time
PASSED
        <Data>
            <OctetString Value="07E60C15030E2D0000FFC400" />
        </Data>

Mngmt Get Last Average Demand Register 6 - Apparent energy export (-VA)
1-0:10.5.0.255 (@893)
(493) .logical_name
PASSED
        <Data>
            <OctetString Value="01000A0500FF" />
        </Data>
(494) .value
PASSED
        <Data>
            <DoubleLongUnsigned Value="00000000" />
        </Data>
(495) .scaler_unit
PASSED
        <Data>
            <Structure Qty="0002" >
                <Integer Value="00" />
                <Enum Value="1C" />
            </Structure>
        </Data>
(496) .status
PASSED
        <Data>
            <Unsigned Value="00" />
        </Data>
(497) .capture_time
PASSED
        <Data>
            <OctetString Value="07E60C15030E2D0000FFC400" />
        </Data>

Mngmt Get Maximum Demand Register 1 - Active energy import (+A) 1-0:1.6.0.255
(@901)
(498) .logical_name
PASSED
        <Data>
            <OctetString Value="0100010600FF" />
        </Data>
(499) .value
PASSED
        <Data>
            <DoubleLongUnsigned Value="00000000" />
        </Data>
(500) .scaler_unit
PASSED

```

```
    <Data>
      <Structure Qty="0002" >
        <Integer Value="00" />
        <Enum Value="1B" />
      </Structure>
    </Data>
(501) .status
PASSED
    <Data>
      <Unsigned Value="00" />
    </Data>
(502) .capture_time
PASSED
    <Data>
      <OctetString Value="07E60C15030D1C1300FFC400" />
    </Data>
```

Mngmt Get Maximum Demand Register 2 - Active energy import (+A) - rate 1
1-0:1.6.1.255 (@909)

```
(503) .logical_name
PASSED
    <Data>
      <OctetString Value="0100010601FF" />
    </Data>
(504) .value
PASSED
    <Data>
      <DoubleLongUnsigned Value="00000000" />
    </Data>
(505) .scaler_unit
PASSED
    <Data>
      <Structure Qty="0002" >
        <Integer Value="00" />
        <Enum Value="1B" />
      </Structure>
    </Data>
(506) .status
PASSED
    <Data>
      <Unsigned Value="00" />
    </Data>
(507) .capture_time
PASSED
    <Data>
      <OctetString Value="07E60C15030D1C1300FFC400" />
    </Data>
```

Mngmt Get Maximum Demand Register 3 - Active energy import (+A) - rate 2
1-0:1.6.2.255 (@917)

```
(508) .logical_name
PASSED
    <Data>
      <OctetString Value="0100010602FF" />
```

```
    </Data>
(509) .value
PASSED
    <Data>
        <DoubleLongUnsigned Value="00000000" />
    </Data>
(510) .scaler_unit
PASSED
    <Data>
        <Structure Qty="0002" >
            <Integer Value="00" />
            <Enum Value="1B" />
        </Structure>
    </Data>
(511) .status
PASSED
    <Data>
        <Unsigned Value="00" />
    </Data>
(512) .capture_time
PASSED
    <Data>
        <OctetString Value="07E60C15030D1C1300FFC400" />
    </Data>
```

Mngmt Get Maximum Demand Register 4 - Active energy import (+A) - rate 3
1-0:1.6.3.255 (@925)

```
(513) .logical_name
PASSED
    <Data>
        <OctetString Value="0100010603FF" />
    </Data>
(514) .value
PASSED
    <Data>
        <DoubleLongUnsigned Value="00000000" />
    </Data>
(515) .scaler_unit
PASSED
    <Data>
        <Structure Qty="0002" >
            <Integer Value="00" />
            <Enum Value="1B" />
        </Structure>
    </Data>
(516) .status
PASSED
    <Data>
        <Unsigned Value="00" />
    </Data>
(517) .capture_time
PASSED
    <Data>
        <OctetString Value="07E60C15030D1C1300FFC400" />
```

</Data>

Mngmt Get Maximum Demand Register 5 - Active energy import (+A) - rate 4
1-0:1.6.4.255 (@933)

(518) .logical_name

PASSED

<Data>
 <OctetString Value="0100010604FF" />
</Data>

(519) .value

PASSED

<Data>
 <DoubleLongUnsigned Value="00000000" />
</Data>

(520) .scaler_unit

PASSED

<Data>
 <Structure Qty="0002" >
 <Integer Value="00" />
 <Enum Value="1B" />
 </Structure>
</Data>

(521) .status

PASSED

<Data>
 <Unsigned Value="00" />
</Data>

(522) .capture_time

PASSED

<Data>
 <OctetString Value="07E60C15030D1C1300FFC400" />
</Data>

Mngmt Get Maximum Demand Register 6 - Active energy export (-A) 1-0:2.6.0.255
(@941)

(523) .logical_name

PASSED

<Data>
 <OctetString Value="0100020600FF" />
</Data>

(524) .value

PASSED

<Data>
 <DoubleLongUnsigned Value="00000000" />
</Data>

(525) .scaler_unit

PASSED

<Data>
 <Structure Qty="0002" >
 <Integer Value="00" />
 <Enum Value="1B" />
 </Structure>
</Data>

(526) .status

PASSED

```
<Data>
  <Unsigned Value="00" />
</Data>
```

(527) .capture_time

PASSED

```
<Data>
  <OctetString Value="07E60C15030D1C1300FFC400" />
</Data>
```

Mngmt Get Maximum Demand Register 7 - Active energy export (-A) - rate 1
1-0:2.6.1.255 (@949)

(528) .logical_name

PASSED

```
<Data>
  <OctetString Value="0100020601FF" />
</Data>
```

(529) .value

PASSED

```
<Data>
  <DoubleLongUnsigned Value="00000000" />
</Data>
```

(530) .scaler_unit

PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="00" />
    <Enum Value="1B" />
  </Structure>
</Data>
```

(531) .status

PASSED

```
<Data>
  <Unsigned Value="00" />
</Data>
```

(532) .capture_time

PASSED

```
<Data>
  <OctetString Value="07E60C15030D1C1300FFC400" />
</Data>
```

Mngmt Get Maximum Demand Register 8 - Active energy export (-A) - rate 2
1-0:2.6.2.255 (@957)

(533) .logical_name

PASSED

```
<Data>
  <OctetString Value="0100020602FF" />
</Data>
```

(534) .value

PASSED

```
<Data>
  <DoubleLongUnsigned Value="00000000" />
</Data>
```

(535) .scaler_unit

PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="00" />
    <Enum Value="1B" />
  </Structure>
</Data>
```

(536) .status

PASSED

```
<Data>
  <Unsigned Value="00" />
</Data>
```

(537) .capture_time

PASSED

```
<Data>
  <OctetString Value="07E60C15030D1C1300FFC400" />
</Data>
```

Mngmt Get Maximum Demand Register 9 - Active energy export (-A) - rate 3
1-0:2.6.3.255 (@965)

(538) .logical_name

PASSED

```
<Data>
  <OctetString Value="0100020603FF" />
</Data>
```

(539) .value

PASSED

```
<Data>
  <DoubleLongUnsigned Value="00000000" />
</Data>
```

(540) .scaler_unit

PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="00" />
    <Enum Value="1B" />
  </Structure>
</Data>
```

(541) .status

PASSED

```
<Data>
  <Unsigned Value="00" />
</Data>
```

(542) .capture_time

PASSED

```
<Data>
  <OctetString Value="07E60C15030D1C1300FFC400" />
</Data>
```

Mngmt Get Maximum Demand Register 10 - Active energy export (-A) - rate 4
1-0:2.6.4.255 (@973)

(543) .logical_name

PASSED

```
<Data>
```



```

        <OctetString Value="0100020604FF" />
    </Data>
(544) .value
PASSED
    <Data>
        <DoubleLongUnsigned Value="00000000" />
    </Data>
(545) .scaler_unit
PASSED
    <Data>
        <Structure Qty="0002" >
            <Integer Value="00" />
            <Enum Value="1B" />
        </Structure>
    </Data>
(546) .status
PASSED
    <Data>
        <Unsigned Value="00" />
    </Data>
(547) .capture_time
PASSED
    <Data>
        <OctetString Value="07E60C15030D1C1300FFC400" />
    </Data>

```

Mngmt Get Maximum Demand Register 11 - Reactive energy import (+R)
1-0:3.6.0.255 (@981)

```

(548) .logical_name
PASSED
    <Data>
        <OctetString Value="0100030600FF" />
    </Data>
(549) .value
PASSED
    <Data>
        <DoubleLongUnsigned Value="00000000" />
    </Data>
(550) .scaler_unit
PASSED
    <Data>
        <Structure Qty="0002" >
            <Integer Value="00" />
            <Enum Value="1D" />
        </Structure>
    </Data>
(551) .status
PASSED
    <Data>
        <Unsigned Value="00" />
    </Data>
(552) .capture_time
PASSED
    <Data>

```

```
    <OctetString Value="07E60C15030D1C1300FFC400" />
  </Data>
```

Mngmt Get Maximum Demand Register 12 - Reactive energy import (+R) - rate 1
1-0:3.6.1.255 (@989)

(553) .logical_name

PASSED

```
  <Data>
    <OctetString Value="0100030601FF" />
  </Data>
```

(554) .value

PASSED

```
  <Data>
    <DoubleLongUnsigned Value="00000000" />
  </Data>
```

(555) .scaler_unit

PASSED

```
  <Data>
    <Structure Qty="0002" >
      <Integer Value="00" />
      <Enum Value="1D" />
    </Structure>
  </Data>
```

(556) .status

PASSED

```
  <Data>
    <Unsigned Value="00" />
  </Data>
```

(557) .capture_time

PASSED

```
  <Data>
    <OctetString Value="07E60C15030D1C1300FFC400" />
  </Data>
```

Mngmt Get Maximum Demand Register 13 - Reactive energy import (+R) - rate 2
1-0:3.6.2.255 (@997)

(558) .logical_name

PASSED

```
  <Data>
    <OctetString Value="0100030602FF" />
  </Data>
```

(559) .value

PASSED

```
  <Data>
    <DoubleLongUnsigned Value="00000000" />
  </Data>
```

(560) .scaler_unit

PASSED

```
  <Data>
    <Structure Qty="0002" >
      <Integer Value="00" />
      <Enum Value="1D" />
    </Structure>
  </Data>
```

(561) .status
PASSED

```
<Data>  
  <Unsigned Value="00" />  
</Data>
```

(562) .capture_time
PASSED

```
<Data>  
  <OctetString Value="07E60C15030D1C1300FFC400" />  
</Data>
```

Mngmt Get Maximum Demand Register 14 - Reactive energy import (+R) - rate 3
1-0:3.6.3.255 (@1005)

(563) .logical_name
PASSED

```
<Data>  
  <OctetString Value="0100030603FF" />  
</Data>
```

(564) .value
PASSED

```
<Data>  
  <DoubleLongUnsigned Value="00000000" />  
</Data>
```

(565) .scaler_unit
PASSED

```
<Data>  
  <Structure Qty="0002" >  
    <Integer Value="00" />  
    <Enum Value="1D" />  
  </Structure>  
</Data>
```

(566) .status
PASSED

```
<Data>  
  <Unsigned Value="00" />  
</Data>
```

(567) .capture_time
PASSED

```
<Data>  
  <OctetString Value="07E60C15030D1C1300FFC400" />  
</Data>
```

Mngmt Get Maximum Demand Register 15 - Reactive energy import (+R) - rate 4
1-0:3.6.4.255 (@1013)

(568) .logical_name
PASSED

```
<Data>  
  <OctetString Value="0100030604FF" />  
</Data>
```

(569) .value
PASSED

```
<Data>  
  <DoubleLongUnsigned Value="00000000" />  
</Data>
```

(570) .scaler_unit
PASSED

```
<Data>  
  <Structure Qty="0002" >  
    <Integer Value="00" />  
    <Enum Value="1D" />  
  </Structure>  
</Data>
```

(571) .status
PASSED

```
<Data>  
  <Unsigned Value="00" />  
</Data>
```

(572) .capture_time
PASSED

```
<Data>  
  <OctetString Value="07E60C15030D1C1300FFC400" />  
</Data>
```

Mngmt Get Maximum Demand Register 16 - Reactive energy export (-R)
1-0:4.6.0.255 (@1021)

(573) .logical_name
PASSED

```
<Data>  
  <OctetString Value="0100040600FF" />  
</Data>
```

(574) .value
PASSED

```
<Data>  
  <DoubleLongUnsigned Value="00000000" />  
</Data>
```

(575) .scaler_unit
PASSED

```
<Data>  
  <Structure Qty="0002" >  
    <Integer Value="00" />  
    <Enum Value="1D" />  
  </Structure>  
</Data>
```

(576) .status
PASSED

```
<Data>  
  <Unsigned Value="00" />  
</Data>
```

(577) .capture_time
PASSED

```
<Data>  
  <OctetString Value="07E60C15030D1C1300FFC400" />  
</Data>
```

Mngmt Get Maximum Demand Register 17 - Reactive energy export (-R) - rate 1
1-0:4.6.1.255 (@1029)

(578) .logical_name
PASSED

```
    <Data>
      <OctetString Value="0100040601FF" />
    </Data>
(579) .value
PASSED
    <Data>
      <DoubleLongUnsigned Value="00000000" />
    </Data>
(580) .scaler_unit
PASSED
    <Data>
      <Structure Qty="0002" >
        <Integer Value="00" />
        <Enum Value="1D" />
      </Structure>
    </Data>
(581) .status
PASSED
    <Data>
      <Unsigned Value="00" />
    </Data>
(582) .capture_time
PASSED
    <Data>
      <OctetString Value="07E60C15030D1C1300FFC400" />
    </Data>
```

Mngmt Get Maximum Demand Register 18 - Reactive energy export (-R) - rate 2
1-0:4.6.2.255 (@1037)

```
(583) .logical_name
PASSED
    <Data>
      <OctetString Value="0100040602FF" />
    </Data>
(584) .value
PASSED
    <Data>
      <DoubleLongUnsigned Value="00000000" />
    </Data>
(585) .scaler_unit
PASSED
    <Data>
      <Structure Qty="0002" >
        <Integer Value="00" />
        <Enum Value="1D" />
      </Structure>
    </Data>
(586) .status
PASSED
    <Data>
      <Unsigned Value="00" />
    </Data>
(587) .capture_time
PASSED
```

```
<Data>
  <OctetString Value="07E60C15030D1C1300FFC400" />
</Data>
```

Mngmt Get Maximum Demand Register 19 - Reactive energy export (-R) - rate 3
1-0:4.6.3.255 (@1045)

(588) .logical_name

PASSED

```
<Data>
  <OctetString Value="0100040603FF" />
</Data>
```

(589) .value

PASSED

```
<Data>
  <DoubleLongUnsigned Value="00000000" />
</Data>
```

(590) .scaler_unit

PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="00" />
    <Enum Value="1D" />
  </Structure>
</Data>
```

(591) .status

PASSED

```
<Data>
  <Unsigned Value="00" />
</Data>
```

(592) .capture_time

PASSED

```
<Data>
  <OctetString Value="07E60C15030D1C1300FFC400" />
</Data>
```

Mngmt Get Maximum Demand Register 20 - Reactive energy export (-R) - rate 4
1-0:4.6.4.255 (@1053)

(593) .logical_name

PASSED

```
<Data>
  <OctetString Value="0100040604FF" />
</Data>
```

(594) .value

PASSED

```
<Data>
  <DoubleLongUnsigned Value="00000000" />
</Data>
```

(595) .scaler_unit

PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="00" />
    <Enum Value="1D" />
  </Structure>
```

```
    </Data>
(596) .status
PASSED
    <Data>
        <Unsigned Value="00" />
    </Data>
(597) .capture_time
PASSED
    <Data>
        <OctetString Value="07E60C15030D1C1300FFC400" />
    </Data>
```

Mngmt Get Maximum Demand Register 21 - Apparent energy import (+VA)
1-0:9.6.0.255 (@1061)

```
(598) .logical_name
PASSED
    <Data>
        <OctetString Value="0100090600FF" />
    </Data>
(599) .value
PASSED
    <Data>
        <DoubleLongUnsigned Value="00000000" />
    </Data>
(600) .scaler_unit
PASSED
    <Data>
        <Structure Qty="0002" >
            <Integer Value="00" />
            <Enum Value="1C" />
        </Structure>
    </Data>
(601) .status
PASSED
    <Data>
        <Unsigned Value="00" />
    </Data>
(602) .capture_time
PASSED
    <Data>
        <OctetString Value="07E60C15030D1C1300FFC400" />
    </Data>
```

Mngmt Get Maximum Demand Register 22 - Apparent energy import (+VA) - rate 1
1-0:9.6.1.255 (@1069)

```
(603) .logical_name
PASSED
    <Data>
        <OctetString Value="0100090601FF" />
    </Data>
(604) .value
PASSED
    <Data>
        <DoubleLongUnsigned Value="00000000" />
```

```
</Data>
(605) .scaler_unit
PASSED
```

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="00" />
    <Enum Value="1C" />
  </Structure>
</Data>
```

```
(606) .status
PASSED
```

```
<Data>
  <Unsigned Value="00" />
</Data>
```

```
(607) .capture_time
PASSED
```

```
<Data>
  <OctetString Value="07E60C15030D1C1300FFC400" />
</Data>
```

Mngmt Get Maximum Demand Register 23 - Apparent energy import (+VA) - rate 2
1-0:9.6.2.255 (@1077)

```
(608) .logical_name
PASSED
```

```
<Data>
  <OctetString Value="0100090602FF" />
</Data>
```

```
(609) .value
PASSED
```

```
<Data>
  <DoubleLongUnsigned Value="00000000" />
</Data>
```

```
(610) .scaler_unit
PASSED
```

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="00" />
    <Enum Value="1C" />
  </Structure>
</Data>
```

```
(611) .status
PASSED
```

```
<Data>
  <Unsigned Value="00" />
</Data>
```

```
(612) .capture_time
PASSED
```

```
<Data>
  <OctetString Value="07E60C15030D1C1300FFC400" />
</Data>
```

Mngmt Get Maximum Demand Register 24 - Apparent energy import (+VA) - rate 3
1-0:9.6.3.255 (@1085)

```
(613) .logical_name
```


PASSED

```
<Data>
  <OctetString Value="0100090603FF" />
</Data>
```

(614) .value

PASSED

```
<Data>
  <DoubleLongUnsigned Value="00000000" />
</Data>
```

(615) .scaler_unit

PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="00" />
    <Enum Value="1C" />
  </Structure>
</Data>
```

(616) .status

PASSED

```
<Data>
  <Unsigned Value="00" />
</Data>
```

(617) .capture_time

PASSED

```
<Data>
  <OctetString Value="07E60C15030D1C1300FFC400" />
</Data>
```

Mngmt Get Maximum Demand Register 25 - Apparent energy import (+VA) - rate 4
1-0:9.6.4.255 (@1093)

(618) .logical_name

PASSED

```
<Data>
  <OctetString Value="0100090604FF" />
</Data>
```

(619) .value

PASSED

```
<Data>
  <DoubleLongUnsigned Value="00000000" />
</Data>
```

(620) .scaler_unit

PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="00" />
    <Enum Value="1C" />
  </Structure>
</Data>
```

(621) .status

PASSED

```
<Data>
  <Unsigned Value="00" />
</Data>
```

(622) .capture_time

PASSED

```
<Data>
  <OctetString Value="07E60C15030D1C1300FFC400" />
</Data>
```

Mngmt Get Maximum Demand Register 26 - Apparent energy export (-VA)

1-0:10.6.0.255 (@1101)

(623) .logical_name

PASSED

```
<Data>
  <OctetString Value="01000A0600FF" />
</Data>
```

(624) .value

PASSED

```
<Data>
  <DoubleLongUnsigned Value="00000000" />
</Data>
```

(625) .scaler_unit

PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="00" />
    <Enum Value="1C" />
  </Structure>
</Data>
```

(626) .status

PASSED

```
<Data>
  <Unsigned Value="00" />
</Data>
```

(627) .capture_time

PASSED

```
<Data>
  <OctetString Value="07E60C15030D1C1300FFC400" />
</Data>
```

Mngmt Get Maximum Demand Register 27 - Apparent energy export (-VA) - rate 1

1-0:10.6.1.255 (@1109)

(628) .logical_name

PASSED

```
<Data>
  <OctetString Value="01000A0601FF" />
</Data>
```

(629) .value

PASSED

```
<Data>
  <DoubleLongUnsigned Value="00000000" />
</Data>
```

(630) .scaler_unit

PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="00" />
    <Enum Value="1C" />
  </Structure>
</Data>
```

```
        </Structure>
    </Data>
(631) .status
PASSED
    <Data>
        <Unsigned Value="00" />
    </Data>
(632) .capture_time
PASSED
    <Data>
        <OctetString Value="07E60C15030D1C1300FFC400" />
    </Data>
```

Mngmt Get Maximum Demand Register 28 - Apparent energy export (-VA) - rate 2
1-0:10.6.2.255 (@1117)

```
(633) .logical_name
PASSED
    <Data>
        <OctetString Value="01000A0602FF" />
    </Data>
(634) .value
PASSED
    <Data>
        <DoubleLongUnsigned Value="00000000" />
    </Data>
(635) .scaler_unit
PASSED
    <Data>
        <Structure Qty="0002" >
            <Integer Value="00" />
            <Enum Value="1C" />
        </Structure>
    </Data>
(636) .status
PASSED
    <Data>
        <Unsigned Value="00" />
    </Data>
(637) .capture_time
PASSED
    <Data>
        <OctetString Value="07E60C15030D1C1300FFC400" />
    </Data>
```

Mngmt Get Maximum Demand Register 29 - Apparent energy export (-VA) - rate 3
1-0:10.6.3.255 (@1125)

```
(638) .logical_name
PASSED
    <Data>
        <OctetString Value="01000A0603FF" />
    </Data>
(639) .value
PASSED
    <Data>
```

```
    <DoubleLongUnsigned Value="00000000" />
  </Data>
```

(640) .scaler_unit
PASSED

```
  <Data>
    <Structure Qty="0002" >
      <Integer Value="00" />
      <Enum Value="1C" />
    </Structure>
  </Data>
```

(641) .status
PASSED

```
  <Data>
    <Unsigned Value="00" />
  </Data>
```

(642) .capture_time
PASSED

```
  <Data>
    <OctetString Value="07E60C15030D1C1300FFC400" />
  </Data>
```

Mngmt Get Maximum Demand Register 30 - Apparent energy export (-VA) - rate 4
1-0:10.6.4.255 (@1133)

(643) .logical_name
PASSED

```
  <Data>
    <OctetString Value="01000A0604FF" />
  </Data>
```

(644) .value
PASSED

```
  <Data>
    <DoubleLongUnsigned Value="00000000" />
  </Data>
```

(645) .scaler_unit
PASSED

```
  <Data>
    <Structure Qty="0002" >
      <Integer Value="00" />
      <Enum Value="1C" />
    </Structure>
  </Data>
```

(646) .status
PASSED

```
  <Data>
    <Unsigned Value="00" />
  </Data>
```

(647) .capture_time
PASSED

```
  <Data>
    <OctetString Value="07E60C15030D1C1300FFC400" />
  </Data>
```

Mngmt Get Profile status - Load profile with period 1 0-0:96.10.1.255 (@1142)

(648) .logical_name

PASSED

```
<Data>
  <OctetString Value="0000600A01FF" />
</Data>
```

(649) .status

PASSED

```
<Data>
  <Unsigned Value="00" />
</Data>
```

Mngmt Get Load profile with period 1 i.e. General Load Profile 1-0:99.1.0.255
(@1146)

(650) .logical_name

PASSED

```
<Data>
  <OctetString Value="0100630100FF" />
</Data>
```

(651) .capture_objects

PASSED

```
<Data>
  <Array Qty="0004" >
    <Structure Qty="0004" >
      <LongUnsigned Value="0008" />
      <OctetString Value="0000010000FF" />
      <Integer Value="02" />
      <LongUnsigned Value="0000" />
    </Structure>
    <Structure Qty="0004" >
      <LongUnsigned Value="0001" />
      <OctetString Value="0000600A01FF" />
      <Integer Value="02" />
      <LongUnsigned Value="0000" />
    </Structure>
    <Structure Qty="0004" >
      <LongUnsigned Value="0003" />
      <OctetString Value="0100010800FF" />
      <Integer Value="02" />
      <LongUnsigned Value="0000" />
    </Structure>
    <Structure Qty="0004" >
      <LongUnsigned Value="0003" />
      <OctetString Value="0100020800FF" />
      <Integer Value="02" />
      <LongUnsigned Value="0000" />
    </Structure>
  </Array>
</Data>
```

(652) .capture_period

PASSED

```
<Data>
  <DoubleLongUnsigned Value="00000384" />
</Data>
```

(653) .sort_method

PASSED

```
<Data>
  <Enum Value="01" />
</Data>
(654) .sort_object
PASSED
```

```
<Data>
  <Structure Qty="0004" >
    <LongUnsigned Value="0008" />
    <OctetString Value="0000010000FF" />
    <Integer Value="02" />
    <LongUnsigned Value="0000" />
  </Structure>
</Data>
```

```
(655) .entries_in_use
PASSED
```

```
<Data>
  <DoubleLongUnsigned Value="00000013" />
</Data>
```

```
(656) .profile_entries
PASSED
```

```
<Data>
  <DoubleLongUnsigned Value="000010E0" />
</Data>
```

```
Mngmt Get Profile status - Load profile with period 2 0-0:96.10.2.255 (@1157)
(657) .logical_name
PASSED
```

```
<Data>
  <OctetString Value="0000600A02FF" />
</Data>
```

```
(658) .status
PASSED
```

```
<Data>
  <Unsigned Value="20" />
</Data>
```

```
Mngmt Get Load profile with period 2 i.e. Daily Values Profile 1-0:99.2.0.255
(@1161)
```

```
(659) .logical_name
PASSED
```

```
<Data>
  <OctetString Value="0100630200FF" />
</Data>
```

```
(660) .capture_objects
PASSED
```

```
<Data>
  <Array Qty="0004" >
    <Structure Qty="0004" >
      <LongUnsigned Value="0008" />
      <OctetString Value="0000010000FF" />
      <Integer Value="02" />
      <LongUnsigned Value="0000" />
    </Structure>
  <Structure Qty="0004" >
```

```

        <LongUnsigned Value="0001" />
        <OctetString Value="0000600A02FF" />
        <Integer Value="02" />
        <LongUnsigned Value="0000" />
    </Structure>
    <Structure Qty="0004" >
        <LongUnsigned Value="0003" />
        <OctetString Value="0100010800FF" />
        <Integer Value="02" />
        <LongUnsigned Value="0000" />
    </Structure>
    <Structure Qty="0004" >
        <LongUnsigned Value="0003" />
        <OctetString Value="0100020800FF" />
        <Integer Value="02" />
        <LongUnsigned Value="0000" />
    </Structure>
</Array>
</Data>
(661) .capture_period
PASSED
    <Data>
        <DoubleLongUnsigned Value="00015180" />
    </Data>
(662) .sort_method
PASSED
    <Data>
        <Enum Value="01" />
    </Data>
(663) .sort_object
PASSED
    <Data>
        <Structure Qty="0004" >
            <LongUnsigned Value="0008" />
            <OctetString Value="0000010000FF" />
            <Integer Value="02" />
            <LongUnsigned Value="0000" />
        </Structure>
    </Data>
(664) .entries_in_use
PASSED
    <Data>
        <DoubleLongUnsigned Value="0000000A" />
    </Data>
(665) .profile_entries
PASSED
    <Data>
        <DoubleLongUnsigned Value="0000003C" />
    </Data>

Mngmt Get Number of power failures in any phase 0-0:96.7.21.255 (@1173)
(666) .logical_name
PASSED
    <Data>

```

```

        <OctetString Value="0000600715FF" />
    </Data>
(667) .value
PASSED
    <Data>
        <LongUnsigned Value="0013" />
    </Data>

Mngmt Get Number of long power failures in any phase 0-0:96.7.9.255 (@1177)
(668) .logical_name
PASSED
    <Data>
        <OctetString Value="0000600709FF" />
    </Data>
(669) .value
PASSED
    <Data>
        <LongUnsigned Value="0004" />
    </Data>

Mngmt Get Time threshold for long power failure 0-0:96.7.20.255 (@1181)
(670) .logical_name
PASSED
    <Data>
        <OctetString Value="0000600714FF" />
    </Data>
(671) .value
PASSED
    <Data>
        <LongUnsigned Value="00B4" />
    </Data>
(672) .scaler_unit
PASSED
    <Data>
        <Structure Qty="0002" >
            <Integer Value="00" />
            <Enum Value="07" />
        </Structure>
    </Data>

Mngmt Get Duration of last long power failure in any phase 0-0:96.7.19.255
(@1187)
(673) .logical_name
PASSED
    <Data>
        <OctetString Value="0000600713FF" />
    </Data>
(674) .value
PASSED
    <Data>
        <LongUnsigned Value="0000" />
    </Data>
(675) .scaler_unit
PASSED

```



```
<Data>
  <Structure Qty="0002" >
    <Integer Value="00" />
    <Enum Value="07" />
  </Structure>
</Data>
```

Mngmt Get Threshold for voltage sag 1-0:12.31.0.255 (@1193)
(676) .logical_name
PASSED

```
<Data>
  <OctetString Value="01000C1F00FF" />
</Data>
```

(677) .value
PASSED

```
<Data>
  <LongUnsigned Value="00CF" />
</Data>
```

(678) .scaler_unit
PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="00" />
    <Enum Value="23" />
  </Structure>
</Data>
```

Mngmt Get Time threshold for voltage sag 1-0:12.43.0.255 (@1199)
(679) .logical_name
PASSED

```
<Data>
  <OctetString Value="01000C2B00FF" />
</Data>
```

(680) .value
PASSED

```
<Data>
  <LongUnsigned Value="001E" />
</Data>
```

(681) .scaler_unit
PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="00" />
    <Enum Value="07" />
  </Structure>
</Data>
```

Mngmt Get Number of voltage sags in phase L1 1-0:32.32.0.255 (@1205)
(682) .logical_name
PASSED

```
<Data>
  <OctetString Value="0100202000FF" />
</Data>
```

(683) .value

PASSED

```
<Data>
  <LongUnsigned Value="0000" />
</Data>
```

Mngmt Get Number of voltage sags in phase L2 1-0:52.32.0.255 (@1209)
(684) .logical_name

PASSED

```
<Data>
  <OctetString Value="0100342000FF" />
</Data>
```

(685) .value

PASSED

```
<Data>
  <LongUnsigned Value="0000" />
</Data>
```

Mngmt Get Number of voltage sags in phase L3 1-0:72.32.0.255 (@1213)
(686) .logical_name

PASSED

```
<Data>
  <OctetString Value="0100482000FF" />
</Data>
```

(687) .value

PASSED

```
<Data>
  <LongUnsigned Value="0000" />
</Data>
```

Mngmt Get Duration of last voltage sag in phase L1 1-0:32.33.0.255 (@1217)
(688) .logical_name

PASSED

```
<Data>
  <OctetString Value="0100202100FF" />
</Data>
```

(689) .value

PASSED

```
<Data>
  <LongUnsigned Value="0000" />
</Data>
```

(690) .scaler_unit

PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="00" />
    <Enum Value="07" />
  </Structure>
</Data>
```

Mngmt Get Duration of last voltage sag in phase L2 1-0:52.33.0.255 (@1223)
(691) .logical_name

PASSED

```
<Data>
  <OctetString Value="0100342100FF" />
```

```
    </Data>
(692) .value
PASSED
    <Data>
      <LongUnsigned Value="0000" />
    </Data>
```

```
(693) .scaler_unit
PASSED
    <Data>
      <Structure Qty="0002" >
        <Integer Value="00" />
        <Enum Value="07" />
      </Structure>
    </Data>
```

```
Mngmt Get Duration of last voltage sag in phase L3 1-0:72.33.0.255 (@1229)
(694) .logical_name
PASSED
```

```
    <Data>
      <OctetString Value="0100482100FF" />
    </Data>
```

```
(695) .value
PASSED
    <Data>
      <LongUnsigned Value="0000" />
    </Data>
```

```
(696) .scaler_unit
PASSED
    <Data>
      <Structure Qty="0002" >
        <Integer Value="00" />
        <Enum Value="07" />
      </Structure>
    </Data>
```

```
Mngmt Get Magnitude of last voltage sag in phase L1 1-0:32.34.0.255 (@1235)
(697) .logical_name
PASSED
```

```
    <Data>
      <OctetString Value="0100202200FF" />
    </Data>
```

```
(698) .value
PASSED
    <Data>
      <LongUnsigned Value="0000" />
    </Data>
```

```
(699) .scaler_unit
PASSED
    <Data>
      <Structure Qty="0002" >
        <Integer Value="00" />
        <Enum Value="23" />
      </Structure>
    </Data>
```

Mngmt Get Magnitude of last voltage sag in phase L2 1-0:52.34.0.255 (@1241)
(700) .logical_name
PASSED

```
<Data>  
  <OctetString Value="0100342200FF" />  
</Data>
```

(701) .value
PASSED

```
<Data>  
  <LongUnsigned Value="0000" />  
</Data>
```

(702) .scaler_unit
PASSED

```
<Data>  
  <Structure Qty="0002" >  
    <Integer Value="00" />  
    <Enum Value="23" />  
  </Structure>  
</Data>
```

Mngmt Get Magnitude of last voltage sag in phase L3 1-0:72.34.0.255 (@1247)
(703) .logical_name
PASSED

```
<Data>  
  <OctetString Value="0100482200FF" />  
</Data>
```

(704) .value
PASSED

```
<Data>  
  <LongUnsigned Value="0000" />  
</Data>
```

(705) .scaler_unit
PASSED

```
<Data>  
  <Structure Qty="0002" >  
    <Integer Value="00" />  
    <Enum Value="23" />  
  </Structure>  
</Data>
```

Mngmt Get Threshold for voltage swell 1-0:12.35.0.255 (@1253)
(706) .logical_name
PASSED

```
<Data>  
  <OctetString Value="01000C2300FF" />  
</Data>
```

(707) .value
PASSED

```
<Data>  
  <LongUnsigned Value="00FD" />  
</Data>
```

(708) .scaler_unit
PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="00" />
    <Enum Value="23" />
  </Structure>
</Data>
```

Mngmt Get Time threshold for voltage swell 1-0:12.44.0.255 (@1259)
(709) .logical_name
PASSED

```
<Data>
  <OctetString Value="01000C2C00FF" />
</Data>
```

(710) .value
PASSED

```
<Data>
  <LongUnsigned Value="001E" />
</Data>
```

(711) .scaler_unit
PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="00" />
    <Enum Value="07" />
  </Structure>
</Data>
```

Mngmt Get Number of voltage swells in phase L1 1-0:32.36.0.255 (@1265)
(712) .logical_name
PASSED

```
<Data>
  <OctetString Value="0100202400FF" />
</Data>
```

(713) .value
PASSED

```
<Data>
  <LongUnsigned Value="0000" />
</Data>
```

Mngmt Get Number of voltage swells in phase L2 1-0:52.36.0.255 (@1269)
(714) .logical_name
PASSED

```
<Data>
  <OctetString Value="0100342400FF" />
</Data>
```

(715) .value
PASSED

```
<Data>
  <LongUnsigned Value="0000" />
</Data>
```

Mngmt Get Number of voltage swells in phase L3 1-0:72.36.0.255 (@1273)
(716) .logical_name
PASSED

```

    <Data>
      <OctetString Value="0100482400FF" />
    </Data>
(717) .value
PASSED
    <Data>
      <LongUnsigned Value="0000" />
    </Data>

Mngmt Get Duration of last voltage swell in phase L1 1-0:32.37.0.255 (@1277)
(718) .logical_name
PASSED
    <Data>
      <OctetString Value="0100202500FF" />
    </Data>
(719) .value
PASSED
    <Data>
      <LongUnsigned Value="0000" />
    </Data>
(720) .scaler_unit
PASSED
    <Data>
      <Structure Qty="0002" >
        <Integer Value="00" />
        <Enum Value="07" />
      </Structure>
    </Data>

Mngmt Get Duration of last voltage swell in phase L2 1-0:52.37.0.255 (@1283)
(721) .logical_name
PASSED
    <Data>
      <OctetString Value="0100342500FF" />
    </Data>
(722) .value
PASSED
    <Data>
      <LongUnsigned Value="0000" />
    </Data>
(723) .scaler_unit
PASSED
    <Data>
      <Structure Qty="0002" >
        <Integer Value="00" />
        <Enum Value="07" />
      </Structure>
    </Data>

Mngmt Get Duration of last voltage swell in phase L3 1-0:72.37.0.255 (@1289)
(724) .logical_name
PASSED
    <Data>
      <OctetString Value="0100482500FF" />

```

```
    </Data>
(725) .value
PASSED
    <Data>
      <LongUnsigned Value="0000" />
    </Data>
```

```
(726) .scaler_unit
PASSED
    <Data>
      <Structure Qty="0002" >
        <Integer Value="00" />
        <Enum Value="07" />
      </Structure>
    </Data>
```

Mngmt Get Magnitude of last voltage swell in phase L1 1-0:32.38.0.255 (@1295)

```
(727) .logical_name
PASSED
    <Data>
      <OctetString Value="0100202600FF" />
    </Data>
```

```
(728) .value
PASSED
    <Data>
      <LongUnsigned Value="0000" />
    </Data>
```

```
(729) .scaler_unit
PASSED
    <Data>
      <Structure Qty="0002" >
        <Integer Value="00" />
        <Enum Value="23" />
      </Structure>
    </Data>
```

Mngmt Get Magnitude of last voltage swell in phase L2 1-0:52.38.0.255 (@1301)

```
(730) .logical_name
PASSED
    <Data>
      <OctetString Value="0100342600FF" />
    </Data>
```

```
(731) .value
PASSED
    <Data>
      <LongUnsigned Value="0000" />
    </Data>
```

```
(732) .scaler_unit
PASSED
    <Data>
      <Structure Qty="0002" >
        <Integer Value="00" />
        <Enum Value="23" />
      </Structure>
    </Data>
```

Mngmt Get Magnitude of last voltage swell in phase L3 1-0:72.38.0.255 (@1307)
(733) .logical_name
PASSED

```
<Data>  
  <OctetString Value="0100482600FF" />  
</Data>
```

(734) .value
PASSED

```
<Data>  
  <LongUnsigned Value="0000" />  
</Data>
```

(735) .scaler_unit
PASSED

```
<Data>  
  <Structure Qty="0002" >  
    <Integer Value="00" />  
    <Enum Value="23" />  
  </Structure>  
</Data>
```

Mngmt Get Threshold for missing voltage (voltage cut) 1-0:12.39.0.255 (@1313)
(736) .logical_name
PASSED

```
<Data>  
  <OctetString Value="01000C2700FF" />  
</Data>
```

(737) .value
PASSED

```
<Data>  
  <LongUnsigned Value="0067" />  
</Data>
```

(738) .scaler_unit
PASSED

```
<Data>  
  <Structure Qty="0002" >  
    <Integer Value="00" />  
    <Enum Value="23" />  
  </Structure>  
</Data>
```

Mngmt Get Time threshold for voltage cut 1-0:12.45.0.255 (@1319)
(739) .logical_name
PASSED

```
<Data>  
  <OctetString Value="01000C2D00FF" />  
</Data>
```

(740) .value
PASSED

```
<Data>  
  <LongUnsigned Value="001E" />  
</Data>
```

(741) .scaler_unit
PASSED


```
<Data>
  <Structure Qty="0002" >
    <Integer Value="00" />
    <Enum Value="07" />
  </Structure>
</Data>
```

Mngmt Get Power Failure Event Log 1-0:99.97.0.255 (@1325)
(742) .logical_name
PASSED

```
<Data>
  <OctetString Value="0100636100FF" />
</Data>
```

(743) .capture_objects
PASSED

```
<Data>
  <Array Qty="0002" >
    <Structure Qty="0004" >
      <LongUnsigned Value="0008" />
      <OctetString Value="0000010000FF" />
      <Integer Value="02" />
      <LongUnsigned Value="0000" />
    </Structure>
    <Structure Qty="0004" >
      <LongUnsigned Value="0003" />
      <OctetString Value="0000600713FF" />
      <Integer Value="02" />
      <LongUnsigned Value="0000" />
    </Structure>
  </Array>
</Data>
```

(744) .capture_period
PASSED

```
<Data>
  <DoubleLongUnsigned Value="00000000" />
</Data>
```

(745) .sort_method
PASSED

```
<Data>
  <Enum Value="01" />
</Data>
```

(746) .sort_object
PASSED

```
<Data>
  <Structure Qty="0004" >
    <LongUnsigned Value="0008" />
    <OctetString Value="0000010000FF" />
    <Integer Value="02" />
    <LongUnsigned Value="0000" />
  </Structure>
</Data>
```

(747) .entries_in_use
PASSED

```
<Data>
```

```

        <DoubleLongUnsigned Value="00000007" />
    </Data>
(748) .profile_entries
PASSED
    <Data>
        <DoubleLongUnsigned Value="0000000A" />
    </Data>

Mngmt Get Event Object - Power Quality Log 0-0:96.11.4.255 (@1336)
(749) .logical_name
PASSED
    <Data>
        <OctetString Value="0000600B04FF" />
    </Data>
(750) .value
PASSED
    <Data>
        <Enum Value="5A" />
    </Data>

Mngmt Get Power Quality Log 0-0:99.98.4.255 (@1340)
(751) .logical_name
PASSED
    <Data>
        <OctetString Value="0000636204FF" />
    </Data>
(752) .capture_objects
PASSED
    <Data>
        <Array Qty="0002" >
            <Structure Qty="0004" >
                <LongUnsigned Value="0008" />
                <OctetString Value="0000010000FF" />
                <Integer Value="02" />
                <LongUnsigned Value="0000" />
            </Structure>
            <Structure Qty="0004" >
                <LongUnsigned Value="0001" />
                <OctetString Value="0000600B04FF" />
                <Integer Value="02" />
                <LongUnsigned Value="0000" />
            </Structure>
        </Array>
    </Data>
(753) .capture_period
PASSED
    <Data>
        <DoubleLongUnsigned Value="00000000" />
    </Data>
(754) .sort_method
PASSED
    <Data>
        <Enum Value="01" />
    </Data>

```

(755) .sort_object
PASSED

```
<Data>
  <Structure Qty="0004" >
    <LongUnsigned Value="0008" />
    <OctetString Value="0000010000FF" />
    <Integer Value="02" />
    <LongUnsigned Value="0000" />
  </Structure>
</Data>
```

(756) .entries_in_use
PASSED

```
<Data>
  <DoubleLongUnsigned Value="00000026" />
</Data>
```

(757) .profile_entries
PASSED

```
<Data>
  <DoubleLongUnsigned Value="00000064" />
</Data>
```

Mngmt Get Instantaneous voltage L1 1-0:32.7.0.255 (@1351)

(758) .logical_name
PASSED

```
<Data>
  <OctetString Value="0100200700FF" />
</Data>
```

(759) .value
PASSED

```
<Data>
  <LongUnsigned Value="0000" />
</Data>
```

(760) .scaler_unit
PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="FF" />
    <Enum Value="23" />
  </Structure>
</Data>
```

Mngmt Get Average voltage L1 1-0:32.24.0.255 (@1357)

(761) .logical_name
PASSED

```
<Data>
  <OctetString Value="0100201800FF" />
</Data>
```

(762) .value
PASSED

```
<Data>
  <LongUnsigned Value="0000" />
</Data>
```

(763) .scaler_unit
PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="FF" />
    <Enum Value="23" />
  </Structure>
</Data>
```

Mngmt Get Instantaneous current L1 1-0:31.7.0.255 (@1363)
(764) .logical_name
PASSED

```
<Data>
  <OctetString Value="01001F0700FF" />
</Data>
```

(765) .value
PASSED

```
<Data>
  <LongUnsigned Value="0000" />
</Data>
```

(766) .scaler_unit
PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="FE" />
    <Enum Value="21" />
  </Structure>
</Data>
```

Mngmt Get Sliding Average current L1 (for fuse supervision) 1-0:31.4.0.255
(@1369)

(767) .logical_name
PASSED

```
<Data>
  <OctetString Value="01001F0400FF" />
</Data>
```

(768) .current_average_value
PASSED

```
<Data>
  <DoubleLongUnsigned Value="00000000" />
</Data>
```

(769) .last_average_value
PASSED

```
<Data>
  <DoubleLongUnsigned Value="00000000" />
</Data>
```

(770) .scaler_unit
PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="FE" />
    <Enum Value="21" />
  </Structure>
</Data>
```

(771) .status
PASSED

```

    <Data>
      <Unsigned Value="00" />
    </Data>
(772) .capture_time
PASSED
    <Data>
      <OctetString Value="07E60C15030E350A00FFC400" />
    </Data>
(773) .start_time_current
PASSED
    <Data>
      <OctetString Value="07E60C15030E332A00FFC400" />
    </Data>
(774) .period
PASSED
    <Data>
      <DoubleLongUnsigned Value="00000001" />
    </Data>
(775) .number_of_periods
PASSED
    <Data>
      <LongUnsigned Value="005A" />
    </Data>

Mngmt Get Instantaneous voltage L2 1-0:52.7.0.255 (@1382)
(776) .logical_name
PASSED
    <Data>
      <OctetString Value="0100340700FF" />
    </Data>
(777) .value
PASSED
    <Data>
      <LongUnsigned Value="0000" />
    </Data>
(778) .scaler_unit
PASSED
    <Data>
      <Structure Qty="0002" >
        <Integer Value="FF" />
        <Enum Value="23" />
      </Structure>
    </Data>

Mngmt Get Average voltage L2 1-0:52.24.0.255 (@1388)
(779) .logical_name
PASSED
    <Data>
      <OctetString Value="0100341800FF" />
    </Data>
(780) .value
PASSED
    <Data>
      <LongUnsigned Value="0000" />

```

```
</Data>
(781) .scaler_unit
PASSED
```

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="FF" />
    <Enum Value="23" />
  </Structure>
</Data>
```

```
Mngmt Get Instantaneous current L2 1-0:51.7.0.255 (@1394)
(782) .logical_name
PASSED
```

```
<Data>
  <OctetString Value="0100330700FF" />
</Data>
```

```
(783) .value
PASSED
```

```
<Data>
  <LongUnsigned Value="0000" />
</Data>
```

```
(784) .scaler_unit
PASSED
```

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="FE" />
    <Enum Value="21" />
  </Structure>
</Data>
```

```
Mngmt Get Sliding Average current L2 (for fuse supervision) 1-0:51.4.0.255
(@1400)
```

```
(785) .logical_name
PASSED
```

```
<Data>
  <OctetString Value="0100330400FF" />
</Data>
```

```
(786) .current_average_value
PASSED
```

```
<Data>
  <DoubleLongUnsigned Value="00000000" />
</Data>
```

```
(787) .last_average_value
PASSED
```

```
<Data>
  <DoubleLongUnsigned Value="00000000" />
</Data>
```

```
(788) .scaler_unit
PASSED
```

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="FE" />
    <Enum Value="21" />
  </Structure>
```

```

    </Data>
(789) .status
PASSED
    <Data>
        <Unsigned Value="00" />
    </Data>
(790) .capture_time
PASSED
    <Data>
        <OctetString Value="07E60C15030E351E00FFC400" />
    </Data>
(791) .start_time_current
PASSED
    <Data>
        <OctetString Value="07E60C15030E340200FFC400" />
    </Data>
(792) .period
PASSED
    <Data>
        <DoubleLongUnsigned Value="00000001" />
    </Data>
(793) .number_of_periods
PASSED
    <Data>
        <LongUnsigned Value="005A" />
    </Data>

Mngmt Get Instantaneous voltage L3 1-0:72.7.0.255 (@1413)
(794) .logical_name
PASSED
    <Data>
        <OctetString Value="0100480700FF" />
    </Data>
(795) .value
PASSED
    <Data>
        <LongUnsigned Value="08ED" />
    </Data>
(796) .scaler_unit
PASSED
    <Data>
        <Structure Qty="0002" >
            <Integer Value="FF" />
            <Enum Value="23" />
        </Structure>
    </Data>

Mngmt Get Average voltage L3 1-0:72.24.0.255 (@1419)
(797) .logical_name
PASSED
    <Data>
        <OctetString Value="0100481800FF" />
    </Data>
(798) .value

```

PASSED

```
<Data>
  <LongUnsigned Value="0902" />
</Data>
```

(799) .scaler_unit

PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="FF" />
    <Enum Value="23" />
  </Structure>
</Data>
```

Mngmt Get Instantaneous current L3 1-0:71.7.0.255 (@1425)

(800) .logical_name

PASSED

```
<Data>
  <OctetString Value="0100470700FF" />
</Data>
```

(801) .value

PASSED

```
<Data>
  <LongUnsigned Value="0000" />
</Data>
```

(802) .scaler_unit

PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="FE" />
    <Enum Value="21" />
  </Structure>
</Data>
```

Mngmt Get Sliding Average current L3 (for fuse supervision) 1-0:71.4.0.255 (@1431)

(803) .logical_name

PASSED

```
<Data>
  <OctetString Value="0100470400FF" />
</Data>
```

(804) .current_average_value

PASSED

```
<Data>
  <DoubleLongUnsigned Value="00000000" />
</Data>
```

(805) .last_average_value

PASSED

```
<Data>
  <DoubleLongUnsigned Value="00000000" />
</Data>
```

(806) .scaler_unit

PASSED

```
<Data>
  <Structure Qty="0002" >
```



```

        <Integer Value="FE" />
        <Enum Value="21" />
    </Structure>
</Data>
(807) .status
PASSED
    <Data>
        <Unsigned Value="00" />
    </Data>
(808) .capture_time
PASSED
    <Data>
        <OctetString Value="07E60C15030E353200FFC400" />
    </Data>
(809) .start_time_current
PASSED
    <Data>
        <OctetString Value="07E60C15030E341700FFC400" />
    </Data>
(810) .period
PASSED
    <Data>
        <DoubleLongUnsigned Value="00000001" />
    </Data>
(811) .number_of_periods
PASSED
    <Data>
        <LongUnsigned Value="005A" />
    </Data>

Mngmt Get Instantaneous current (sum over all phases) 1-0:90.7.0.255 (@1444)
(812) .logical_name
PASSED
    <Data>
        <OctetString Value="01005A0700FF" />
    </Data>
(813) .value
PASSED
    <Data>
        <LongUnsigned Value="0000" />
    </Data>
(814) .scaler_unit
PASSED
    <Data>
        <Structure Qty="0002" >
            <Integer Value="FE" />
            <Enum Value="21" />
        </Structure>
    </Data>

Mngmt Get Instantaneous net frequency; any phase 1-0:14.7.0.255 (@1450)
(815) .logical_name
PASSED
    <Data>

```

```

        <OctetString Value="01000E0700FF" />
    </Data>
(816) .value
PASSED
    <Data>
        <LongUnsigned Value="1386" />
    </Data>
(817) .scaler_unit
PASSED
    <Data>
        <Structure Qty="0002" >
            <Integer Value="FE" />
            <Enum Value="2C" />
        </Structure>
    </Data>

Mngmt Get Instantaneous active power (|+A|+|-A|) 1-0:15.7.0.255 (@1456)
(818) .logical_name
PASSED
    <Data>
        <OctetString Value="01000F0700FF" />
    </Data>
(819) .value
PASSED
    <Data>
        <DoubleLongUnsigned Value="00000000" />
    </Data>
(820) .scaler_unit
PASSED
    <Data>
        <Structure Qty="0002" >
            <Integer Value="00" />
            <Enum Value="1B" />
        </Structure>
    </Data>

Mngmt Get Instantaneous active import power (+A) 1-0:1.7.0.255 (@1462)
(821) .logical_name
PASSED
    <Data>
        <OctetString Value="0100010700FF" />
    </Data>
(822) .value
PASSED
    <Data>
        <DoubleLongUnsigned Value="00000000" />
    </Data>
(823) .scaler_unit
PASSED
    <Data>
        <Structure Qty="0002" >
            <Integer Value="00" />
            <Enum Value="1B" />
        </Structure>

```

</Data>

Mngmt Get Instantaneous active export power (-A) 1-0:2.7.0.255 (@1468)
(824) .logical_name

PASSED

<Data>
 <OctetString Value="0100020700FF" />
</Data>

(825) .value

PASSED

<Data>
 <DoubleLongUnsigned Value="00000000" />
</Data>

(826) .scaler_unit

PASSED

<Data>
 <Structure Qty="0002" >
 <Integer Value="00" />
 <Enum Value="1B" />
 </Structure>
</Data>

Mngmt Get Instantaneous reactive import power (+R) 1-0:3.7.0.255 (@1474)

(827) .logical_name

PASSED

<Data>
 <OctetString Value="0100030700FF" />
</Data>

(828) .value

PASSED

<Data>
 <DoubleLongUnsigned Value="00000000" />
</Data>

(829) .scaler_unit

PASSED

<Data>
 <Structure Qty="0002" >
 <Integer Value="00" />
 <Enum Value="1D" />
 </Structure>
</Data>

Mngmt Get Instantaneous reactive export power (-R) 1-0:4.7.0.255 (@1480)

(830) .logical_name

PASSED

<Data>
 <OctetString Value="0100040700FF" />
</Data>

(831) .value

PASSED

<Data>
 <DoubleLongUnsigned Value="00000000" />
</Data>

(832) .scaler_unit

PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="00" />
    <Enum Value="1D" />
  </Structure>
</Data>
```

Mngmt Get Instantaneous apparent import power (+VA) 1-0:9.7.0.255 (@1486)
(833) .logical_name

PASSED

```
<Data>
  <OctetString Value="0100090700FF" />
</Data>
```

(834) .value

PASSED

```
<Data>
  <DoubleLongUnsigned Value="00000000" />
</Data>
```

(835) .scaler_unit

PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="00" />
    <Enum Value="1C" />
  </Structure>
</Data>
```

Mngmt Get Instantaneous apparent export power (-VA) 1-0:10.7.0.255 (@1492)
(836) .logical_name

PASSED

```
<Data>
  <OctetString Value="01000A0700FF" />
</Data>
```

(837) .value

PASSED

```
<Data>
  <DoubleLongUnsigned Value="00000000" />
</Data>
```

(838) .scaler_unit

PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="00" />
    <Enum Value="1C" />
  </Structure>
</Data>
```

Mngmt Get Average Import Power (+A) 1-0:1.24.0.255 (@1498)
(839) .logical_name

PASSED

```
<Data>
  <OctetString Value="0100011800FF" />
</Data>
```

```

(840) .current_average_value
PASSED
    <Data>
        <DoubleLongUnsigned Value="00000000" />
    </Data>
(841) .last_average_value
PASSED
    <Data>
        <DoubleLongUnsigned Value="00000000" />
    </Data>
(842) .scaler_unit
PASSED
    <Data>
        <Structure Qty="0002" >
            <Integer Value="00" />
            <Enum Value="1B" />
        </Structure>
    </Data>
(843) .status
PASSED
    <Data>
        <Unsigned Value="00" />
    </Data>
(844) .capture_time
PASSED
    <Data>
        <OctetString Value="07E60C15030E360000FFC400" />
    </Data>
(845) .start_time_current
PASSED
    <Data>
        <OctetString Value="07E60C15030E280000FFC400" />
    </Data>
(846) .period
PASSED
    <Data>
        <DoubleLongUnsigned Value="0000003C" />
    </Data>
(847) .number_of_periods
PASSED
    <Data>
        <LongUnsigned Value="000F" />
    </Data>

Mngmt Get Average Net Power (|+A|-|-A|) 1-0:16.24.0.255 (@1511)
(848) .logical_name
PASSED
    <Data>
        <OctetString Value="0100101800FF" />
    </Data>
(849) .current_average_value
PASSED
    <Data>
        <DoubleLong Value="00000000" />

```

```

    </Data>
(850) .last_average_value
PASSED
    <Data>
        <DoubleLong Value="00000000" />
    </Data>
(851) .scaler_unit
PASSED
    <Data>
        <Structure Qty="0002" >
            <Integer Value="00" />
            <Enum Value="1B" />
        </Structure>
    </Data>
(852) .status
PASSED
    <Data>
        <Unsigned Value="00" />
    </Data>
(853) .capture_time
PASSED
    <Data>
        <OctetString Value="07E60C15030E360000FFC400" />
    </Data>
(854) .start_time_current
PASSED
    <Data>
        <OctetString Value="07E60C15030E280000FFC400" />
    </Data>
(855) .period
PASSED
    <Data>
        <DoubleLongUnsigned Value="0000003C" />
    </Data>
(856) .number_of_periods
PASSED
    <Data>
        <LongUnsigned Value="000F" />
    </Data>

Mngmt Get Average Total Power (|+A|+|-A|) 1-0:15.24.0.255 (@1524)
(857) .logical_name
PASSED
    <Data>
        <OctetString Value="01000F1800FF" />
    </Data>
(858) .current_average_value
PASSED
    <Data>
        <DoubleLongUnsigned Value="00000000" />
    </Data>
(859) .last_average_value
PASSED
    <Data>

```

```

        <DoubleLongUnsigned Value="00000000" />
    </Data>
(860) .scaler_unit
PASSED
    <Data>
        <Structure Qty="0002" >
            <Integer Value="00" />
            <Enum Value="1B" />
        </Structure>
    </Data>
(861) .status
PASSED
    <Data>
        <Unsigned Value="00" />
    </Data>
(862) .capture_time
PASSED
    <Data>
        <OctetString Value="07E60C15030E360000FFC400" />
    </Data>
(863) .start_time_current
PASSED
    <Data>
        <OctetString Value="07E60C15030E280000FFC400" />
    </Data>
(864) .period
PASSED
    <Data>
        <DoubleLongUnsigned Value="0000003C" />
    </Data>
(865) .number_of_periods
PASSED
    <Data>
        <LongUnsigned Value="000F" />
    </Data>

Mngmt Get Instantaneous Power factor (+A/+VA) 1-0:13.7.0.255 (@1537)
(866) .logical_name
PASSED
    <Data>
        <OctetString Value="01000D0700FF" />
    </Data>
(867) .value
PASSED
    <Data>
        <LongUnsigned Value="0000" />
    </Data>
(868) .scaler_unit
PASSED
    <Data>
        <Structure Qty="0002" >
            <Integer Value="FD" />
            <Enum Value="FF" />
        </Structure>

```

</Data>

Mngmt Get Last Average Power factor (+A/+VA) 1-0:13.5.0.255 (@1543)
(869) .logical_name

PASSED

<Data>
 <OctetString Value="01000D0500FF" />
</Data>

(870) .value

PASSED

<Data>
 <LongUnsigned Value="0000" />
</Data>

(871) .scaler_unit

PASSED

<Data>
 <Structure Qty="0002" >
 <Integer Value="FD" />
 <Enum Value="FF" />
 </Structure>
</Data>

(872) .status

PASSED

<Data>
 <Unsigned Value="00" />
</Data>

(873) .capture_time

PASSED

<Data>
 <OctetString Value="07E60C15030E2D0000FFC400" />
</Data>

Mngmt Get Minimum Power factor (+A/+VA) 1-0:13.3.0.255 (@1551)

(874) .logical_name

PASSED

<Data>
 <OctetString Value="01000D0300FF" />
</Data>

(875) .value

PASSED

<Data>
 <LongUnsigned Value="0000" />
</Data>

(876) .scaler_unit

PASSED

<Data>
 <Structure Qty="0002" >
 <Integer Value="FD" />
 <Enum Value="FF" />
 </Structure>
</Data>

(877) .status

PASSED

<Data>


```
        <Unsigned Value="00" />
    </Data>
(878) .capture_time
PASSED
    <Data>
        <OctetString Value="07E60C15030D1C1300FFC400" />
    </Data>

Mngmt Get Measurement Period 3 for Instantaneous values 1-0:0.8.2.255 (@1559)
(879) .logical_name
PASSED
    <Data>
        <OctetString Value="0100000802FF" />
    </Data>
(880) .value
PASSED
    <Data>
        <DoubleLongUnsigned Value="00000258" />
    </Data>
(881) .scaler_unit
PASSED
    <Data>
        <Structure Qty="0002" >
            <Integer Value="00" />
            <Enum Value="07" />
        </Structure>
    </Data>

Mngmt Get M-Bus master port setup 1 0-0:24.6.0.255 (@1566)
(882) .logical_name
PASSED
    <Data>
        <OctetString Value="0000180600FF" />
    </Data>
(883) .comm_speed
PASSED
    <Data>
        <Enum Value="03" />
    </Data>

Mngmt Get M-Bus master port setup 2 0-1:24.6.0.255 (@1570)
(884) .logical_name
INAPPLICABLE
    Optional object is not implemented
(885) .comm_speed
INAPPLICABLE
    Optional object is not implemented

Mngmt Get M-Bus client channel 1 0-1:24.1.0.255 (@1574)
(886) .logical_name
PASSED
    <Data>
        <OctetString Value="0001180100FF" />
    </Data>
```

```
(887) .mbus_port_reference
PASSED
  <Data>
    <OctetString Value="0000180600FF" />
  </Data>
(888) .capture_definition
PASSED
  <Data>
    <Array Qty="0000" >
    </Array>
  </Data>
(889) .capture_period
PASSED
  <Data>
    <DoubleLongUnsigned Value="00000E10" />
  </Data>
(890) .primary_address
PASSED
  <Data>
    <Unsigned Value="00" />
  </Data>
(891) .identification_number
PASSED
  <Data>
    <DoubleLongUnsigned Value="00000000" />
  </Data>
(892) .manufacturer_id
PASSED
  <Data>
    <LongUnsigned Value="0000" />
  </Data>
(893) .version
PASSED
  <Data>
    <Unsigned Value="00" />
  </Data>
(894) .device_type
PASSED
  <Data>
    <Unsigned Value="00" />
  </Data>
(895) .access_number
PASSED
  <Data>
    <Unsigned Value="00" />
  </Data>
(896) .status
PASSED
  <Data>
    <Unsigned Value="00" />
  </Data>
(897) .alarm
PASSED
  <Data>
```

```
    <Unsigned Value="00" />
  </Data>

Mngmt Get M-Bus client channel 2 0-2:24.1.0.255 (@1596)
(898) .logical_name
PASSED
  <Data>
    <OctetString Value="0002180100FF" />
  </Data>
(899) .mbus_port_reference
PASSED
  <Data>
    <OctetString Value="0000180600FF" />
  </Data>
(900) .capture_definition
PASSED
  <Data>
    <Array Qty="0000" >
      </Array>
    </Data>
(901) .capture_period
PASSED
  <Data>
    <DoubleLongUnsigned Value="00000E10" />
  </Data>
(902) .primary_address
PASSED
  <Data>
    <Unsigned Value="00" />
  </Data>
(903) .identification_number
PASSED
  <Data>
    <DoubleLongUnsigned Value="00000000" />
  </Data>
(904) .manufacturer_id
PASSED
  <Data>
    <LongUnsigned Value="0000" />
  </Data>
(905) .version
PASSED
  <Data>
    <Unsigned Value="00" />
  </Data>
(906) .device_type
PASSED
  <Data>
    <Unsigned Value="00" />
  </Data>
(907) .access_number
PASSED
  <Data>
    <Unsigned Value="00" />
  </Data>
```

```
    </Data>
(908) .status
PASSED
    <Data>
      <Unsigned Value="00" />
    </Data>
(909) .alarm
PASSED
    <Data>
      <Unsigned Value="00" />
    </Data>

Mngmt Get M-Bus client channel 3 0-3:24.1.0.255 (@1618)
(910) .logical_name
PASSED
    <Data>
      <OctetString Value="0003180100FF" />
    </Data>
(911) .mbus_port_reference
PASSED
    <Data>
      <OctetString Value="0000180600FF" />
    </Data>
(912) .capture_definition
PASSED
    <Data>
      <Array Qty="0000" >
        </Array>
    </Data>
(913) .capture_period
PASSED
    <Data>
      <DoubleLongUnsigned Value="00000E10" />
    </Data>
(914) .primary_address
PASSED
    <Data>
      <Unsigned Value="00" />
    </Data>
(915) .identification_number
PASSED
    <Data>
      <DoubleLongUnsigned Value="00000000" />
    </Data>
(916) .manufacturer_id
PASSED
    <Data>
      <LongUnsigned Value="0000" />
    </Data>
(917) .version
PASSED
    <Data>
      <Unsigned Value="00" />
    </Data>
```

```
(918) .device_type
PASSED
    <Data>
        <Unsigned Value="00" />
    </Data>
(919) .access_number
PASSED
    <Data>
        <Unsigned Value="00" />
    </Data>
(920) .status
PASSED
    <Data>
        <Unsigned Value="00" />
    </Data>
(921) .alarm
PASSED
    <Data>
        <Unsigned Value="00" />
    </Data>

Mngmt Get M-Bus client channel 4 0-4:24.1.0.255 (@1640)
(922) .logical_name
PASSED
    <Data>
        <OctetString Value="0004180100FF" />
    </Data>
(923) .mbus_port_reference
PASSED
    <Data>
        <OctetString Value="0000180600FF" />
    </Data>
(924) .capture_definition
PASSED
    <Data>
        <Array Qty="0000" >
            </Array>
    </Data>
(925) .capture_period
PASSED
    <Data>
        <DoubleLongUnsigned Value="00000E10" />
    </Data>
(926) .primary_address
PASSED
    <Data>
        <Unsigned Value="00" />
    </Data>
(927) .identification_number
PASSED
    <Data>
        <DoubleLongUnsigned Value="00000000" />
    </Data>
(928) .manufacturer_id
```

PASSED

```
<Data>
  <LongUnsigned Value="0000" />
</Data>
```

(929) .version

PASSED

```
<Data>
  <Unsigned Value="00" />
</Data>
```

(930) .device_type

PASSED

```
<Data>
  <Unsigned Value="00" />
</Data>
```

(931) .access_number

PASSED

```
<Data>
  <Unsigned Value="00" />
</Data>
```

(932) .status

PASSED

```
<Data>
  <Unsigned Value="00" />
</Data>
```

(933) .alarm

PASSED

```
<Data>
  <Unsigned Value="00" />
</Data>
```

Mngmt Get M-Bus Value channel 1, instance 1 0-1:24.2.1.255 (@1662)

(934) .logical_name

PASSED

```
<Data>
  <OctetString Value="0001180201FF" />
</Data>
```

(935) .value

PASSED

```
<Data>
  <DoubleLongUnsigned Value="00000000" />
</Data>
```

(936) .scaler_unit

PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="00" />
    <Enum Value="00" />
  </Structure>
</Data>
```

(937) .status

PASSED

```
<Data>
  <Unsigned Value="00" />
</Data>
```

```
(938) .capture_time
PASSED
  <Data>
    <OctetString Value="FFFFFFFFFFFFFFFF008000FF" />
  </Data>

Mngmt Get M-Bus Value channel 1, instance 2 0-1:24.2.2.255 (@1670)
(939) .logical_name
PASSED
  <Data>
    <OctetString Value="0001180202FF" />
  </Data>
(940) .value
PASSED
  <Data>
    <DoubleLongUnsigned Value="00000000" />
  </Data>
(941) .scaler_unit
PASSED
  <Data>
    <Structure Qty="0002" >
      <Integer Value="00" />
      <Enum Value="00" />
    </Structure>
  </Data>
(942) .status
PASSED
  <Data>
    <Unsigned Value="00" />
  </Data>
(943) .capture_time
PASSED
  <Data>
    <OctetString Value="FFFFFFFFFFFFFFFF008000FF" />
  </Data>

Mngmt Get M-Bus Value channel 1, instance 3 0-1:24.2.3.255 (@1678)
(944) .logical_name
PASSED
  <Data>
    <OctetString Value="0001180203FF" />
  </Data>
(945) .value
PASSED
  <Data>
    <DoubleLongUnsigned Value="00000000" />
  </Data>
(946) .scaler_unit
PASSED
  <Data>
    <Structure Qty="0002" >
      <Integer Value="00" />
      <Enum Value="00" />
    </Structure>
```

```
    </Data>
(947) .status
PASSED
    <Data>
        <Unsigned Value="00" />
    </Data>
(948) .capture_time
PASSED
    <Data>
        <OctetString Value="FFFFFFFFFFFFFFFF008000FF" />
    </Data>

Mngmt Get M-Bus Value channel 1, instance 4 0-1:24.2.4.255 (@1686)
(949) .logical_name
PASSED
    <Data>
        <OctetString Value="0001180204FF" />
    </Data>
(950) .value
PASSED
    <Data>
        <DoubleLongUnsigned Value="00000000" />
    </Data>
(951) .scaler_unit
PASSED
    <Data>
        <Structure Qty="0002" >
            <Integer Value="00" />
            <Enum Value="00" />
        </Structure>
    </Data>
(952) .status
PASSED
    <Data>
        <Unsigned Value="00" />
    </Data>
(953) .capture_time
PASSED
    <Data>
        <OctetString Value="FFFFFFFFFFFFFFFF008000FF" />
    </Data>

Mngmt Get M-Bus Value channel 2, instance 1 0-2:24.2.1.255 (@1694)
(954) .logical_name
PASSED
    <Data>
        <OctetString Value="0002180201FF" />
    </Data>
(955) .value
PASSED
    <Data>
        <DoubleLongUnsigned Value="00000000" />
    </Data>
(956) .scaler_unit
```


PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="00" />
    <Enum Value="00" />
  </Structure>
</Data>
```

(957) .status

PASSED

```
<Data>
  <Unsigned Value="00" />
</Data>
```

(958) .capture_time

PASSED

```
<Data>
  <OctetString Value="FFFFFFFFFFFFFFFF008000FF" />
</Data>
```

Mngmt Get M-Bus Value channel 2, instance 2 0-2:24.2.2.255 (@1702)

(959) .logical_name

PASSED

```
<Data>
  <OctetString Value="0002180202FF" />
</Data>
```

(960) .value

PASSED

```
<Data>
  <DoubleLongUnsigned Value="00000000" />
</Data>
```

(961) .scaler_unit

PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="00" />
    <Enum Value="00" />
  </Structure>
</Data>
```

(962) .status

PASSED

```
<Data>
  <Unsigned Value="00" />
</Data>
```

(963) .capture_time

PASSED

```
<Data>
  <OctetString Value="FFFFFFFFFFFFFFFF008000FF" />
</Data>
```

Mngmt Get M-Bus Value channel 2, instance 3 0-2:24.2.3.255 (@1710)

(964) .logical_name

PASSED

```
<Data>
  <OctetString Value="0002180203FF" />
</Data>
```

```
(965) .value
PASSED
  <Data>
    <DoubleLongUnsigned Value="00000000" />
  </Data>
(966) .scaler_unit
PASSED
  <Data>
    <Structure Qty="0002" >
      <Integer Value="00" />
      <Enum Value="00" />
    </Structure>
  </Data>
(967) .status
PASSED
  <Data>
    <Unsigned Value="00" />
  </Data>
(968) .capture_time
PASSED
  <Data>
    <OctetString Value="FFFFFFFFFFFFFFFF008000FF" />
  </Data>

Mngmt Get M-Bus Value channel 2, instance 4 0-2:24.2.4.255 (@1718)
(969) .logical_name
PASSED
  <Data>
    <OctetString Value="0002180204FF" />
  </Data>
(970) .value
PASSED
  <Data>
    <DoubleLongUnsigned Value="00000000" />
  </Data>
(971) .scaler_unit
PASSED
  <Data>
    <Structure Qty="0002" >
      <Integer Value="00" />
      <Enum Value="00" />
    </Structure>
  </Data>
(972) .status
PASSED
  <Data>
    <Unsigned Value="00" />
  </Data>
(973) .capture_time
PASSED
  <Data>
    <OctetString Value="FFFFFFFFFFFFFFFF008000FF" />
  </Data>
```

Mngmt Get M-Bus Value channel 3, instance 1 0-3:24.2.1.255 (@1726)

(974) .logical_name

PASSED

```
<Data>
  <OctetString Value="0003180201FF" />
</Data>
```

(975) .value

PASSED

```
<Data>
  <DoubleLongUnsigned Value="00000000" />
</Data>
```

(976) .scaler_unit

PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="00" />
    <Enum Value="00" />
  </Structure>
</Data>
```

(977) .status

PASSED

```
<Data>
  <Unsigned Value="00" />
</Data>
```

(978) .capture_time

PASSED

```
<Data>
  <OctetString Value="FFFFFFFFFFFFFFFF008000FF" />
</Data>
```

Mngmt Get M-Bus Value channel 3, instance 2 0-3:24.2.2.255 (@1734)

(979) .logical_name

PASSED

```
<Data>
  <OctetString Value="0003180202FF" />
</Data>
```

(980) .value

PASSED

```
<Data>
  <DoubleLongUnsigned Value="00000000" />
</Data>
```

(981) .scaler_unit

PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="00" />
    <Enum Value="00" />
  </Structure>
</Data>
```

(982) .status

PASSED

```
<Data>
  <Unsigned Value="00" />
</Data>
```

```
(983) .capture_time
PASSED
  <Data>
    <OctetString Value="FFFFFFFFFFFFFFFF008000FF" />
  </Data>

Mngmt Get M-Bus Value channel 3, instance 3 0-3:24.2.3.255 (@1742)
(984) .logical_name
PASSED
  <Data>
    <OctetString Value="0003180203FF" />
  </Data>
(985) .value
PASSED
  <Data>
    <DoubleLongUnsigned Value="00000000" />
  </Data>
(986) .scaler_unit
PASSED
  <Data>
    <Structure Qty="0002" >
      <Integer Value="00" />
      <Enum Value="00" />
    </Structure>
  </Data>
(987) .status
PASSED
  <Data>
    <Unsigned Value="00" />
  </Data>
(988) .capture_time
PASSED
  <Data>
    <OctetString Value="FFFFFFFFFFFFFFFF008000FF" />
  </Data>

Mngmt Get M-Bus Value channel 3, instance 4 0-3:24.2.4.255 (@1750)
(989) .logical_name
PASSED
  <Data>
    <OctetString Value="0003180204FF" />
  </Data>
(990) .value
PASSED
  <Data>
    <DoubleLongUnsigned Value="00000000" />
  </Data>
(991) .scaler_unit
PASSED
  <Data>
    <Structure Qty="0002" >
      <Integer Value="00" />
      <Enum Value="00" />
    </Structure>
```

```
    </Data>
(992) .status
PASSED
    <Data>
        <Unsigned Value="00" />
    </Data>
(993) .capture_time
PASSED
    <Data>
        <OctetString Value="FFFFFFFFFFFFFFFF008000FF" />
    </Data>

Mngmt Get M-Bus Value channel 4, instance 1 0-4:24.2.1.255 (@1758)
(994) .logical_name
PASSED
    <Data>
        <OctetString Value="0004180201FF" />
    </Data>
(995) .value
PASSED
    <Data>
        <DoubleLongUnsigned Value="00000000" />
    </Data>
(996) .scaler_unit
PASSED
    <Data>
        <Structure Qty="0002" >
            <Integer Value="00" />
            <Enum Value="00" />
        </Structure>
    </Data>
(997) .status
PASSED
    <Data>
        <Unsigned Value="00" />
    </Data>
(998) .capture_time
PASSED
    <Data>
        <OctetString Value="FFFFFFFFFFFFFFFF008000FF" />
    </Data>

Mngmt Get M-Bus Value channel 4, instance 2 0-4:24.2.2.255 (@1766)
(999) .logical_name
PASSED
    <Data>
        <OctetString Value="0004180202FF" />
    </Data>
(1000) .value
PASSED
    <Data>
        <DoubleLongUnsigned Value="00000000" />
    </Data>
(1001) .scaler_unit
```

PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="00" />
    <Enum Value="00" />
  </Structure>
</Data>
```

(1002) .status

PASSED

```
<Data>
  <Unsigned Value="00" />
</Data>
```

(1003) .capture_time

PASSED

```
<Data>
  <OctetString Value="FFFFFFFFFFFFFFFF008000FF" />
</Data>
```

Mngmt Get M-Bus Value channel 4, instance 3 0-4:24.2.3.255 (@1774)

(1004) .logical_name

PASSED

```
<Data>
  <OctetString Value="0004180203FF" />
</Data>
```

(1005) .value

PASSED

```
<Data>
  <DoubleLongUnsigned Value="00000000" />
</Data>
```

(1006) .scaler_unit

PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="00" />
    <Enum Value="00" />
  </Structure>
</Data>
```

(1007) .status

PASSED

```
<Data>
  <Unsigned Value="00" />
</Data>
```

(1008) .capture_time

PASSED

```
<Data>
  <OctetString Value="FFFFFFFFFFFFFFFF008000FF" />
</Data>
```

Mngmt Get M-Bus Value channel 4, instance 4 0-4:24.2.4.255 (@1782)

(1009) .logical_name

PASSED

```
<Data>
  <OctetString Value="0004180204FF" />
</Data>
```

```
(1010) .value
PASSED
  <Data>
    <DoubleLongUnsigned Value="00000000" />
  </Data>
(1011) .scaler_unit
PASSED
  <Data>
    <Structure Qty="0002" >
      <Integer Value="00" />
      <Enum Value="00" />
    </Structure>
  </Data>
(1012) .status
PASSED
  <Data>
    <Unsigned Value="00" />
  </Data>
(1013) .capture_time
PASSED
  <Data>
    <OctetString Value="FFFFFFFFFFFFFFFF008000FF" />
  </Data>

Mngmt Get M-Bus Device ID 1 channel 1 0-1:96.1.0.255 (@1790)
(1014) .logical_name
PASSED
  <Data>
    <OctetString Value="0001600100FF" />
  </Data>
(1015) .value
PASSED
  <Data>
    <OctetString Value="" />
  </Data>

Mngmt Get M-Bus Device ID 1 channel 2 0-2:96.1.0.255 (@1794)
(1016) .logical_name
PASSED
  <Data>
    <OctetString Value="0002600100FF" />
  </Data>
(1017) .value
PASSED
  <Data>
    <OctetString Value="" />
  </Data>

Mngmt Get M-Bus Device ID 1 channel 3 0-3:96.1.0.255 (@1798)
(1018) .logical_name
PASSED
  <Data>
    <OctetString Value="0003600100FF" />
  </Data>
```

(1019) .value
PASSED

```
<Data>  
  <OctetString Value="" />  
</Data>
```

Mngmt Get M-Bus Device ID 1 channel 4 0-4:96.1.0.255 (@1802)
(1020) .logical_name
PASSED

```
<Data>  
  <OctetString Value="0004600100FF" />  
</Data>
```

(1021) .value
PASSED

```
<Data>  
  <OctetString Value="" />  
</Data>
```

Mngmt Get M-Bus Device ID 2 channel 1 0-1:96.1.1.255 (@1806)
(1022) .logical_name
PASSED

```
<Data>  
  <OctetString Value="0001600101FF" />  
</Data>
```

(1023) .value
PASSED

```
<Data>  
  <OctetString Value="" />  
</Data>
```

Mngmt Get M-Bus Device ID 2 channel 2 0-2:96.1.1.255 (@1810)
(1024) .logical_name
PASSED

```
<Data>  
  <OctetString Value="0002600101FF" />  
</Data>
```

(1025) .value
PASSED

```
<Data>  
  <OctetString Value="" />  
</Data>
```

Mngmt Get M-Bus Device ID 2 channel 3 0-3:96.1.1.255 (@1814)
(1026) .logical_name
PASSED

```
<Data>  
  <OctetString Value="0003600101FF" />  
</Data>
```

(1027) .value
PASSED

```
<Data>  
  <OctetString Value="" />  
</Data>
```


Mngmt Get M-Bus Device ID 2 channel 4 0-4:96.1.1.255 (@1818)
(1028) .logical_name

PASSED

```
<Data>
  <OctetString Value="0004600101FF" />
</Data>
```

(1029) .value

PASSED

```
<Data>
  <OctetString Value="" />
</Data>
```

Mngmt Get Profile status for M-Bus Master Load profile 1 0-1:96.10.3.255
(@1822)

(1030) .logical_name

PASSED

```
<Data>
  <OctetString Value="0001600A03FF" />
</Data>
```

(1031) .status

PASSED

```
<Data>
  <Unsigned Value="00" />
</Data>
```

Mngmt Get Profile status for M-Bus Master Load profile 2 0-2:96.10.3.255
(@1826)

(1032) .logical_name

PASSED

```
<Data>
  <OctetString Value="0002600A03FF" />
</Data>
```

(1033) .status

PASSED

```
<Data>
  <Unsigned Value="00" />
</Data>
```

Mngmt Get Profile status for M-Bus Master Load profile 3 0-3:96.10.3.255
(@1830)

(1034) .logical_name

PASSED

```
<Data>
  <OctetString Value="0003600A03FF" />
</Data>
```

(1035) .status

PASSED

```
<Data>
  <Unsigned Value="00" />
</Data>
```

Mngmt Get Profile status for M-Bus Master Load profile 4 0-4:96.10.3.255
(@1834)

(1036) .logical_name

PASSED

```
<Data>
  <OctetString Value="0004600A03FF" />
</Data>
```

(1037) .status

PASSED

```
<Data>
  <Unsigned Value="00" />
</Data>
```

Mngmt Get M-Bus Master Load profile for channel 1 0-1:24.3.0.255 (@1838)

(1038) .logical_name

PASSED

```
<Data>
  <OctetString Value="0001180300FF" />
</Data>
```

(1039) .capture_objects

PASSED

```
<Data>
  <Array Qty="0006" >
    <Structure Qty="0004" >
      <LongUnsigned Value="0008" />
      <OctetString Value="0000010000FF" />
      <Integer Value="02" />
      <LongUnsigned Value="0000" />
    </Structure>
    <Structure Qty="0004" >
      <LongUnsigned Value="0001" />
      <OctetString Value="0001600A03FF" />
      <Integer Value="02" />
      <LongUnsigned Value="0000" />
    </Structure>
    <Structure Qty="0004" >
      <LongUnsigned Value="0004" />
      <OctetString Value="0001180201FF" />
      <Integer Value="02" />
      <LongUnsigned Value="0000" />
    </Structure>
    <Structure Qty="0004" >
      <LongUnsigned Value="0004" />
      <OctetString Value="0001180202FF" />
      <Integer Value="02" />
      <LongUnsigned Value="0000" />
    </Structure>
    <Structure Qty="0004" >
      <LongUnsigned Value="0004" />
      <OctetString Value="0001180203FF" />
      <Integer Value="02" />
      <LongUnsigned Value="0000" />
    </Structure>
    <Structure Qty="0004" >
      <LongUnsigned Value="0004" />
      <OctetString Value="0001180204FF" />
      <Integer Value="02" />
    </Structure>
```

```

                <LongUnsigned Value="0000" />
            </Structure>
        </Array>
    </Data>
(1040) .capture_period
PASSED
    <Data>
        <DoubleLongUnsigned Value="00000E10" />
    </Data>
(1041) .sort_method
PASSED
    <Data>
        <Enum Value="01" />
    </Data>
(1042) .sort_object
PASSED
    <Data>
        <Structure Qty="0004" >
            <LongUnsigned Value="0008" />
            <OctetString Value="0000010000FF" />
            <Integer Value="02" />
            <LongUnsigned Value="0000" />
        </Structure>
    </Data>
(1043) .entries_in_use
PASSED
    <Data>
        <DoubleLongUnsigned Value="00000007" />
    </Data>
(1044) .profile_entries
PASSED
    <Data>
        <DoubleLongUnsigned Value="000000F0" />
    </Data>

Mngmt Get M-Bus Master Load profile for channel 2 0-2:24.3.0.255 (@1849)
(1045) .logical_name
PASSED
    <Data>
        <OctetString Value="0002180300FF" />
    </Data>
(1046) .capture_objects
PASSED
    <Data>
        <Array Qty="0006" >
            <Structure Qty="0004" >
                <LongUnsigned Value="0008" />
                <OctetString Value="0000010000FF" />
                <Integer Value="02" />
                <LongUnsigned Value="0000" />
            </Structure>
            <Structure Qty="0004" >
                <LongUnsigned Value="0001" />
                <OctetString Value="0002600A03FF" />
            </Structure>
        </Array>
    </Data>

```

```

        <Integer Value="02" />
        <LongUnsigned Value="0000" />
    </Structure>
    <Structure Qty="0004" >
        <LongUnsigned Value="0004" />
        <OctetString Value="0002180201FF" />
        <Integer Value="02" />
        <LongUnsigned Value="0000" />
    </Structure>
    <Structure Qty="0004" >
        <LongUnsigned Value="0004" />
        <OctetString Value="0002180202FF" />
        <Integer Value="02" />
        <LongUnsigned Value="0000" />
    </Structure>
    <Structure Qty="0004" >
        <LongUnsigned Value="0004" />
        <OctetString Value="0002180203FF" />
        <Integer Value="02" />
        <LongUnsigned Value="0000" />
    </Structure>
    <Structure Qty="0004" >
        <LongUnsigned Value="0004" />
        <OctetString Value="0002180204FF" />
        <Integer Value="02" />
        <LongUnsigned Value="0000" />
    </Structure>
</Array>
</Data>
(1047) .capture_period
PASSED
    <Data>
        <DoubleLongUnsigned Value="00000E10" />
    </Data>
(1048) .sort_method
PASSED
    <Data>
        <Enum Value="01" />
    </Data>
(1049) .sort_object
PASSED
    <Data>
        <Structure Qty="0004" >
            <LongUnsigned Value="0008" />
            <OctetString Value="0000010000FF" />
            <Integer Value="02" />
            <LongUnsigned Value="0000" />
        </Structure>
    </Data>
(1050) .entries_in_use
PASSED
    <Data>
        <DoubleLongUnsigned Value="00000007" />
    </Data>

```

(1051) .profile_entries
PASSED

```
<Data>  
  <DoubleLongUnsigned Value="000000F0" />  
</Data>
```

Mngmt Get M-Bus Master Load profile for channel 3 0-3:24.3.0.255 (@1860)

(1052) .logical_name
PASSED

```
<Data>  
  <OctetString Value="0003180300FF" />  
</Data>
```

(1053) .capture_objects
PASSED

```
<Data>  
  <Array Qty="0006" >  
    <Structure Qty="0004" >  
      <LongUnsigned Value="0008" />  
      <OctetString Value="0000010000FF" />  
      <Integer Value="02" />  
      <LongUnsigned Value="0000" />  
    </Structure>  
    <Structure Qty="0004" >  
      <LongUnsigned Value="0001" />  
      <OctetString Value="0003600A03FF" />  
      <Integer Value="02" />  
      <LongUnsigned Value="0000" />  
    </Structure>  
    <Structure Qty="0004" >  
      <LongUnsigned Value="0004" />  
      <OctetString Value="0003180201FF" />  
      <Integer Value="02" />  
      <LongUnsigned Value="0000" />  
    </Structure>  
    <Structure Qty="0004" >  
      <LongUnsigned Value="0004" />  
      <OctetString Value="0003180202FF" />  
      <Integer Value="02" />  
      <LongUnsigned Value="0000" />  
    </Structure>  
    <Structure Qty="0004" >  
      <LongUnsigned Value="0004" />  
      <OctetString Value="0003180203FF" />  
      <Integer Value="02" />  
      <LongUnsigned Value="0000" />  
    </Structure>  
    <Structure Qty="0004" >  
      <LongUnsigned Value="0004" />  
      <OctetString Value="0003180204FF" />  
      <Integer Value="02" />  
      <LongUnsigned Value="0000" />  
    </Structure>  
  </Array>  
</Data>
```

(1054) .capture_period
PASSED

```
<Data>  
  <DoubleLongUnsigned Value="00000E10" />  
</Data>
```

(1055) .sort_method
PASSED

```
<Data>  
  <Enum Value="01" />  
</Data>
```

(1056) .sort_object
PASSED

```
<Data>  
  <Structure Qty="0004" >  
    <LongUnsigned Value="0008" />  
    <OctetString Value="0000010000FF" />  
    <Integer Value="02" />  
    <LongUnsigned Value="0000" />  
  </Structure>  
</Data>
```

(1057) .entries_in_use
PASSED

```
<Data>  
  <DoubleLongUnsigned Value="00000007" />  
</Data>
```

(1058) .profile_entries
PASSED

```
<Data>  
  <DoubleLongUnsigned Value="000000F0" />  
</Data>
```

Mngmt Get M-Bus Master Load profile for channel 4 0-4:24.3.0.255 (@1871)

(1059) .logical_name
PASSED

```
<Data>  
  <OctetString Value="0004180300FF" />  
</Data>
```

(1060) .capture_objects
PASSED

```
<Data>  
  <Array Qty="0006" >  
    <Structure Qty="0004" >  
      <LongUnsigned Value="0008" />  
      <OctetString Value="0000010000FF" />  
      <Integer Value="02" />  
      <LongUnsigned Value="0000" />  
    </Structure>  
    <Structure Qty="0004" >  
      <LongUnsigned Value="0001" />  
      <OctetString Value="0004600A03FF" />  
      <Integer Value="02" />  
      <LongUnsigned Value="0000" />  
    </Structure>  
  <Structure Qty="0004" >
```

```

        <LongUnsigned Value="0004" />
        <OctetString Value="0004180201FF" />
        <Integer Value="02" />
        <LongUnsigned Value="0000" />
    </Structure>
</Structure>
<Structure Qty="0004" >
    <LongUnsigned Value="0004" />
    <OctetString Value="0004180202FF" />
    <Integer Value="02" />
    <LongUnsigned Value="0000" />
</Structure>
<Structure Qty="0004" >
    <LongUnsigned Value="0004" />
    <OctetString Value="0004180203FF" />
    <Integer Value="02" />
    <LongUnsigned Value="0000" />
</Structure>
<Structure Qty="0004" >
    <LongUnsigned Value="0004" />
    <OctetString Value="0004180204FF" />
    <Integer Value="02" />
    <LongUnsigned Value="0000" />
</Structure>
</Array>
</Data>
(1061) .capture_period
PASSED
    <Data>
        <DoubleLongUnsigned Value="00000E10" />
    </Data>
(1062) .sort_method
PASSED
    <Data>
        <Enum Value="01" />
    </Data>
(1063) .sort_object
PASSED
    <Data>
        <Structure Qty="0004" >
            <LongUnsigned Value="0008" />
            <OctetString Value="0000010000FF" />
            <Integer Value="02" />
            <LongUnsigned Value="0000" />
        </Structure>
    </Data>
(1064) .entries_in_use
PASSED
    <Data>
        <DoubleLongUnsigned Value="00000007" />
    </Data>
(1065) .profile_entries
PASSED
    <Data>
        <DoubleLongUnsigned Value="000000F0" />

```

</Data>

Mngmt Get M-Bus Master Disconnect control object 1 0-1:24.4.0.255 (@1882)
(1066) .logical_name

PASSED

<Data>
 <OctetString Value="0001180400FF" />
</Data>

(1067) .output_state

PASSED

<Data>
 <Boolean Value="00" />
</Data>

(1068) .control_state

PASSED

<Data>
 <Enum Value="02" />
</Data>

(1069) .control_mode

PASSED

<Data>
 <Enum Value="05" />
</Data>

Mngmt Get M-Bus Master Disconnect control object 2 0-2:24.4.0.255 (@1890)
(1070) .logical_name

PASSED

<Data>
 <OctetString Value="0002180400FF" />
</Data>

(1071) .output_state

PASSED

<Data>
 <Boolean Value="00" />
</Data>

(1072) .control_state

PASSED

<Data>
 <Enum Value="02" />
</Data>

(1073) .control_mode

PASSED

<Data>
 <Enum Value="05" />
</Data>

Mngmt Get M-Bus Master Disconnect control object 3 0-3:24.4.0.255 (@1898)
(1074) .logical_name

PASSED

<Data>
 <OctetString Value="0003180400FF" />
</Data>

(1075) .output_state

PASSED


```
    <Data>
      <Boolean Value="00" />
    </Data>
```

(1076) .control_state
PASSED

```
    <Data>
      <Enum Value="02" />
    </Data>
```

(1077) .control_mode
PASSED

```
    <Data>
      <Enum Value="05" />
    </Data>
```

Mngmt Get M-Bus Master Disconnect control object 4 0-4:24.4.0.255 (@1906)

(1078) .logical_name
PASSED

```
    <Data>
      <OctetString Value="0004180400FF" />
    </Data>
```

(1079) .output_state
PASSED

```
    <Data>
      <Boolean Value="01" />
    </Data>
```

(1080) .control_state
PASSED

```
    <Data>
      <Enum Value="01" />
    </Data>
```

(1081) .control_mode
PASSED

```
    <Data>
      <Enum Value="05" />
    </Data>
```

Mngmt Get M-Bus Disconnect control scheduler 0-1:15.0.1.255 (@1914)

(1082) .logical_name
PASSED

```
    <Data>
      <OctetString Value="00010F0001FF" />
    </Data>
```

(1083) .executed_script
PASSED

```
    <Data>
      <Structure Qty="0002" >
        <OctetString Value="00010A006AFF" />
        <LongUnsigned Value="0001" />
      </Structure>
    </Data>
```

(1084) .type
PASSED

```
    <Data>
      <Enum Value="01" />
```

```
</Data>
(1085) .execution_time
PASSED
```

```
<Data>
  <Array Qty="0000" >
  </Array>
</Data>
```

```
Mngmt Get M-Bus Disconnecter script table 0-1:10.0.106.255 (@1920)
(1086) .logical_name
PASSED
```

```
<Data>
  <OctetString Value="00010A006AFF" />
</Data>
```

```
(1087) .scripts
PASSED
```

```
<_Data>
  <Array Qty="0010" >
    <Structure Qty="0002" >
      <LongUnsigned Value="0001" />
      <Array Qty="0001" >
        <Structure Qty="0005" >
          <Enum Value="01" />
          <LongUnsigned Value="0046" />
          <OctetString Value="0001180400FF" />
          <Integer Value="03" />
          <Enum Value="02" />
        </Structure>
      </Array>
    </Structure>
    <Structure Qty="0002" >
      <LongUnsigned Value="0002" />
      <Array Qty="0001" >
        <Structure Qty="0005" >
          <Enum Value="01" />
          <LongUnsigned Value="0046" />
          <OctetString Value="0001180400FF" />
          <Integer Value="03" />
          <Enum Value="01" />
        </Structure>
      </Array>
    </Structure>
    <Structure Qty="0002" >
      <LongUnsigned Value="0003" />
      <Array Qty="0001" >
        <Structure Qty="0005" >
          <Enum Value="01" />
          <LongUnsigned Value="0046" />
          <OctetString Value="0002180400FF" />
          <Integer Value="03" />
          <Enum Value="02" />
        </Structure>
      </Array>
    </Structure>
  </Array>
</_Data>
```

```

<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <Array Qty="0001" >
    <Structure Qty="0005" >
      <Enum Value="01" />
      <LongUnsigned Value="0046" />
      <OctetString Value="0002180400FF" />
      <Integer Value="03" />
      <Enum Value="01" />
    </Structure>
  </Array>
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0005" />
  <Array Qty="0001" >
    <Structure Qty="0005" >
      <Enum Value="01" />
      <LongUnsigned Value="0046" />
      <OctetString Value="0003180400FF" />
      <Integer Value="03" />
      <Enum Value="02" />
    </Structure>
  </Array>
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0006" />
  <Array Qty="0001" >
    <Structure Qty="0005" >
      <Enum Value="01" />
      <LongUnsigned Value="0046" />
      <OctetString Value="0003180400FF" />
      <Integer Value="03" />
      <Enum Value="01" />
    </Structure>
  </Array>
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0007" />
  <Array Qty="0001" >
    <Structure Qty="0005" >
      <Enum Value="01" />
      <LongUnsigned Value="0046" />
      <OctetString Value="0004180400FF" />
      <Integer Value="03" />
      <Enum Value="02" />
    </Structure>
  </Array>
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0008" />
  <Array Qty="0001" >
    <Structure Qty="0005" >
      <Enum Value="01" />
      <LongUnsigned Value="0046" />

```

```
        <OctetString Value="0004180400FF" />
        <Integer Value="03" />
        <Enum Value="01" />
    </Structure>
</Array>
</Structure>
<Structure Qty="0002" >
    <LongUnsigned Value="0009" />
    <Array Qty="0001" >
        <Structure Qty="0005" >
            <Enum Value="02" />
            <LongUnsigned Value="0046" />
            <OctetString Value="0001180400FF" />
            <Integer Value="01" />
            <Integer Value="00" />
        </Structure>
    </Array>
</Structure>
<Structure Qty="0002" >
    <LongUnsigned Value="000A" />
    <Array Qty="0001" >
        <Structure Qty="0005" >
            <Enum Value="02" />
            <LongUnsigned Value="0046" />
            <OctetString Value="0001180400FF" />
            <Integer Value="02" />
            <Integer Value="00" />
        </Structure>
    </Array>
</Structure>
<Structure Qty="0002" >
    <LongUnsigned Value="000B" />
    <Array Qty="0001" >
        <Structure Qty="0005" >
            <Enum Value="02" />
            <LongUnsigned Value="0046" />
            <OctetString Value="0002180400FF" />
            <Integer Value="01" />
            <Integer Value="00" />
        </Structure>
    </Array>
</Structure>
<Structure Qty="0002" >
    <LongUnsigned Value="000C" />
    <Array Qty="0001" >
        <Structure Qty="0005" >
            <Enum Value="02" />
            <LongUnsigned Value="0046" />
            <OctetString Value="0002180400FF" />
            <Integer Value="02" />
            <Integer Value="00" />
        </Structure>
    </Array>
</Structure>
```

```

<Structure Qty="0002" >
  <LongUnsigned Value="000D" />
  <Array Qty="0001" >
    <Structure Qty="0005" >
      <Enum Value="02" />
      <LongUnsigned Value="0046" />
      <OctetString Value="0003180400FF" />
      <Integer Value="01" />
      <Integer Value="00" />
    </Structure>
  </Array>
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="000E" />
  <Array Qty="0001" >
    <Structure Qty="0005" >
      <Enum Value="02" />
      <LongUnsigned Value="0046" />
      <OctetString Value="0003180400FF" />
      <Integer Value="02" />
      <Integer Value="00" />
    </Structure>
  </Array>
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="000F" />
  <Array Qty="0001" >
    <Structure Qty="0005" >
      <Enum Value="02" />
      <LongUnsigned Value="0046" />
      <OctetString Value="0004180400FF" />
      <Integer Value="01" />
      <Integer Value="00" />
    </Structure>
  </Array>
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0010" />
  <Array Qty="0001" >
    <Structure Qty="0005" >
      <Enum Value="02" />
      <LongUnsigned Value="0046" />
      <OctetString Value="0004180400FF" />
      <Integer Value="02" />
      <Integer Value="00" />
    </Structure>
  </Array>
</Structure>
</Array>
</_Data>

```

Mngmt Get Event Objects - M-Bus Master Control logs 1 0-1:96.11.4.255 (@1925)
(1088) .logical_name
PASSED

```
    <Data>
      <OctetString Value="0001600B04FF" />
    </Data>
```

(1089) .value

PASSED

```
    <Data>
      <Enum Value="A1" />
    </Data>
```

Mngmt Get Event Objects - M-Bus Master Control logs 2 0-2:96.11.4.255 (@1929)

(1090) .logical_name

PASSED

```
    <Data>
      <OctetString Value="0002600B04FF" />
    </Data>
```

(1091) .value

PASSED

```
    <Data>
      <Enum Value="AB" />
    </Data>
```

Mngmt Get Event Objects - M-Bus Master Control logs 3 0-3:96.11.4.255 (@1933)

(1092) .logical_name

PASSED

```
    <Data>
      <OctetString Value="0003600B04FF" />
    </Data>
```

(1093) .value

PASSED

```
    <Data>
      <Enum Value="B5" />
    </Data>
```

Mngmt Get Event Objects - M-Bus Master Control logs 4 0-4:96.11.4.255 (@1937)

(1094) .logical_name

PASSED

```
    <Data>
      <OctetString Value="0004600B04FF" />
    </Data>
```

(1095) .value

PASSED

```
    <Data>
      <Enum Value="BF" />
    </Data>
```

Mngmt Get M-Bus Master Control log object 1 0-1:24.5.0.255 (@1941)

(1096) .logical_name

PASSED

```
    <Data>
      <OctetString Value="0001180500FF" />
    </Data>
```

(1097) .capture_objects

PASSED

```
    <Data>
```

```

    <Array Qty="0002" >
      <Structure Qty="0004" >
        <LongUnsigned Value="0008" />
        <OctetString Value="0000010000FF" />
        <Integer Value="02" />
        <LongUnsigned Value="0000" />
      </Structure>
      <Structure Qty="0004" >
        <LongUnsigned Value="0001" />
        <OctetString Value="0001600B04FF" />
        <Integer Value="02" />
        <LongUnsigned Value="0000" />
      </Structure>
    </Array>
  </Data>
(1098) .capture_period
PASSED
  <Data>
    <DoubleLongUnsigned Value="00000000" />
  </Data>
(1099) .sort_method
PASSED
  <Data>
    <Enum Value="01" />
  </Data>
(1100) .sort_object
PASSED
  <Data>
    <Structure Qty="0004" >
      <LongUnsigned Value="0008" />
      <OctetString Value="0000010000FF" />
      <Integer Value="02" />
      <LongUnsigned Value="0000" />
    </Structure>
  </Data>
(1101) .entries_in_use
PASSED
  <Data>
    <DoubleLongUnsigned Value="00000005" />
  </Data>
(1102) .profile_entries
PASSED
  <Data>
    <DoubleLongUnsigned Value="0000000A" />
  </Data>

Mngmt Get M-Bus Master Control log object 2 0-2:24.5.0.255 (@1952)
(1103) .logical_name
PASSED
  <Data>
    <OctetString Value="0002180500FF" />
  </Data>
(1104) .capture_objects
PASSED

```

```

<Data>
  <Array Qty="0002" >
    <Structure Qty="0004" >
      <LongUnsigned Value="0008" />
      <OctetString Value="0000010000FF" />
      <Integer Value="02" />
      <LongUnsigned Value="0000" />
    </Structure>
    <Structure Qty="0004" >
      <LongUnsigned Value="0001" />
      <OctetString Value="0002600B04FF" />
      <Integer Value="02" />
      <LongUnsigned Value="0000" />
    </Structure>
  </Array>
</Data>
(1105) .capture_period
PASSED
<Data>
  <DoubleLongUnsigned Value="00000000" />
</Data>
(1106) .sort_method
PASSED
<Data>
  <Enum Value="01" />
</Data>
(1107) .sort_object
PASSED
<Data>
  <Structure Qty="0004" >
    <LongUnsigned Value="0008" />
    <OctetString Value="0000010000FF" />
    <Integer Value="02" />
    <LongUnsigned Value="0000" />
  </Structure>
</Data>
(1108) .entries_in_use
PASSED
<Data>
  <DoubleLongUnsigned Value="00000005" />
</Data>
(1109) .profile_entries
PASSED
<Data>
  <DoubleLongUnsigned Value="0000000A" />
</Data>

Mngmt Get M-Bus Master Control log object 3 0-3:24.5.0.255 (@1963)
(1110) .logical_name
PASSED
<Data>
  <OctetString Value="0003180500FF" />
</Data>
(1111) .capture_objects

```


PASSED

```
<Data>
  <Array Qty="0002" >
    <Structure Qty="0004" >
      <LongUnsigned Value="0008" />
      <OctetString Value="0000010000FF" />
      <Integer Value="02" />
      <LongUnsigned Value="0000" />
    </Structure>
    <Structure Qty="0004" >
      <LongUnsigned Value="0001" />
      <OctetString Value="0003600B04FF" />
      <Integer Value="02" />
      <LongUnsigned Value="0000" />
    </Structure>
  </Array>
</Data>
```

(1112) .capture_period

PASSED

```
<Data>
  <DoubleLongUnsigned Value="00000000" />
</Data>
```

(1113) .sort_method

PASSED

```
<Data>
  <Enum Value="01" />
</Data>
```

(1114) .sort_object

PASSED

```
<Data>
  <Structure Qty="0004" >
    <LongUnsigned Value="0008" />
    <OctetString Value="0000010000FF" />
    <Integer Value="02" />
    <LongUnsigned Value="0000" />
  </Structure>
</Data>
```

(1115) .entries_in_use

PASSED

```
<Data>
  <DoubleLongUnsigned Value="00000005" />
</Data>
```

(1116) .profile_entries

PASSED

```
<Data>
  <DoubleLongUnsigned Value="0000000A" />
</Data>
```

Mngmt Get M-Bus Master Control log object 4 0-4:24.5.0.255 (@1974)

(1117) .logical_name

PASSED

```
<Data>
  <OctetString Value="0004180500FF" />
</Data>
```

(1118) .capture_objects
PASSED

```
<Data>
  <Array Qty="0002" >
    <Structure Qty="0004" >
      <LongUnsigned Value="0008" />
      <OctetString Value="0000010000FF" />
      <Integer Value="02" />
      <LongUnsigned Value="0000" />
    </Structure>
    <Structure Qty="0004" >
      <LongUnsigned Value="0001" />
      <OctetString Value="0004600B04FF" />
      <Integer Value="02" />
      <LongUnsigned Value="0000" />
    </Structure>
  </Array>
</Data>
```

(1119) .capture_period
PASSED

```
<Data>
  <DoubleLongUnsigned Value="00000000" />
</Data>
```

(1120) .sort_method
PASSED

```
<Data>
  <Enum Value="01" />
</Data>
```

(1121) .sort_object
PASSED

```
<Data>
  <Structure Qty="0004" >
    <LongUnsigned Value="0008" />
    <OctetString Value="0000010000FF" />
    <Integer Value="02" />
    <LongUnsigned Value="0000" />
  </Structure>
</Data>
```

(1122) .entries_in_use
PASSED

```
<Data>
  <DoubleLongUnsigned Value="00000005" />
</Data>
```

(1123) .profile_entries
PASSED

```
<Data>
  <DoubleLongUnsigned Value="0000000A" />
</Data>
```

Mngmt Get Event Object - M-Bus Event Log 0-0:96.11.3.255 (@1985)

(1124) .logical_name
PASSED

```
<Data>
  <OctetString Value="0000600B03FF" />
```

```
    </Data>
(1125) .value
PASSED
    <Data>
      <Enum Value="87" />
    </Data>

Mngmt Get M-Bus Event Log 0-0:99.98.3.255 (@1989)
(1126) .logical_name
PASSED
    <Data>
      <OctetString Value="0000636203FF" />
    </Data>
(1127) .capture_objects
PASSED
    <Data>
      <Array Qty="0002" >
        <Structure Qty="0004" >
          <LongUnsigned Value="0008" />
          <OctetString Value="0000010000FF" />
          <Integer Value="02" />
          <LongUnsigned Value="0000" />
        </Structure>
        <Structure Qty="0004" >
          <LongUnsigned Value="0001" />
          <OctetString Value="0000600B03FF" />
          <Integer Value="02" />
          <LongUnsigned Value="0000" />
        </Structure>
      </Array>
    </Data>
(1128) .capture_period
PASSED
    <Data>
      <DoubleLongUnsigned Value="00000000" />
    </Data>
(1129) .sort_method
PASSED
    <Data>
      <Enum Value="01" />
    </Data>
(1130) .sort_object
PASSED
    <Data>
      <Structure Qty="0004" >
        <LongUnsigned Value="0008" />
        <OctetString Value="0000010000FF" />
        <Integer Value="02" />
        <LongUnsigned Value="0000" />
      </Structure>
    </Data>
(1131) .entries_in_use
PASSED
    <Data>
```

```
        <DoubleLongUnsigned Value="00000009" />
    </Data>
(1132) .profile_entries
PASSED
    <Data>
        <DoubleLongUnsigned Value="0000000A" />
    </Data>

Mngmt Get IEC local port setup - IEC Optical port 0-0:20.0.0.255 (@2001)
(1133) .logical_name
PASSED
    <Data>
        <OctetString Value="0000140000FF" />
    </Data>
(1134) .default_mode
PASSED
    <Data>
        <Enum Value="01" />
    </Data>
(1135) .default_baud
PASSED
    <Data>
        <Enum Value="05" />
    </Data>
(1136) .prop_baud
PASSED
    <Data>
        <Enum Value="05" />
    </Data>
(1137) .response_time
PASSED
    <Data>
        <Enum Value="00" />
    </Data>
(1138) .device_addr
PASSED
    <Data>
        <OctetString Value="\12000016" />
    </Data>

Mngmt Get IEC HDLC setup - HDLC Optical port 0-0:22.0.0.255 (@2012)
(1139) .logical_name
PASSED
    <Data>
        <OctetString Value="0000160000FF" />
    </Data>
(1140) .comm_speed
PASSED
    <Data>
        <Enum Value="05" />
    </Data>
(1141) .window_size_transmit
PASSED
    <Data>
```

```
        <Unsigned Value="01" />
    </Data>
(1142) .window_size_receive
PASSED
    <Data>
        <Unsigned Value="01" />
    </Data>
(1143) .max_info_field_lenght_transmit
PASSED
    <Data>
        <LongUnsigned Value="00F2" />
    </Data>
(1144) .max_info_field_lenght_receive
PASSED
    <Data>
        <LongUnsigned Value="00F2" />
    </Data>
(1145) .inter_octet_time_out
PASSED
    <Data>
        <LongUnsigned Value="0019" />
    </Data>
(1146) .inactivity_time_out
PASSED
    <Data>
        <LongUnsigned Value="0078" />
    </Data>
(1147) .device_address
PASSED
    <Data>
        <LongUnsigned Value="0015" />
    </Data>

Mngmt Get TCP-UDP setup 0-0:25.0.0.255 (@2024)
(1148) .logical_name
PASSED
    <Data>
        <OctetString Value="0000190000FF" />
    </Data>
(1149) .TCP-UDP_port
PASSED
    <Data>
        <LongUnsigned Value="F0B0" />
    </Data>
(1150) .IP_reference
PASSED
    <Data>
        <OctetString Value="0000190700FF" />
    </Data>
(1151) .MSS
PASSED
    <Data>
        <LongUnsigned Value="0500" />
    </Data>
```

(1152) .nb_of_sim_conn
PASSED

```
<Data>  
  <Unsigned Value="01" />  
</Data>
```

(1153) .inactivity_time_out
PASSED

```
<Data>  
  <LongUnsigned Value="00B4" />  
</Data>
```

Mngmt Get IPv4 setup 0-0:25.1.0.255 (@2032)

(1154) .logical_name
INAPPLICABLE

Object is not required according to OM and/or extensions

(1155) .DL_reference
INAPPLICABLE

Object is not required according to OM and/or extensions

(1156) .IP_address
INAPPLICABLE

Object is not required according to OM and/or extensions

(1157) .multicast_IP_address
INAPPLICABLE

Object is not required according to OM and/or extensions

(1158) .IP_options
INAPPLICABLE

Object is not required according to OM and/or extensions

(1159) .subnet_mask
INAPPLICABLE

Object is not required according to OM and/or extensions

(1160) .gateway_IP_address
INAPPLICABLE

Object is not required according to OM and/or extensions

(1161) .use_DHCP_flag
INAPPLICABLE

Object is not required according to OM and/or extensions

(1162) .primary_DNS_address
INAPPLICABLE

Object is not required according to OM and/or extensions

(1163) .secondary_DNS_address
INAPPLICABLE

Object is not required according to OM and/or extensions

Mngmt Get IPv6 setup 0-0:25.7.0.255 (@2047)

(1164) .logical_name
PASSED

```
<Data>  
  <OctetString Value="0000190700FF" />  
</Data>
```

(1165) .DL_reference
PASSED

```
<Data>  
  <OctetString Value="0000190200FF" />  
</Data>
```

```

(1166) .address_config_mode
PASSED
  <Data>
    <Enum Value="00" />
  </Data>
(1167) .unicast_IPv6_addresses
PASSED
  <Data>
    <Array Qty="0002" >
      <OctetString Value="FE80000000000000781D00FFFE000001" />
      <OctetString Value="FFFFFFFFFFFFFFFFFFFFFFFFFFFFFFFF" />
    </Array>
  </Data>
(1168) .multicast_IPv6_addresses
PASSED
  <Data>
    <Array Qty="0000" >
    </Array>
  </Data>
(1169) .gateway_IPv6_address
PASSED
  <Data>
    <Array Qty="0000" >
    </Array>
  </Data>
(1170) .primary_DNS_address
PASSED
  <Data>
    <OctetString Value="FE80000000000000781D00FFFE000000" />
  </Data>
(1171) .secondary_DNS_address
PASSED
  <Data>
    <OctetString Value="00000000000000000000000000000000" />
  </Data>
(1172) .traffic_class
PASSED
  <Data>
    <Unsigned Value="00" />
  </Data>
(1173) .neighbor_discovery_setup
PASSED
  <Data>
    <Array Qty="0000" >
    </Array>
  </Data>

```

Mngmt Get PPP setup 0-0:25.3.0.255 (@2061)

```

(1174) .logical_name
INAPPLICABLE
  Object is not required according to OM and/or extensions
(1175) .PHY_refernce
INAPPLICABLE
  Object is not required according to OM and/or extensions

```

(1176) .LCP_options
INAPPLICABLE
Object is not required according to OM and/or extensions
(1177) .IPCP_options
INAPPLICABLE
Object is not required according to OM and/or extensions
(1178) .PPP_authentication
INAPPLICABLE
Object is not required according to OM and/or extensions

Mngmt Get Push setup - Interval_1 0-1:25.9.0.255 (@2069)

(1179) .logical_name
PASSED
<Data>
 <OctetString Value="0001190900FF" />
</Data>
(1180) .push_object_list
PASSED
<Data>
 <Array Qty="0000" >
 </Array>
</Data>
(1181) .send_destination_and_method
PASSED
<Data>
 <Structure Qty="0003" >
 <Enum Value="01" />
 <OctetString Value="\[fe80:0:0:0:781d:ff:fe00:0]:61616" />
 <Enum Value="00" />
 </Structure>
</Data>
(1182) .communication_window
PASSED
<Data>
 <Array Qty="0000" >
 </Array>
</Data>
(1183) .randomisation_start_interval
PASSED
<Data>
 <LongUnsigned Value="0000" />
</Data>
(1184) .number_of_retries
PASSED
<Data>
 <Unsigned Value="00" />
</Data>
(1185) .repetition_delay
PASSED
<Data>
 <LongUnsigned Value="0000" />
</Data>

Mngmt Get Push setup - Interval_2 0-2:25.9.0.255 (@2079)


```
(1186) .logical_name
PASSED
  <Data>
    <OctetString Value="0002190900FF" />
  </Data>
(1187) .push_object_list
PASSED
  <Data>
    <Array Qty="0000" >
    </Array>
  </Data>
(1188) .send_destination_and_method
PASSED
  <Data>
    <Structure Qty="0003" >
      <Enum Value="01" />
      <OctetString Value="\[fe80:0:0:0:781d:ff:fe00:0]:61616" />
      <Enum Value="00" />
    </Structure>
  </Data>
(1189) .communication_window
PASSED
  <Data>
    <Array Qty="0000" >
    </Array>
  </Data>
(1190) .randomisation_start_interval
PASSED
  <Data>
    <LongUnsigned Value="0000" />
  </Data>
(1191) .number_of_retries
PASSED
  <Data>
    <Unsigned Value="00" />
  </Data>
(1192) .repetition_delay
PASSED
  <Data>
    <LongUnsigned Value="0000" />
  </Data>

Mngmt Get Push setup - Interval_3 0-3:25.9.0.255 (@2089)
(1193) .logical_name
PASSED
  <Data>
    <OctetString Value="0003190900FF" />
  </Data>
(1194) .push_object_list
PASSED
  <Data>
    <Array Qty="0000" >
    </Array>
  </Data>
```

```

(1195) .send_destination_and_method
PASSED
  <Data>
    <Structure Qty="0003" >
      <Enum Value="01" />
      <OctetString Value="\[fe80:0:0:0:781d:ff:fe00:0]:61616" />
      <Enum Value="00" />
    </Structure>
  </Data>
(1196) .communication_window
PASSED
  <Data>
    <Array Qty="0000" >
    </Array>
  </Data>
(1197) .randomisation_start_interval
PASSED
  <Data>
    <LongUnsigned Value="0000" />
  </Data>
(1198) .number_of_retries
PASSED
  <Data>
    <Unsigned Value="00" />
  </Data>
(1199) .repetition_delay
PASSED
  <Data>
    <LongUnsigned Value="0000" />
  </Data>

Mngmt Get Push setup - On Alarm 0-4:25.9.0.255 (@2099)
(1200) .logical_name
PASSED
  <Data>
    <OctetString Value="0004190900FF" />
  </Data>
(1201) .push_object_list
PASSED
  <Data>
    <Array Qty="0000" >
    </Array>
  </Data>
(1202) .send_destination_and_method
PASSED
  <Data>
    <Structure Qty="0003" >
      <Enum Value="01" />
      <OctetString Value="\[fe80:0:0:0:4400:ff:fe00:0]:61616" />
      <Enum Value="00" />
    </Structure>
  </Data>
(1203) .communication_window
PASSED

```

```

    <Data>
      <Array Qty="0000" >
        </Array>
      </Data>
(1204) .randomisation_start_interval
PASSED
    <Data>
      <LongUnsigned Value="0000" />
    </Data>
(1205) .number_of_retries
PASSED
    <Data>
      <Unsigned Value="00" />
    </Data>
(1206) .repetition_delay
PASSED
    <Data>
      <LongUnsigned Value="0000" />
    </Data>

Mngmt Get Push setup - On Connectivity 0-0:25.9.0.255 (@2109)
(1207) .logical_name
PASSED
    <Data>
      <OctetString Value="0000190900FF" />
    </Data>
(1208) .push_object_list
PASSED
    <Data>
      <Array Qty="0000" >
        </Array>
      </Data>
(1209) .send_destination_and_method
PASSED
    <Data>
      <Structure Qty="0003" >
        <Enum Value="01" />
        <OctetString Value="\[fe80:0:0:0:4400:ff:fe00:0]:61616" />
        <Enum Value="00" />
      </Structure>
    </Data>
(1210) .communication_window
PASSED
    <Data>
      <Array Qty="0000" >
        </Array>
      </Data>
(1211) .randomisation_start_interval
PASSED
    <Data>
      <LongUnsigned Value="0000" />
    </Data>
(1212) .number_of_retries
PASSED

```

```

    <Data>
      <Unsigned Value="00" />
    </Data>
(1213) .repetition_delay
PASSED
    <Data>
      <LongUnsigned Value="0000" />
    </Data>

Mngmt Get Push setup - On Installation 0-7:25.9.0.255 (@2119)
(1214) .logical_name
PASSED
    <Data>
      <OctetString Value="0007190900FF" />
    </Data>
(1215) .push_object_list
PASSED
    <Data>
      <Array Qty="0000" >
        </Array>
    </Data>
(1216) .send_destination_and_method
PASSED
    <Data>
      <Structure Qty="0003" >
        <Enum Value="01" />
        <OctetString Value="\[fe80:0:0:0:4400:ff:fe00:0]:61616" />
        <Enum Value="00" />
      </Structure>
    </Data>
(1217) .communication_window
PASSED
    <Data>
      <Array Qty="0000" >
        </Array>
    </Data>
(1218) .randomisation_start_interval
PASSED
    <Data>
      <LongUnsigned Value="0000" />
    </Data>
(1219) .number_of_retries
PASSED
    <Data>
      <Unsigned Value="00" />
    </Data>
(1220) .repetition_delay
PASSED
    <Data>
      <LongUnsigned Value="0000" />
    </Data>

Mngmt Get Push setup - On Power down 0-5:25.9.0.255 (@2129)
(1221) .logical_name

```

INAPPLICABLE

Optional object is not implemented

(1222) .push_object_list

INAPPLICABLE

Optional object is not implemented

(1223) .send_destination_and_method

INAPPLICABLE

Optional object is not implemented

(1224) .communication_window

INAPPLICABLE

Optional object is not implemented

(1225) .randomisation_start_interval

INAPPLICABLE

Optional object is not implemented

(1226) .number_of_retries

INAPPLICABLE

Optional object is not implemented

(1227) .repetition_delay

INAPPLICABLE

Optional object is not implemented

Mngmt Get Push script table 0-0:10.0.108.255 (@2139)

(1228) .logical_name

PASSED

<Data>

<OctetString Value="00000A006CFF" />

</Data>

(1229) .scripts

PASSED

<_Data>

<Array Qty="0010" >

<Structure Qty="0002" >

<LongUnsigned Value="0001" />

<Array Qty="0001" >

<Structure Qty="0005" >

<Enum Value="02" />

<LongUnsigned Value="0028" />

<OctetString Value="0001190900FF" />

<Integer Value="01" />

<Integer Value="00" />

</Structure>

</Array>

</Structure>

<Structure Qty="0002" >

<LongUnsigned Value="0002" />

<Array Qty="0001" >

<Structure Qty="0005" >

<Enum Value="02" />

<LongUnsigned Value="0028" />

<OctetString Value="0002190900FF" />

<Integer Value="01" />

<Integer Value="00" />

</Structure>

</Array>

```
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <Array Qty="0001" >
    <Structure Qty="0005" >
      <Enum Value="02" />
      <LongUnsigned Value="0028" />
      <OctetString Value="0003190900FF" />
      <Integer Value="01" />
      <Integer Value="00" />
    </Structure>
  </Array>
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <Array Qty="0001" >
    <Structure Qty="0005" >
      <Enum Value="02" />
      <LongUnsigned Value="0028" />
      <OctetString Value="0004190900FF" />
      <Integer Value="01" />
      <Integer Value="00" />
    </Structure>
  </Array>
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0005" />
  <Array Qty="0001" >
    <Structure Qty="0005" >
      <Enum Value="02" />
      <LongUnsigned Value="0028" />
      <OctetString Value="0000190900FF" />
      <Integer Value="01" />
      <Integer Value="00" />
    </Structure>
  </Array>
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0006" />
  <Array Qty="0001" >
    <Structure Qty="0005" >
      <Enum Value="02" />
      <LongUnsigned Value="0028" />
      <OctetString Value="0007190900FF" />
      <Integer Value="01" />
      <Integer Value="00" />
    </Structure>
  </Array>
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0008" />
  <Array Qty="0001" >
    <Structure Qty="0005" >
      <Enum Value="02" />
```

```
        <LongUnsigned Value="0028" />
        <OctetString Value="0006190900FF" />
        <Integer Value="01" />
        <Integer Value="00" />
    </Structure>
</Array>
</Structure>
<Structure Qty="0002" >
    <LongUnsigned Value="0008" />
    <Array Qty="0002" >
        <Structure Qty="0005" >
            <Enum Value="01" />
            <LongUnsigned Value="0007" />
            <OctetString Value="0100630100FF" />
            <Integer Value="07" />
            <DoubleLongUnsigned Value="00000002" />
        </Structure>
        <Structure Qty="0005" >
            <Enum Value="01" />
            <LongUnsigned Value="0012" />
            <OctetString Value="00002C0000FF" />
            <Integer Value="06" />
            <Enum Value="06" />
        </Structure>
    </Array>
</Structure>
<Structure Qty="0002" >
    <LongUnsigned Value="0090" />
    <Array Qty="0002" >
        <Structure Qty="0005" >
            <Enum Value="01" />
            <LongUnsigned Value="0001" />
            <OctetString Value="0000600B05FF" />
            <Integer Value="02" />
            <Enum Value="90" />
        </Structure>
        <Structure Qty="0005" >
            <Enum Value="02" />
            <LongUnsigned Value="0007" />
            <OctetString Value="0000636205FF" />
            <Integer Value="02" />
            <Integer Value="00" />
        </Structure>
    </Array>
</Structure>
<Structure Qty="0002" >
    <LongUnsigned Value="0091" />
    <Array Qty="0002" >
        <Structure Qty="0005" >
            <Enum Value="01" />
            <LongUnsigned Value="0001" />
            <OctetString Value="0000600B05FF" />
            <Integer Value="02" />
            <Enum Value="91" />
        </Structure>
    </Array>
</Structure>
```

```

</Structure>
<Structure Qty="0005" >
  <Enum Value="02" />
  <LongUnsigned Value="0007" />
  <OctetString Value="0000636205FF" />
  <Integer Value="02" />
  <Integer Value="00" />
</Structure>
</Array>
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0092" />
  <Array Qty="0002" >
    <Structure Qty="0005" >
      <Enum Value="01" />
      <LongUnsigned Value="0001" />
      <OctetString Value="0000600B05FF" />
      <Integer Value="02" />
      <Enum Value="92" />
    </Structure>
    <Structure Qty="0005" >
      <Enum Value="02" />
      <LongUnsigned Value="0007" />
      <OctetString Value="0000636205FF" />
      <Integer Value="02" />
      <Integer Value="00" />
    </Structure>
  </Array>
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0093" />
  <Array Qty="0002" >
    <Structure Qty="0005" >
      <Enum Value="01" />
      <LongUnsigned Value="0001" />
      <OctetString Value="0000600B05FF" />
      <Integer Value="02" />
      <Enum Value="93" />
    </Structure>
    <Structure Qty="0005" >
      <Enum Value="02" />
      <LongUnsigned Value="0007" />
      <OctetString Value="0000636205FF" />
      <Integer Value="02" />
      <Integer Value="00" />
    </Structure>
  </Array>
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0094" />
  <Array Qty="0002" >
    <Structure Qty="0005" >
      <Enum Value="01" />
      <LongUnsigned Value="0001" />

```



```
        <OctetString Value="0000600B05FF" />
        <Integer Value="02" />
        <Enum Value="94" />
    </Structure>
    <Structure Qty="0005" >
        <Enum Value="02" />
        <LongUnsigned Value="0007" />
        <OctetString Value="0000636205FF" />
        <Integer Value="02" />
        <Integer Value="00" />
    </Structure>
</Array>
</Structure>
<Structure Qty="0002" >
    <LongUnsigned Value="0097" />
    <Array Qty="0002" >
        <Structure Qty="0005" >
            <Enum Value="01" />
            <LongUnsigned Value="0001" />
            <OctetString Value="0000600B05FF" />
            <Integer Value="02" />
            <Enum Value="97" />
        </Structure>
        <Structure Qty="0005" >
            <Enum Value="02" />
            <LongUnsigned Value="0007" />
            <OctetString Value="0000636205FF" />
            <Integer Value="02" />
            <Integer Value="00" />
        </Structure>
    </Array>
</Structure>
<Structure Qty="0002" >
    <LongUnsigned Value="0098" />
    <Array Qty="0002" >
        <Structure Qty="0005" >
            <Enum Value="01" />
            <LongUnsigned Value="0001" />
            <OctetString Value="0000600B05FF" />
            <Integer Value="02" />
            <Enum Value="98" />
        </Structure>
        <Structure Qty="0005" >
            <Enum Value="02" />
            <LongUnsigned Value="0007" />
            <OctetString Value="0000636205FF" />
            <Integer Value="02" />
            <Integer Value="00" />
        </Structure>
    </Array>
</Structure>
<Structure Qty="0002" >
    <LongUnsigned Value="0099" />
    <Array Qty="0002" >
```

```
        <Structure Qty="0005" >
          <Enum Value="01" />
          <LongUnsigned Value="0001" />
          <OctetString Value="0000600B05FF" />
          <Integer Value="02" />
          <Enum Value="99" />
        </Structure>
        <Structure Qty="0005" >
          <Enum Value="02" />
          <LongUnsigned Value="0007" />
          <OctetString Value="0000636205FF" />
          <Integer Value="02" />
          <Integer Value="00" />
        </Structure>
      </Array>
    </Structure>
  </Array>
</_Data>
```

Mngmt Get Push action scheduler - Interval_1 0-1:15.0.4.255 (@2144)
(1230) .logical_name
PASSED

```
<Data>
  <OctetString Value="00010F0004FF" />
</Data>
```

(1231) .executed_script
PASSED

```
<Data>
  <Structure Qty="0002" >
    <OctetString Value="00000A006CFF" />
    <LongUnsigned Value="0001" />
  </Structure>
</Data>
```

(1232) .type
PASSED

```
<Data>
  <Enum Value="05" />
</Data>
```

(1233) .execution_time
PASSED

```
<Data>
  <Array Qty="0000" >
  </Array>
</Data>
```

Mngmt Get Push action scheduler - Interval_2 0-2:15.0.4.255 (@2150)
(1234) .logical_name
PASSED

```
<Data>
  <OctetString Value="00020F0004FF" />
</Data>
```

(1235) .executed_script
PASSED

```
<Data>
```

```

        <Structure Qty="0002" >
            <OctetString Value="00000A006CFF" />
            <LongUnsigned Value="0002" />
        </Structure>
    </Data>
(1236) .type
PASSED
    <Data>
        <Enum Value="05" />
    </Data>
(1237) .execution_time
PASSED
    <Data>
        <Array Qty="0000" >
        </Array>
    </Data>

Mngmt Get Push action scheduler - Interval_3 0-3:15.0.4.255 (@2156)
(1238) .logical_name
PASSED
    <Data>
        <OctetString Value="00030F0004FF" />
    </Data>
(1239) .executed_script
PASSED
    <Data>
        <Structure Qty="0002" >
            <OctetString Value="00000A006CFF" />
            <LongUnsigned Value="0003" />
        </Structure>
    </Data>
(1240) .type
PASSED
    <Data>
        <Enum Value="05" />
    </Data>
(1241) .execution_time
PASSED
    <Data>
        <Array Qty="0000" >
        </Array>
    </Data>

Mngmt Get Auto connect 0-0:2.1.0.255 (@2163)
(1242) .logical_name
PASSED
    <Data>
        <OctetString Value="0000020100FF" />
    </Data>
(1243) .mode
PASSED
    <Data>
        <Enum Value="65" />
    </Data>

```

(1244) .repetitions
PASSED

```
<Data>  
  <Unsigned Value="00" />  
</Data>
```

(1245) .repetition_delay
PASSED

```
<Data>  
  <LongUnsigned Value="0000" />  
</Data>
```

(1246) .calling_window
PASSED

```
<Data>  
  <Array Qty="0000" >  
  </Array>  
</Data>
```

(1247) .destination_list
PASSED

```
<Data>  
  <Array Qty="0000" >  
  </Array>  
</Data>
```

Mngmt Get MAC address setup 0-0:25.2.0.255 (@2172)

(1248) .logical_name
PASSED

```
<Data>  
  <OctetString Value="0000190200FF" />  
</Data>
```

(1249) .MAC_address
PASSED

```
<Data>  
  <OctetString Value="4D454C6770B71B15" />  
</Data>
```

Mngmt Get GPRS modem setup 0-0:25.4.0.255 (@2177)

(1250) .logical_name
INAPPLICABLE

Object is not required according to OM and/or extensions

(1251) .APN
INAPPLICABLE

Object is not required according to OM and/or extensions

(1252) .PIN_code
INAPPLICABLE

Object is not required according to OM and/or extensions

(1253) .quality_of_service
INAPPLICABLE

Object is not required according to OM and/or extensions

Mngmt Get Modem configuration 0-0:2.0.0.255 (@2183)

(1254) .logical_name
INAPPLICABLE

Object is not required according to OM and/or extensions

(1255) .comm_speed

INAPPLICABLE

Object is not required according to OM and/or extensions
(1256) .initialization_string

INAPPLICABLE

Object is not required according to OM and/or extensions
(1257) .modem_profile

INAPPLICABLE

Object is not required according to OM and/or extensions

Mngmt Get Auto answer 0-0:2.2.0.255 (@2189)

(1258) .logical_name

INAPPLICABLE

Object is not required according to OM and/or extensions
(1259) .mode

INAPPLICABLE

Object is not required according to OM and/or extensions
(1260) .listening_window

INAPPLICABLE

Object is not required according to OM and/or extensions
(1261) .status

INAPPLICABLE

Object is not required according to OM and/or extensions
(1262) .number_of_calls

INAPPLICABLE

Object is not required according to OM and/or extensions
(1263) .number_of_rings

INAPPLICABLE

Object is not required according to OM and/or extensions
(1264) .list_of_allowed_callers

INAPPLICABLE

Object is not required according to OM and/or extensions

Mngmt Get G3-PLC MAC layer counters 0-0:29.0.0.255 (@2199)

(1265) .logical_name

PASSED

<Data>

<OctetString Value="00001D0000FF" />

</Data>

(1266) .mac_Tx_data_packet_count

PASSED

<Data>

<DoubleLongUnsigned Value="000041D3" />

</Data>

(1267) .mac_Rx_data_packet_count

PASSED

<Data>

<DoubleLongUnsigned Value="0000360E" />

</Data>

(1268) .mac_Tx_cmd_packet_count

PASSED

<Data>

<DoubleLongUnsigned Value="000000A8" />

</Data>

(1269) .mac_Rx_cmd_packet_count

```
PASSED
  <Data>
    <DoubleLongUnsigned Value="00000096" />
  </Data>
(1270) .mac_CSMA_fail_count
PASSED
  <Data>
    <DoubleLongUnsigned Value="00000000" />
  </Data>
(1271) .mac_CSMA_no_ACK_count
PASSED
  <Data>
    <DoubleLongUnsigned Value="00000006" />
  </Data>
(1272) .mac_bad_CRC_count
PASSED
  <Data>
    <DoubleLongUnsigned Value="0000009B" />
  </Data>
(1273) .mac_Tx_data_broadcast_count
PASSED
  <Data>
    <DoubleLongUnsigned Value="00000000" />
  </Data>
(1274) .mac_Rx_data_broadcast_count
PASSED
  <Data>
    <DoubleLongUnsigned Value="00000001" />
  </Data>

Mngmt Get G3-PLC MAC setup 0-0:29.1.0.255 (@2212)
(1275) .logical_name
PASSED
  <Data>
    <OctetString Value="00001D0100FF" />
  </Data>
(1276) .mac_short_address
PASSED
  <Data>
    <LongUnsigned Value="0001" />
  </Data>
(1277) .mac_RC_coord
PASSED
  <Data>
    <LongUnsigned Value="7FFF" />
  </Data>
(1278) .mac_PAN_id
PASSED
  <Data>
    <LongUnsigned Value="781D" />
  </Data>
(1279) .mac_frame_counter
PASSED
  <Data>
```



```
PASSED
  <Data>
    <Unsigned Value="0C" />
  </Data>
(1288) .mac_A
PASSED
  <Data>
    <Unsigned Value="08" />
  </Data>
(1289) .mac_K
PASSED
  <Data>
    <Unsigned Value="05" />
  </Data>
(1290) .mac_min_CW_attempts
PASSED
  <Data>
    <Unsigned Value="0A" />
  </Data>
(1291) .mac_cenelec_legacy_mode
PASSED
  <Data>
    <Unsigned Value="01" />
  </Data>
(1292) .mac_FCC_legacy_mode
PASSED
  <Data>
    <Unsigned Value="01" />
  </Data>
(1293) .mac_max_BE
PASSED
  <Data>
    <Unsigned Value="08" />
  </Data>
(1294) .mac_max_CSMA_backoffs
PASSED
  <Data>
    <Unsigned Value="32" />
  </Data>
(1295) .mac_min_BE
PASSED
  <Data>
    <Unsigned Value="03" />
  </Data>

Mngmt Get G3-PLC MAC 6LoWPAN adaptation layer setup 0-0:29.2.0.255 (@2237)
(1296) .logical_name
PASSED
  <Data>
    <OctetString Value="00001D0200FF" />
  </Data>
(1297) .adp_max_hops
PASSED
  <Data>
```



```
        <Unsigned Value="08" />
    </Data>
(1298) .adp_weak_LQI_value
PASSED
    <Data>
        <Unsigned Value="34" />
    </Data>
(1299) .adp_security_level
PASSED
    <Data>
        <Unsigned Value="05" />
    </Data>
(1300) .adp_prefix_table
PASSED
    <Data>
        <Array Qty="0000" >
            </Array>
    </Data>
(1301) .adp_routing_configuration
PASSED
    <Data>
        <Array Qty="0001" >
            <Structure Qty="000E" >
                <Unsigned Value="14" />
                <LongUnsigned Value="0B40" />
                <Unsigned Value="00" />
                <Unsigned Value="00" />
                <Unsigned Value="00" />
                <Unsigned Value="0A" />
                <Unsigned Value="04" />
                <Unsigned Value="00" />
                <Unsigned Value="00" />
                <Unsigned Value="32" />
                <LongUnsigned Value="000A" />
                <Boolean Value="00" />
                <Boolean Value="00" />
                <Unsigned Value="00" />
            </Structure>
        </Array>
    </Data>
(1302) .adp_broadcast_log_table_entry_TTL
PASSED
    <Data>
        <LongUnsigned Value="0002" />
    </Data>
(1303) .adp_routing_table
PASSED
    <Data>
        <Array Qty="0001" >
            <Structure Qty="0006" >
                <LongUnsigned Value="0000" />
                <LongUnsigned Value="0000" />
                <LongUnsigned Value="000B" />
                <Unsigned Value="01" />
            </Structure>
        </Array>
    </Data>
```

```
        <Unsigned Value="00" />
        <LongUnsigned Value="02B7" />
    </Structure>
</Array>
</Data>
(1304) .adp_context_information_table
PASSED
    <Data>
        <Array Qty="0000" >
        </Array>
    </Data>
(1305) .adp_blacklist_table
PASSED
    <Data>
        <Array Qty="0000" >
        </Array>
    </Data>
(1306) .adp_broadcast_log_table
PASSED
    <Data>
        <Array Qty="0000" >
        </Array>
    </Data>
(1307) .adp_group_table
PASSED
    <Data>
        <Array Qty="0001" >
            <LongUnsigned Value="8001" />
        </Array>
    </Data>
(1308) .adp_max_join_wait_time
PASSED
    <Data>
        <LongUnsigned Value="0014" />
    </Data>
(1309) .adp_path_discovery_time
PASSED
    <Data>
        <Unsigned Value="28" />
    </Data>
(1310) .adp_active_key_index
PASSED
    <Data>
        <Unsigned Value="00" />
    </Data>
(1311) .adp_metric_type
PASSED
    <Data>
        <Unsigned Value="0F" />
    </Data>
(1312) .adp_coord_short_address
PASSED
    <Data>
        <LongUnsigned Value="0000" />
```

```
    </Data>
(1313) .adp_disable_default_routing
PASSED
```

```
    <Data>
      <Boolean Value="00" />
    </Data>
```

```
(1314) .adp_device_type
PASSED
```

```
    <Data>
      <Enum Value="00" />
    </Data>
```

```
*****
Test Case 6 : Set mngmt attributes, 325 item(s)
*****
```

```
Mngmt Set Current association 0-0:40.0.0.255 (@9)
```

```
(1) .authentication_mechanism_name
PASSED
```

```
    <Data>
      <Structure Qty="0007" >
        <Unsigned Value="02" />
        <Unsigned Value="10" />
        <LongUnsigned Value="02F4" />
        <Unsigned Value="05" />
        <Unsigned Value="08" />
        <Unsigned Value="02" />
        <Unsigned Value="05" />
      </Structure>
    </Data>
```

```
(2) .secret
PASSED
```

```
    <Data>
      <OctetString Value="\12345678" />
    </Data>
```

```
Mngmt Set Security setup 0-0:43.0.0.255 (@24)
```

```
(3) .security_suite
PASSED
```

```
    <Data>
      <Enum Value="00" />
    </Data>
```

```
Mngmt Set Device ID 2 0-0:96.1.1.255 (@50)
```

```
(4) .value
PASSED
```

```
    <Data>
      <OctetString
Value="4D45543630302D4F4671517A6937372D303030303030000000000000000000" />
    </Data>
```

```
Mngmt Set Device ID 3 0-0:96.1.2.255 (@54)
```

```
(5) .value
PASSED
```

```
<Data>
  <OctetString Value="\          " />
</Data>

Mngmt Set Device ID 4 0-0:96.1.3.255 (@58)
(6) .value
PASSED
  <Data>
    <OctetString Value="\          " />
  </Data>

Mngmt Set Device ID 5 0-0:96.1.4.255 (@62)
(7) .value
PASSED
  <Data>
    <OctetString Value="\          " />
  </Data>

Mngmt Set Clock 0-0:1.0.0.255 (@75)
(8) .time
PASSED
  <Data>
    <OctetString Value="07E60C15030E270D00FFC400" />
  </Data>
(9) .time_zone
PASSED
  <Data>
    <Long Value="FFC4" />
  </Data>
(10) .daylights_savings_begin
PASSED
  <Data>
    <OctetString Value="FFFF03FE07020000008000FF" />
  </Data>
(11) .daylights_savings_end
PASSED
  <Data>
    <OctetString Value="FFFF0AFE07030000008000FF" />
  </Data>
(12) .daylights_savings_deviation
PASSED
  <Data>
    <Integer Value="3C" />
  </Data>
(13) .daylights_savings_enabled
PASSED
  <Data>
    <Boolean Value="01" />
  </Data>

Mngmt Set Clock Time Shift Limit 1-0:0.9.11.255 (@94)
(14) .value
PASSED
  <Data>
```

```
    <Unsigned Value="3C" />
  </Data>
```

Mngmt Set NTP setup 0-0:25.10.0.255 (@100)

(15) .activated

INAPPLICABLE

Optional object is not implemented

(16) .server_address

INAPPLICABLE

Optional object is not implemented

(17) .server_port

INAPPLICABLE

Optional object is not implemented

(18) .authentication_method

INAPPLICABLE

Optional object is not implemented

(19) .authentication_keys

INAPPLICABLE

Optional object is not implemented

(20) .client_key

INAPPLICABLE

Optional object is not implemented

Mngmt Set Activity Calendar 0-0:13.0.0.255 (@112)

(21) .calendar_name_passive

PASSED

```
  <Data>
```

```
    <OctetString Value="\CNP_674F" />
```

```
  </Data>
```

(22) .season_profile_passive

PASSED

```
  <Data>
```

```
    <Array Qty="0004" >
```

```
      <Structure Qty="0003" >
```

```
        <OctetString Value="01" />
```

```
        <OctetString Value="FFFF0101FF000000008000FF" />
```

```
        <OctetString Value="01" />
```

```
      </Structure>
```

```
      <Structure Qty="0003" >
```

```
        <OctetString Value="02" />
```

```
        <OctetString Value="FFFF0102FF000000008000FF" />
```

```
        <OctetString Value="02" />
```

```
      </Structure>
```

```
      <Structure Qty="0003" >
```

```
        <OctetString Value="03" />
```

```
        <OctetString Value="FFFF0103FF000000008000FF" />
```

```
        <OctetString Value="03" />
```

```
      </Structure>
```

```
      <Structure Qty="0003" >
```

```
        <OctetString Value="04" />
```

```
        <OctetString Value="FFFF0104FF000000008000FF" />
```

```
        <OctetString Value="04" />
```

```
      </Structure>
```

```
    </Array>
```

```
</Data>
(23) .week_profile_table_passive
PASSED
<Data>
  <Array Qty="0004" >
    <Structure Qty="0008" >
      <OctetString Value="01" />
      <Unsigned Value="01" />
      <Unsigned Value="01" />
      <Unsigned Value="01" />
      <Unsigned Value="01" />
      <Unsigned Value="01" />
      <Unsigned Value="01" />
      <Unsigned Value="01" />
    </Structure>
    <Structure Qty="0008" >
      <OctetString Value="02" />
      <Unsigned Value="02" />
      <Unsigned Value="02" />
      <Unsigned Value="02" />
      <Unsigned Value="02" />
      <Unsigned Value="02" />
      <Unsigned Value="02" />
      <Unsigned Value="02" />
    </Structure>
    <Structure Qty="0008" >
      <OctetString Value="03" />
      <Unsigned Value="03" />
      <Unsigned Value="03" />
      <Unsigned Value="03" />
      <Unsigned Value="03" />
      <Unsigned Value="03" />
      <Unsigned Value="03" />
      <Unsigned Value="03" />
    </Structure>
    <Structure Qty="0008" >
      <OctetString Value="04" />
      <Unsigned Value="04" />
      <Unsigned Value="04" />
      <Unsigned Value="04" />
      <Unsigned Value="04" />
      <Unsigned Value="04" />
      <Unsigned Value="04" />
      <Unsigned Value="04" />
    </Structure>
  </Array>
</Data>
```

```
(24) .day_profile_table_passive
PASSED
<_Data>
  <Array Qty="0004" >
    <Structure Qty="0002" >
      <Unsigned Value="01" />
    <Array Qty="0005" >
```

```
<Structure Qty="0003" >
  <OctetString Value="00000000" />
  <OctetString Value="00000A0064FF" />
  <LongUnsigned Value="0001" />
</Structure>
<Structure Qty="0003" >
  <OctetString Value="04000000" />
  <OctetString Value="00000A0064FF" />
  <LongUnsigned Value="0002" />
</Structure>
<Structure Qty="0003" >
  <OctetString Value="08000000" />
  <OctetString Value="00000A0064FF" />
  <LongUnsigned Value="0003" />
</Structure>
<Structure Qty="0003" >
  <OctetString Value="0C000000" />
  <OctetString Value="00000A0064FF" />
  <LongUnsigned Value="0004" />
</Structure>
<Structure Qty="0003" >
  <OctetString Value="10000000" />
  <OctetString Value="00000A0064FF" />
  <LongUnsigned Value="0001" />
</Structure>
</Array>
</Structure>
<Structure Qty="0002" >
  <Unsigned Value="02" />
  <Array Qty="0005" >
    <Structure Qty="0003" >
      <OctetString Value="00000000" />
      <OctetString Value="00000A0064FF" />
      <LongUnsigned Value="0003" />
    </Structure>
    <Structure Qty="0003" >
      <OctetString Value="04000000" />
      <OctetString Value="00000A0064FF" />
      <LongUnsigned Value="0003" />
    </Structure>
    <Structure Qty="0003" >
      <OctetString Value="08000000" />
      <OctetString Value="00000A0064FF" />
      <LongUnsigned Value="0003" />
    </Structure>
    <Structure Qty="0003" >
      <OctetString Value="0C000000" />
      <OctetString Value="00000A0064FF" />
      <LongUnsigned Value="0003" />
    </Structure>
    <Structure Qty="0003" >
      <OctetString Value="10000000" />
      <OctetString Value="00000A0064FF" />
      <LongUnsigned Value="0003" />
    </Structure>
  </Array>
</Structure>
```

```
    </Structure>
  </Array>
</Structure>
<Structure Qty="0002" >
  <Unsigned Value="03" />
  <Array Qty="0005" >
    <Structure Qty="0003" >
      <OctetString Value="00000000" />
      <OctetString Value="00000A0064FF" />
      <LongUnsigned Value="0001" />
    </Structure>
    <Structure Qty="0003" >
      <OctetString Value="04000000" />
      <OctetString Value="00000A0064FF" />
      <LongUnsigned Value="0002" />
    </Structure>
    <Structure Qty="0003" >
      <OctetString Value="08000000" />
      <OctetString Value="00000A0064FF" />
      <LongUnsigned Value="0003" />
    </Structure>
    <Structure Qty="0003" >
      <OctetString Value="0C000000" />
      <OctetString Value="00000A0064FF" />
      <LongUnsigned Value="0004" />
    </Structure>
    <Structure Qty="0003" >
      <OctetString Value="10000000" />
      <OctetString Value="00000A0064FF" />
      <LongUnsigned Value="0001" />
    </Structure>
  </Array>
</Structure>
<Structure Qty="0002" >
  <Unsigned Value="04" />
  <Array Qty="0005" >
    <Structure Qty="0003" >
      <OctetString Value="00000000" />
      <OctetString Value="00000A0064FF" />
      <LongUnsigned Value="0001" />
    </Structure>
    <Structure Qty="0003" >
      <OctetString Value="04000000" />
      <OctetString Value="00000A0064FF" />
      <LongUnsigned Value="0002" />
    </Structure>
    <Structure Qty="0003" >
      <OctetString Value="08000000" />
      <OctetString Value="00000A0064FF" />
      <LongUnsigned Value="0003" />
    </Structure>
    <Structure Qty="0003" >
      <OctetString Value="0C000000" />
      <OctetString Value="00000A0064FF" />
    </Structure>
```



```
        <LongUnsigned Value="0004" />
      </Structure>
    <Structure Qty="0003" >
      <OctetString Value="10000000" />
      <OctetString Value="00000A0064FF" />
      <LongUnsigned Value="0001" />
    </Structure>
  </Array>
</Structure>
</Array>
</_Data>
(25) .activate_passive_calendar_time
PASSED
  <Data>
    <OctetString Value="FFFFFFFFFFFFFFFF008000FF" />
  </Data>
```

Mngmt Set Special Days Table 0-0:11.0.0.255 (@125)

```
(26) .entries
PASSED
  <_Data>
    <Array Qty="001E" >
      <Structure Qty="0003" >
        <LongUnsigned Value="0001" />
        <OctetString Value="FFFF0101FF" />
        <Unsigned Value="02" />
      </Structure>
      <Structure Qty="0003" >
        <LongUnsigned Value="0002" />
        <OctetString Value="FFFF0102FF" />
        <Unsigned Value="02" />
      </Structure>
      <Structure Qty="0003" >
        <LongUnsigned Value="0003" />
        <OctetString Value="FFFF0103FF" />
        <Unsigned Value="02" />
      </Structure>
      <Structure Qty="0003" >
        <LongUnsigned Value="0004" />
        <OctetString Value="FFFF0104FF" />
        <Unsigned Value="02" />
      </Structure>
      <Structure Qty="0003" >
        <LongUnsigned Value="0005" />
        <OctetString Value="FFFF0105FF" />
        <Unsigned Value="02" />
      </Structure>
      <Structure Qty="0003" >
        <LongUnsigned Value="0006" />
        <OctetString Value="FFFF0106FF" />
        <Unsigned Value="02" />
      </Structure>
      <Structure Qty="0003" >
        <LongUnsigned Value="0007" />
```

```
<OctetString Value="FFFF0107FF" />
<Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0008" />
  <OctetString Value="FFFF0108FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0009" />
  <OctetString Value="FFFF0109FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="000A" />
  <OctetString Value="FFFF010AFF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="000B" />
  <OctetString Value="FFFF0201FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="000C" />
  <OctetString Value="FFFF0202FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="000D" />
  <OctetString Value="FFFF0203FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="000E" />
  <OctetString Value="FFFF0204FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="000F" />
  <OctetString Value="FFFF0205FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0010" />
  <OctetString Value="FFFF0206FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0011" />
  <OctetString Value="FFFF0207FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
```

```
<LongUnsigned Value="0012" />
<OctetString Value="FFFF0208FF" />
<Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0013" />
  <OctetString Value="FFFF0209FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0014" />
  <OctetString Value="FFFF020AFF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0015" />
  <OctetString Value="FFFF0301FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0016" />
  <OctetString Value="FFFF0302FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0017" />
  <OctetString Value="FFFF0303FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0018" />
  <OctetString Value="FFFF0304FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0019" />
  <OctetString Value="FFFF0305FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="001A" />
  <OctetString Value="FFFF0306FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="001B" />
  <OctetString Value="FFFF0307FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="001C" />
  <OctetString Value="FFFF0308FF" />
  <Unsigned Value="02" />
</Structure>
```

```
<Structure Qty="0003" >
  <LongUnsigned Value="001D" />
  <OctetString Value="FFFF0309FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="001E" />
  <OctetString Value="FFFF030AFF" />
  <Unsigned Value="02" />
</Structure>
</Array>
</_Data>
```

Mngmt Set Register activation - Energy 0-0:14.0.1.255 (@129)
(27) .register_assignment
PASSED

```
<_Data>
  <Array Qty="0038" >
    <Structure Qty="0002" >
      <LongUnsigned Value="0003" />
      <OctetString Value="0100010800FF" />
    </Structure>
    <Structure Qty="0002" >
      <LongUnsigned Value="0003" />
      <OctetString Value="0100010801FF" />
    </Structure>
    <Structure Qty="0002" >
      <LongUnsigned Value="0003" />
      <OctetString Value="0100010802FF" />
    </Structure>
    <Structure Qty="0002" >
      <LongUnsigned Value="0003" />
      <OctetString Value="0100010803FF" />
    </Structure>
    <Structure Qty="0002" >
      <LongUnsigned Value="0003" />
      <OctetString Value="0100010804FF" />
    </Structure>
    <Structure Qty="0002" >
      <LongUnsigned Value="0003" />
      <OctetString Value="0100020800FF" />
    </Structure>
    <Structure Qty="0002" >
      <LongUnsigned Value="0003" />
      <OctetString Value="0100020801FF" />
    </Structure>
    <Structure Qty="0002" >
      <LongUnsigned Value="0003" />
      <OctetString Value="0100020802FF" />
    </Structure>
    <Structure Qty="0002" >
      <LongUnsigned Value="0003" />
      <OctetString Value="0100020803FF" />
    </Structure>
```

```
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100020804FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100030800FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100030801FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100030802FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100030803FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100030804FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100040800FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100040801FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100040802FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100040803FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100040804FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100050800FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100050801FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
```

```
<OctetString Value="0100050802FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100050803FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100050804FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100060800FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100060801FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100060802FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100060803FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100060804FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100070800FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100070801FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100070802FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100070803FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100070804FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100080800FF" />
</Structure>
```

```
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100080801FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100080802FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100080803FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100080804FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100090800FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100090801FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100090802FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100090803FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100090804FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="01000A0800FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="01000A0801FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="01000A0802FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="01000A0803FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
```

```
        <OctetString Value="01000A0804FF" />
    </Structure>
    <Structure Qty="0002" >
        <LongUnsigned Value="0003" />
        <OctetString Value="01000F0800FF" />
    </Structure>
    <Structure Qty="0002" >
        <LongUnsigned Value="0003" />
        <OctetString Value="01000F0801FF" />
    </Structure>
    <Structure Qty="0002" >
        <LongUnsigned Value="0003" />
        <OctetString Value="01000F0802FF" />
    </Structure>
    <Structure Qty="0002" >
        <LongUnsigned Value="0003" />
        <OctetString Value="01000F0803FF" />
    </Structure>
    <Structure Qty="0002" >
        <LongUnsigned Value="0003" />
        <OctetString Value="01000F0804FF" />
    </Structure>
    <Structure Qty="0002" >
        <LongUnsigned Value="0003" />
        <OctetString Value="0100100800FF" />
    </Structure>
</Array>
</_Data>
(28) .mask_list
PASSED
<_Data>
    <Array Qty="0004" >
        <Structure Qty="0002" >
            <OctetString Value="01" />
            <Array Qty="0017" >
                <Unsigned Value="00" />
                <Unsigned Value="01" />
                <Unsigned Value="05" />
                <Unsigned Value="06" />
                <Unsigned Value="0A" />
                <Unsigned Value="0B" />
                <Unsigned Value="0F" />
                <Unsigned Value="10" />
                <Unsigned Value="14" />
                <Unsigned Value="15" />
                <Unsigned Value="19" />
                <Unsigned Value="1A" />
                <Unsigned Value="1E" />
                <Unsigned Value="1F" />
                <Unsigned Value="23" />
                <Unsigned Value="24" />
                <Unsigned Value="28" />
                <Unsigned Value="29" />
                <Unsigned Value="2D" />
            </Array>
        </Structure>
    </Array>
</_Data>
```



```
        <Unsigned Value="2E" />
        <Unsigned Value="32" />
        <Unsigned Value="33" />
        <Unsigned Value="37" />
    </Array>
</Structure>
<Structure Qty="0002" >
    <OctetString Value="02" />
    <Array Qty="0017" >
        <Unsigned Value="00" />
        <Unsigned Value="02" />
        <Unsigned Value="05" />
        <Unsigned Value="07" />
        <Unsigned Value="0A" />
        <Unsigned Value="0C" />
        <Unsigned Value="0F" />
        <Unsigned Value="11" />
        <Unsigned Value="14" />
        <Unsigned Value="16" />
        <Unsigned Value="19" />
        <Unsigned Value="1B" />
        <Unsigned Value="1E" />
        <Unsigned Value="20" />
        <Unsigned Value="23" />
        <Unsigned Value="25" />
        <Unsigned Value="28" />
        <Unsigned Value="2A" />
        <Unsigned Value="2D" />
        <Unsigned Value="2F" />
        <Unsigned Value="32" />
        <Unsigned Value="34" />
        <Unsigned Value="37" />
    </Array>
</Structure>
<Structure Qty="0002" >
    <OctetString Value="03" />
    <Array Qty="0017" >
        <Unsigned Value="00" />
        <Unsigned Value="03" />
        <Unsigned Value="05" />
        <Unsigned Value="08" />
        <Unsigned Value="0A" />
        <Unsigned Value="0D" />
        <Unsigned Value="0F" />
        <Unsigned Value="12" />
        <Unsigned Value="14" />
        <Unsigned Value="17" />
        <Unsigned Value="19" />
        <Unsigned Value="1C" />
        <Unsigned Value="1E" />
        <Unsigned Value="21" />
        <Unsigned Value="23" />
        <Unsigned Value="26" />
        <Unsigned Value="28" />
    </Array>
</Structure>
```

```
        <Unsigned Value="2B" />
        <Unsigned Value="2D" />
        <Unsigned Value="30" />
        <Unsigned Value="32" />
        <Unsigned Value="35" />
        <Unsigned Value="37" />
    </Array>
</Structure>
<Structure Qty="0002" >
    <OctetString Value="04" />
    <Array Qty="0017" >
        <Unsigned Value="00" />
        <Unsigned Value="04" />
        <Unsigned Value="05" />
        <Unsigned Value="09" />
        <Unsigned Value="0A" />
        <Unsigned Value="0E" />
        <Unsigned Value="0F" />
        <Unsigned Value="13" />
        <Unsigned Value="14" />
        <Unsigned Value="18" />
        <Unsigned Value="19" />
        <Unsigned Value="1D" />
        <Unsigned Value="1E" />
        <Unsigned Value="22" />
        <Unsigned Value="23" />
        <Unsigned Value="27" />
        <Unsigned Value="28" />
        <Unsigned Value="2C" />
        <Unsigned Value="2D" />
        <Unsigned Value="31" />
        <Unsigned Value="32" />
        <Unsigned Value="36" />
        <Unsigned Value="37" />
    </Array>
</Structure>
</Array>
</_Data>
```

Mngmt Set Register activation - Maximum Demand 0-0:14.0.2.255 (@135)
(29) .register_assignment
PASSED

```
<_Data>
  <Array Qty="0049" >
    <Structure Qty="0002" >
      <LongUnsigned Value="0005" />
      <OctetString Value="0100010400FF" />
    </Structure>
    <Structure Qty="0002" >
      <LongUnsigned Value="0004" />
      <OctetString Value="0100010500FF" />
    </Structure>
    <Structure Qty="0002" >
      <LongUnsigned Value="0004" />
    </Structure>
  </Array>
```

```
<OctetString Value="0100010600FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100010601FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100010602FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100010603FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100010604FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0005" />
  <OctetString Value="0100020400FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100020500FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100020600FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100020601FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100020602FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100020603FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100020604FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0005" />
  <OctetString Value="0100030400FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100030500FF" />
</Structure>
```

```
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100030600FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100030601FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100030602FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100030603FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100030604FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0005" />
  <OctetString Value="0100040400FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100040500FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100040600FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100040601FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100040602FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100040603FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100040604FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0005" />
  <OctetString Value="0100050400FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
```

```
<OctetString Value="0100050500FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100050600FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100050601FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100050602FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100050603FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100050604FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0005" />
  <OctetString Value="0100060400FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100060500FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100060600FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100060601FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100060602FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100060603FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100060604FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0005" />
  <OctetString Value="0100070400FF" />
</Structure>
```

```
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100070500FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100070600FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100070601FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100070602FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100070603FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100070604FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0005" />
  <OctetString Value="0100080400FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100080500FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100080600FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100080601FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100080602FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100080603FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100080604FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0005" />
```

```
<OctetString Value="0100090400FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100090500FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100090600FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100090601FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100090602FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100090603FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100090604FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0005" />
  <OctetString Value="01000A0400FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="01000A0500FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="01000A0600FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="01000A0601FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="01000A0602FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="01000A0603FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="01000A0604FF" />
</Structure>
```

```
<Structure Qty="0002" >
  <LongUnsigned Value="0005" />
  <OctetString Value="0100011800FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0005" />
  <OctetString Value="01000F1800FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0005" />
  <OctetString Value="0100101800FF" />
</Structure>
</Array>
</_Data>
(30) .mask_list
PASSED
```

```
<_Data>
  <Array Qty="0004" >
    <Structure Qty="0002" >
      <OctetString Value="01" />
      <Array Qty="002B" >
        <Unsigned Value="00" />
        <Unsigned Value="01" />
        <Unsigned Value="02" />
        <Unsigned Value="03" />
        <Unsigned Value="07" />
        <Unsigned Value="08" />
        <Unsigned Value="09" />
        <Unsigned Value="0A" />
        <Unsigned Value="0E" />
        <Unsigned Value="0F" />
        <Unsigned Value="10" />
        <Unsigned Value="11" />
        <Unsigned Value="15" />
        <Unsigned Value="16" />
        <Unsigned Value="17" />
        <Unsigned Value="18" />
        <Unsigned Value="1C" />
        <Unsigned Value="1D" />
        <Unsigned Value="1E" />
        <Unsigned Value="1F" />
        <Unsigned Value="23" />
        <Unsigned Value="24" />
        <Unsigned Value="25" />
        <Unsigned Value="26" />
        <Unsigned Value="2A" />
        <Unsigned Value="2B" />
        <Unsigned Value="2C" />
        <Unsigned Value="2D" />
        <Unsigned Value="31" />
        <Unsigned Value="32" />
        <Unsigned Value="33" />
        <Unsigned Value="34" />
        <Unsigned Value="38" />
      </Array>
    </Structure>
  </Array>
</_Data>
```



```
<Unsigned Value="39" />
<Unsigned Value="3A" />
<Unsigned Value="3B" />
<Unsigned Value="3F" />
<Unsigned Value="40" />
<Unsigned Value="41" />
<Unsigned Value="42" />
<Unsigned Value="46" />
<Unsigned Value="47" />
<Unsigned Value="48" />
</Array>
</Structure>
<Structure Qty="0002" >
  <OctetString Value="02" />
  <Array Qty="002B" >
    <Unsigned Value="00" />
    <Unsigned Value="01" />
    <Unsigned Value="02" />
    <Unsigned Value="04" />
    <Unsigned Value="07" />
    <Unsigned Value="08" />
    <Unsigned Value="09" />
    <Unsigned Value="0B" />
    <Unsigned Value="0E" />
    <Unsigned Value="0F" />
    <Unsigned Value="10" />
    <Unsigned Value="12" />
    <Unsigned Value="15" />
    <Unsigned Value="16" />
    <Unsigned Value="17" />
    <Unsigned Value="19" />
    <Unsigned Value="1C" />
    <Unsigned Value="1D" />
    <Unsigned Value="1E" />
    <Unsigned Value="20" />
    <Unsigned Value="23" />
    <Unsigned Value="24" />
    <Unsigned Value="25" />
    <Unsigned Value="27" />
    <Unsigned Value="2A" />
    <Unsigned Value="2B" />
    <Unsigned Value="2C" />
    <Unsigned Value="2E" />
    <Unsigned Value="31" />
    <Unsigned Value="32" />
    <Unsigned Value="33" />
    <Unsigned Value="35" />
    <Unsigned Value="38" />
    <Unsigned Value="39" />
    <Unsigned Value="3A" />
    <Unsigned Value="3C" />
    <Unsigned Value="3F" />
    <Unsigned Value="40" />
    <Unsigned Value="41" />
```

```
<Unsigned Value="43" />
<Unsigned Value="46" />
<Unsigned Value="47" />
<Unsigned Value="48" />
</Array>
</Structure>
<Structure Qty="0002" >
  <OctetString Value="03" />
  <Array Qty="002B" >
    <Unsigned Value="00" />
    <Unsigned Value="01" />
    <Unsigned Value="02" />
    <Unsigned Value="05" />
    <Unsigned Value="07" />
    <Unsigned Value="08" />
    <Unsigned Value="09" />
    <Unsigned Value="0C" />
    <Unsigned Value="0E" />
    <Unsigned Value="0F" />
    <Unsigned Value="10" />
    <Unsigned Value="13" />
    <Unsigned Value="15" />
    <Unsigned Value="16" />
    <Unsigned Value="17" />
    <Unsigned Value="1A" />
    <Unsigned Value="1C" />
    <Unsigned Value="1D" />
    <Unsigned Value="1E" />
    <Unsigned Value="21" />
    <Unsigned Value="23" />
    <Unsigned Value="24" />
    <Unsigned Value="25" />
    <Unsigned Value="28" />
    <Unsigned Value="2A" />
    <Unsigned Value="2B" />
    <Unsigned Value="2C" />
    <Unsigned Value="2F" />
    <Unsigned Value="31" />
    <Unsigned Value="32" />
    <Unsigned Value="33" />
    <Unsigned Value="36" />
    <Unsigned Value="38" />
    <Unsigned Value="39" />
    <Unsigned Value="3A" />
    <Unsigned Value="3D" />
    <Unsigned Value="3F" />
    <Unsigned Value="40" />
    <Unsigned Value="41" />
    <Unsigned Value="44" />
    <Unsigned Value="46" />
    <Unsigned Value="47" />
    <Unsigned Value="48" />
  </Array>
</Structure>
```

```
<Structure Qty="0002" >
  <OctetString Value="04" />
  <Array Qty="002B" >
    <Unsigned Value="00" />
    <Unsigned Value="01" />
    <Unsigned Value="02" />
    <Unsigned Value="06" />
    <Unsigned Value="07" />
    <Unsigned Value="08" />
    <Unsigned Value="09" />
    <Unsigned Value="0D" />
    <Unsigned Value="0E" />
    <Unsigned Value="0F" />
    <Unsigned Value="10" />
    <Unsigned Value="14" />
    <Unsigned Value="15" />
    <Unsigned Value="16" />
    <Unsigned Value="17" />
    <Unsigned Value="1B" />
    <Unsigned Value="1C" />
    <Unsigned Value="1D" />
    <Unsigned Value="1E" />
    <Unsigned Value="22" />
    <Unsigned Value="23" />
    <Unsigned Value="24" />
    <Unsigned Value="25" />
    <Unsigned Value="29" />
    <Unsigned Value="2A" />
    <Unsigned Value="2B" />
    <Unsigned Value="2C" />
    <Unsigned Value="30" />
    <Unsigned Value="31" />
    <Unsigned Value="32" />
    <Unsigned Value="33" />
    <Unsigned Value="37" />
    <Unsigned Value="38" />
    <Unsigned Value="39" />
    <Unsigned Value="3A" />
    <Unsigned Value="3E" />
    <Unsigned Value="3F" />
    <Unsigned Value="40" />
    <Unsigned Value="41" />
    <Unsigned Value="45" />
    <Unsigned Value="46" />
    <Unsigned Value="47" />
    <Unsigned Value="48" />
  </Array>
</Structure>
</Array>
</_Data>
```

Mngmt Set Tariffication script table 0-0:10.0.100.255 (@141)
(31) .scripts
PASSED

```
<_Data>
  <Array Qty="0004" >
    <Structure Qty="0002" >
      <LongUnsigned Value="0001" />
      <Array Qty="0003" >
        <Structure Qty="0005" >
          <Enum Value="01" />
          <LongUnsigned Value="0006" />
          <OctetString Value="00000E0001FF" />
          <Integer Value="04" />
          <OctetString Value="01" />
        </Structure>
        <Structure Qty="0005" >
          <Enum Value="01" />
          <LongUnsigned Value="0006" />
          <OctetString Value="00000E0002FF" />
          <Integer Value="04" />
          <OctetString Value="01" />
        </Structure>
        <Structure Qty="0005" >
          <Enum Value="01" />
          <LongUnsigned Value="0046" />
          <OctetString Value="000160030AFF" />
          <Integer Value="03" />
          <Enum Value="02" />
        </Structure>
      </Array>
    </Structure>
    <Structure Qty="0002" >
      <LongUnsigned Value="0002" />
      <Array Qty="0003" >
        <Structure Qty="0005" >
          <Enum Value="01" />
          <LongUnsigned Value="0006" />
          <OctetString Value="00000E0001FF" />
          <Integer Value="04" />
          <OctetString Value="02" />
        </Structure>
        <Structure Qty="0005" >
          <Enum Value="01" />
          <LongUnsigned Value="0006" />
          <OctetString Value="00000E0002FF" />
          <Integer Value="04" />
          <OctetString Value="02" />
        </Structure>
        <Structure Qty="0005" >
          <Enum Value="01" />
          <LongUnsigned Value="0046" />
          <OctetString Value="000160030AFF" />
          <Integer Value="03" />
          <Enum Value="01" />
        </Structure>
      </Array>
    </Structure>
  </Array>
</Structure>
```

```

<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <Array Qty="0003" >
    <Structure Qty="0005" >
      <Enum Value="01" />
      <LongUnsigned Value="0006" />
      <OctetString Value="00000E0001FF" />
      <Integer Value="04" />
      <OctetString Value="03" />
    </Structure>
    <Structure Qty="0005" >
      <Enum Value="01" />
      <LongUnsigned Value="0006" />
      <OctetString Value="00000E0002FF" />
      <Integer Value="04" />
      <OctetString Value="03" />
    </Structure>
    <Structure Qty="0005" >
      <Enum Value="01" />
      <LongUnsigned Value="0046" />
      <OctetString Value="000160030AFF" />
      <Integer Value="03" />
      <Enum Value="02" />
    </Structure>
  </Array>
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <Array Qty="0003" >
    <Structure Qty="0005" >
      <Enum Value="01" />
      <LongUnsigned Value="0006" />
      <OctetString Value="00000E0001FF" />
      <Integer Value="04" />
      <OctetString Value="04" />
    </Structure>
    <Structure Qty="0005" >
      <Enum Value="01" />
      <LongUnsigned Value="0006" />
      <OctetString Value="00000E0002FF" />
      <Integer Value="04" />
      <OctetString Value="04" />
    </Structure>
    <Structure Qty="0005" >
      <Enum Value="01" />
      <LongUnsigned Value="0046" />
      <OctetString Value="000160030AFF" />
      <Integer Value="03" />
      <Enum Value="01" />
    </Structure>
  </Array>
</Structure>
</Array>
</_Data>

```

Mngmt Set End of billing period 1 scheduler 0-0:15.0.0.255 (@152)

(32) .type

PASSED

```
<Data>
  <Enum Value="01" />
</Data>
```

(33) .execution_time

PASSED

```
<Data>
  <Array Qty="0001" >
    <Structure Qty="0002" >
      <OctetString Value="00000000" />
      <OctetString Value="FFFFFF02FF" />
    </Structure>
  </Array>
</Data>
```

Mngmt Set Data of billing period 1 0-0:98.1.0.255 (@158)

(34) .capture_objects

PASSED

```
<Data>
  <Array Qty="0005" >
    <Structure Qty="0004" >
      <LongUnsigned Value="0008" />
      <OctetString Value="0000010000FF" />
      <Integer Value="02" />
      <LongUnsigned Value="0000" />
    </Structure>
    <Structure Qty="0004" >
      <LongUnsigned Value="0003" />
      <OctetString Value="0100010801FF" />
      <Integer Value="02" />
      <LongUnsigned Value="0000" />
    </Structure>
    <Structure Qty="0004" >
      <LongUnsigned Value="0003" />
      <OctetString Value="0100010802FF" />
      <Integer Value="02" />
      <LongUnsigned Value="0000" />
    </Structure>
    <Structure Qty="0004" >
      <LongUnsigned Value="0003" />
      <OctetString Value="0100020801FF" />
      <Integer Value="02" />
      <LongUnsigned Value="0000" />
    </Structure>
    <Structure Qty="0004" >
      <LongUnsigned Value="0003" />
      <OctetString Value="0100020802FF" />
      <Integer Value="02" />
      <LongUnsigned Value="0000" />
    </Structure>
  </Array>
```

</Data>

Mngmt Set Disconnect control scheduler 0-0:15.0.1.255 (@170)

(35) .executed_script

PASSED

<Data>

<Structure Qty="0002" >

<OctetString Value="00000A006AFF" />

<LongUnsigned Value="0001" />

</Structure>

</Data>

(36) .type

PASSED

<Data>

<Enum Value="01" />

</Data>

(37) .execution_time

PASSED

<Data>

<Array Qty="0000" >

</Array>

</Data>

Mngmt Set Disconnect control 0-0:96.3.10.255 (@181)

(38) .control_mode

PASSED

<Data>

<Enum Value="06" />

</Data>

Mngmt Set Disconnect Control Log 0-0:99.98.2.255 (@193)

(39) .capture_objects

PASSED

<Data>

<Array Qty="0003" >

<Structure Qty="0004" >

<LongUnsigned Value="0008" />

<OctetString Value="0000010000FF" />

<Integer Value="02" />

<LongUnsigned Value="0000" />

</Structure>

<Structure Qty="0004" >

<LongUnsigned Value="0001" />

<OctetString Value="0000600B02FF" />

<Integer Value="02" />

<LongUnsigned Value="0000" />

</Structure>

<Structure Qty="0004" >

<LongUnsigned Value="0047" />

<OctetString Value="0000110000FF" />

<Integer Value="03" />

<LongUnsigned Value="0000" />

</Structure>

</Array>

```

    </Data>

Mngmt Set Load Mgmt - Relay control 1 0-1:96.3.10.255 (@209)
(40) .control_mode
PASSED
    <Data>
        <Enum Value="06" />
    </Data>

Mngmt Set Load Mgmt - Relay control 2 0-2:96.3.10.255 (@217)
(41) .control_mode
PASSED
    <Data>
        <Enum Value="06" />
    </Data>

Mngmt Set Limiter 0-0:17.0.0.255 (@225)
(42) .monitored_value
PASSED
    <Data>
        <Structure Qty="0003" >
            <LongUnsigned Value="0005" />
            <OctetString Value="0100011800FF" />
            <Integer Value="02" />
        </Structure>
    </Data>
(43) .threshold_normal
PASSED
    <Data>
        <DoubleLongUnsigned Value="00010D88" />
    </Data>
(44) .treshold_emergency
PASSED
    <Data>
        <DoubleLongUnsigned Value="00010D88" />
    </Data>
(45) .min_over_threshold_duration
PASSED
    <Data>
        <DoubleLongUnsigned Value="000000B4" />
    </Data>
(46) .min_under_threshold_duration
PASSED
    <Data>
        <DoubleLongUnsigned Value="000000B4" />
    </Data>
(47) .emergency_profile
PASSED
    <Data>
        <Structure Qty="0003" >
            <LongUnsigned Value="FFFF" />
            <OctetString Value="FFFFFFFFFFFFFFFF0800FF" />
            <DoubleLongUnsigned Value="00000000" />
        </Structure>

```



```
    </Data>
(48) .emergency_profile_group_id_list
PASSED
```

```
    <Data>
      <Array Qty="0000" >
        </Array>
    </Data>
```

```
(49) .actions
PASSED
```

```
    <Data>
      <Structure Qty="0002" >
        <Structure Qty="0002" >
          <OctetString Value="00000A006AFF" />
          <LongUnsigned Value="0001" />
        </Structure>
        <Structure Qty="0002" >
          <OctetString Value="00000A006AFF" />
          <LongUnsigned Value="0002" />
        </Structure>
      </Structure>
    </Data>
```

Mngmt Set Supervision monitor 1 - Fuse supervision L1 1-0:31.4.0.255 (@238)

```
(50) .thresholds
PASSED
```

```
    <Data>
      <Array Qty="0001" >
        <DoubleLongUnsigned Value="00002710" />
      </Array>
    </Data>
```

```
(51) .monitored_value
PASSED
```

```
    <Data>
      <Structure Qty="0003" >
        <LongUnsigned Value="0005" />
        <OctetString Value="01001F0400FF" />
        <Integer Value="02" />
      </Structure>
    </Data>
```

```
(52) .actions
PASSED
```

```
    <Data>
      <Array Qty="0001" >
        <Structure Qty="0002" >
          <Structure Qty="0002" >
            <OctetString Value="00000A006AFF" />
            <LongUnsigned Value="0001" />
          </Structure>
          <Structure Qty="0002" >
            <OctetString Value="00000A006AFF" />
            <LongUnsigned Value="0002" />
          </Structure>
        </Structure>
      </Array>
```

</Data>

Mngmt Set Supervision monitor 2 - Fuse supervision L2 1-0:51.4.0.255 (@244)

(53) .thresholds

PASSED

<Data>

<Array Qty="0001" >

<DoubleLongUnsigned Value="00002710" />

</Array>

</Data>

(54) .monitored_value

PASSED

<Data>

<Structure Qty="0003" >

<LongUnsigned Value="0005" />

<OctetString Value="0100330400FF" />

<Integer Value="02" />

</Structure>

</Data>

(55) .actions

PASSED

<Data>

<Array Qty="0001" >

<Structure Qty="0002" >

<Structure Qty="0002" >

<OctetString Value="00000A006AFF" />

<LongUnsigned Value="0001" />

</Structure>

<Structure Qty="0002" >

<OctetString Value="00000A006AFF" />

<LongUnsigned Value="0002" />

</Structure>

</Structure>

</Array>

</Data>

Mngmt Set Supervision monitor 3 - Fuse supervision L3 1-0:71.4.0.255 (@250)

(56) .thresholds

PASSED

<Data>

<Array Qty="0001" >

<DoubleLongUnsigned Value="00002710" />

</Array>

</Data>

(57) .monitored_value

PASSED

<Data>

<Structure Qty="0003" >

<LongUnsigned Value="0005" />

<OctetString Value="0100470400FF" />

<Integer Value="02" />

</Structure>

</Data>

(58) .actions

PASSED

```
<Data>
  <Array Qty="0001" >
    <Structure Qty="0002" >
      <Structure Qty="0002" >
        <OctetString Value="00000A006AFF" />
        <LongUnsigned Value="0001" />
      </Structure>
      <Structure Qty="0002" >
        <OctetString Value="00000A006AFF" />
        <LongUnsigned Value="0002" />
      </Structure>
    </Structure>
  </Array>
</Data>
```

Mngmt Set Error Register 0-0:97.97.0.255 (@257)
(59) .value

PASSED

```
<Data>
  <DoubleLongUnsigned Value="00002000" />
</Data>
```

Mngmt Set Alarm Register 1 0-0:97.98.0.255 (@261)
(60) .value

PASSED

```
<Data>
  <DoubleLongUnsigned Value="00002000" />
</Data>
```

Mngmt Set Alarm Filter 1 0-0:97.98.10.255 (@265)
(61) .value

PASSED

```
<Data>
  <DoubleLongUnsigned Value="FFFF3F03" />
</Data>
```

Mngmt Set Alarm Descriptor 1 0-0:97.98.20.255 (@269)
(62) .value

PASSED

```
<Data>
  <DoubleLongUnsigned Value="00000000" />
</Data>
```

Mngmt Set Alarm Monitor 1 0-0:16.1.0.255 (@273)
(63) .actions

PASSED

```
<Data>
  <Array Qty="0001" >
    <Structure Qty="0002" >
      <Structure Qty="0002" >
        <OctetString Value="00000A006CFF" />
        <LongUnsigned Value="0004" />
      </Structure>
    </Structure>
  </Array>
</Data>
```

```
        <Structure Qty="0002" >
          <OctetString Value="00000A006CFF" />
          <LongUnsigned Value="0000" />
        </Structure>
      </Structure>
    </Array>
  </Data>
```

Mngmt Set Alarm Register 2 0-0:97.98.1.255 (@279)
(64) .value
PASSED

```
  <Data>
    <DoubleLongUnsigned Value="0000020C" />
  </Data>
```

Mngmt Set Alarm Filter 2 0-0:97.98.11.255 (@283)
(65) .value
PASSED

```
  <Data>
    <DoubleLongUnsigned Value="F87BFF1D" />
  </Data>
```

Mngmt Set Alarm Descriptor 2 0-0:97.98.21.255 (@287)
(66) .value
PASSED

```
  <Data>
    <DoubleLongUnsigned Value="00000000" />
  </Data>
```

Mngmt Set Alarm Monitor 2 0-0:16.1.1.255 (@291)
(67) .actions
PASSED

```
  <Data>
    <Array Qty="0001" >
      <Structure Qty="0002" >
        <Structure Qty="0002" >
          <OctetString Value="00000A006CFF" />
          <LongUnsigned Value="0004" />
        </Structure>
        <Structure Qty="0002" >
          <OctetString Value="00000A006CFF" />
          <LongUnsigned Value="0000" />
        </Structure>
      </Structure>
    </Array>
  </Data>
```

Mngmt Set Standard Event Log 0-0:99.98.0.255 (@301)
(68) .capture_objects
PASSED

```
  <Data>
    <Array Qty="0002" >
      <Structure Qty="0004" >
        <LongUnsigned Value="0008" />
      </Structure>
    </Array>
  </Data>
```

```
    <OctetString Value="0000010000FF" />
    <Integer Value="02" />
    <LongUnsigned Value="0000" />
  </Structure>
  <Structure Qty="0004" >
    <LongUnsigned Value="0001" />
    <OctetString Value="0000600B00FF" />
    <Integer Value="02" />
    <LongUnsigned Value="0000" />
  </Structure>
</Array>
</Data>
```

Mngmt Set Fraud Detection Log 0-0:99.98.1.255 (@316)
(69) .capture_objects
PASSED

```
<Data>
  <Array Qty="0002" >
    <Structure Qty="0004" >
      <LongUnsigned Value="0008" />
      <OctetString Value="0000010000FF" />
      <Integer Value="02" />
      <LongUnsigned Value="0000" />
    </Structure>
    <Structure Qty="0004" >
      <LongUnsigned Value="0001" />
      <OctetString Value="0000600B01FF" />
      <Integer Value="02" />
      <LongUnsigned Value="0000" />
    </Structure>
  </Array>
</Data>
```

Mngmt Set Communication Log 0-0:99.98.5.255 (@331)
(70) .capture_objects
PASSED

```
<Data>
  <Array Qty="0002" >
    <Structure Qty="0004" >
      <LongUnsigned Value="0008" />
      <OctetString Value="0000010000FF" />
      <Integer Value="02" />
      <LongUnsigned Value="0000" />
    </Structure>
    <Structure Qty="0004" >
      <LongUnsigned Value="0001" />
      <OctetString Value="0000600B05FF" />
      <Integer Value="02" />
      <LongUnsigned Value="0000" />
    </Structure>
  </Array>
</Data>
```

Mngmt Set Consumer Message Code - Meter Display 0-0:96.13.1.255 (@343)

(71) .value
PASSED

```
<Data>
  <OctetString Value="" />
</Data>
```

Mngmt Set Consumer Message Text - Consumer Information 0-0:96.13.0.255 (@347)

(72) .value
PASSED

```
<Data>
  <OctetString Value="\12345678" />
</Data>
```

Mngmt Set Push action scheduler - Consumer Information 0-4:15.0.4.255 (@351)

(73) .executed_script
PASSED

```
<Data>
  <Structure Qty="0002" >
    <OctetString Value="00000A006CFF" />
    <LongUnsigned Value="0008" />
  </Structure>
</Data>
```

(74) .type
PASSED

```
<Data>
  <Enum Value="05" />
</Data>
```

(75) .execution_time
PASSED

```
<Data>
  <Array Qty="0004" >
    <Structure Qty="0002" >
      <OctetString Value="FFFF0000" />
      <OctetString Value="FFFFFFFF" />
    </Structure>
    <Structure Qty="0002" >
      <OctetString Value="FFFF0F00" />
      <OctetString Value="FFFFFFFF" />
    </Structure>
    <Structure Qty="0002" >
      <OctetString Value="FFFF1E00" />
      <OctetString Value="FFFFFFFF" />
    </Structure>
    <Structure Qty="0002" >
      <OctetString Value="FFFF2D00" />
      <OctetString Value="FFFFFFFF" />
    </Structure>
  </Array>
</Data>
```

Mngmt Set Push setup - Consumer Information 0-6:25.9.0.255 (@357)

(76) .push_object_list
PASSED

```
<Data>
```

```
        <Array Qty="0000" >
        </Array>
    </Data>
(77) .send_destination_and_method
PASSED
    <Data>
        <Structure Qty="0003" >
            <Enum Value="05" />
            <OctetString Value="0001160000FF" />
            <Enum Value="00" />
        </Structure>
    </Data>
```

```
(78) .communication_window
PASSED
```

```
    <Data>
        <Array Qty="0000" >
        </Array>
    </Data>
```

```
(79) .randomisation_start_interval
PASSED
```

```
    <Data>
        <LongUnsigned Value="0000" />
    </Data>
```

```
(80) .number_of_retries
PASSED
```

```
    <Data>
        <Unsigned Value="00" />
    </Data>
```

```
(81) .repetition_delay
PASSED
```

```
    <Data>
        <LongUnsigned Value="0000" />
    </Data>
```

Mngmt Set Security setup - Consumer Information 0-0:43.0.1.255 (@367)

```
(82) .security_suite
PASSED
```

```
    <Data>
        <Enum Value="00" />
    </Data>
```

Mngmt Set IEC HDLC setup - Consumer Information Interface 0-1:22.0.0.255

(@376)

```
(83) .comm_speed
PASSED
```

```
    <Data>
        <Enum Value="05" />
    </Data>
```

```
(84) .window_size_transmit
PASSED
```

```
    <Data>
        <Unsigned Value="01" />
    </Data>
```

```
(85) .window_size_receive
```

PASSED

```
<Data>
  <Unsigned Value="01" />
</Data>
```

(86) .max_info_field_lenght_transmit

PASSED

```
<Data>
  <LongUnsigned Value="00F2" />
</Data>
```

(87) .max_info_field_lenght_receive

PASSED

```
<Data>
  <LongUnsigned Value="00F2" />
</Data>
```

(88) .inter_octet_time_out

PASSED

```
<Data>
  <LongUnsigned Value="0019" />
</Data>
```

(89) .inactivity_time_out

PASSED

```
<Data>
  <LongUnsigned Value="0078" />
</Data>
```

(90) .device_address

PASSED

```
<Data>
  <LongUnsigned Value="0015" />
</Data>
```

Mngmt Set Image transfer 0-0:44.0.0.255 (@388)

(91) .image_block_size

PASSED

```
<Data>
  <DoubleLongUnsigned Value="000000C0" />
</Data>
```

(92) .image_transfer_enabled

PASSED

```
<Data>
  <Boolean Value="01" />
</Data>
```

Mngmt Set Image transfer activation scheduler 0-0:15.0.2.255 (@401)

(93) .executed_script

PASSED

```
<Data>
  <Structure Qty="0002" >
    <OctetString Value="00000A006BFF" />
    <LongUnsigned Value="0001" />
  </Structure>
</Data>
```

(94) .type

PASSED

```
<Data>
```



```

        <Enum Value="01" />
    </Data>
(95) .execution_time
PASSED
    <Data>
        <Array Qty="0001" >
            <Structure Qty="0002" >
                <OctetString Value="07100000" />
                <OctetString Value="07E60C1402" />
            </Structure>
        </Array>
    </Data>

Mngmt Set Demand Register 1 - Active energy import (+A) 1-0:1.4.0.255 (@775)
(96) .period
PASSED
    <Data>
        <DoubleLongUnsigned Value="00000384" />
    </Data>
(97) .number_of_periods
PASSED
    <Data>
        <LongUnsigned Value="0001" />
    </Data>

Mngmt Set Demand Register 2 - Active energy export (-A) 1-0:2.4.0.255 (@788)
(98) .period
PASSED
    <Data>
        <DoubleLongUnsigned Value="00000384" />
    </Data>
(99) .number_of_periods
PASSED
    <Data>
        <LongUnsigned Value="0001" />
    </Data>

Mngmt Set Demand Register 3 - Reactive energy import (+R) 1-0:3.4.0.255
(@801)
(100) .period
PASSED
    <Data>
        <DoubleLongUnsigned Value="00000384" />
    </Data>
(101) .number_of_periods
PASSED
    <Data>
        <LongUnsigned Value="0001" />
    </Data>

Mngmt Set Demand Register 4 - Reactive energy export (-R) 1-0:4.4.0.255
(@814)
(102) .period
PASSED

```

```

        <Data>
          <DoubleLongUnsigned Value="00000384" />
        </Data>
(103) .number_of_periods
PASSED
        <Data>
          <LongUnsigned Value="0001" />
        </Data>

Mngmt Set Demand Register 5 - Apparent energy import (+VA) 1-0:9.4.0.255
(@827)
(104) .period
PASSED
        <Data>
          <DoubleLongUnsigned Value="00000384" />
        </Data>
(105) .number_of_periods
PASSED
        <Data>
          <LongUnsigned Value="0001" />
        </Data>

Mngmt Set Demand Register 6 - Apparent energy export (-VA) 1-0:10.4.0.255
(@840)
(106) .period
PASSED
        <Data>
          <DoubleLongUnsigned Value="00000384" />
        </Data>
(107) .number_of_periods
PASSED
        <Data>
          <LongUnsigned Value="0001" />
        </Data>

Mngmt Set Load profile with period 1 i.e. General Load Profile 1-0:99.1.0.255
(@1146)
(108) .capture_objects
PASSED
        <Data>
          <Array Qty="0004" >
            <Structure Qty="0004" >
              <LongUnsigned Value="0008" />
              <OctetString Value="0000010000FF" />
              <Integer Value="02" />
              <LongUnsigned Value="0000" />
            </Structure>
            <Structure Qty="0004" >
              <LongUnsigned Value="0001" />
              <OctetString Value="0000600A01FF" />
              <Integer Value="02" />
              <LongUnsigned Value="0000" />
            </Structure>
          </Array>
        </Data>

```

```
        <LongUnsigned Value="0003" />
        <OctetString Value="0100010800FF" />
        <Integer Value="02" />
        <LongUnsigned Value="0000" />
    </Structure>
    <Structure Qty="0004" >
        <LongUnsigned Value="0003" />
        <OctetString Value="0100020800FF" />
        <Integer Value="02" />
        <LongUnsigned Value="0000" />
    </Structure>
</Array>
</Data>
```

(109) .capture_period
PASSED

```
<Data>
    <DoubleLongUnsigned Value="00000384" />
</Data>
```

(110) .profile_entries
PASSED

```
<Data>
    <DoubleLongUnsigned Value="000010E0" />
</Data>
```

Mngmt Set Load profile with period 2 i.e. Daily Values Profile 1-0:99.2.0.255
(@1161)

(111) .capture_objects
PASSED

```
<Data>
    <Array Qty="0004" >
        <Structure Qty="0004" >
            <LongUnsigned Value="0008" />
            <OctetString Value="0000010000FF" />
            <Integer Value="02" />
            <LongUnsigned Value="0000" />
        </Structure>
        <Structure Qty="0004" >
            <LongUnsigned Value="0001" />
            <OctetString Value="0000600A02FF" />
            <Integer Value="02" />
            <LongUnsigned Value="0000" />
        </Structure>
        <Structure Qty="0004" >
            <LongUnsigned Value="0003" />
            <OctetString Value="0100010800FF" />
            <Integer Value="02" />
            <LongUnsigned Value="0000" />
        </Structure>
        <Structure Qty="0004" >
            <LongUnsigned Value="0003" />
            <OctetString Value="0100020800FF" />
            <Integer Value="02" />
            <LongUnsigned Value="0000" />
        </Structure>
    </Array>
</Data>
```

```
        </Array>
    </Data>
(112) .capture_period
PASSED
    <Data>
        <DoubleLongUnsigned Value="00015180" />
    </Data>
(113) .profile_entries
PASSED
    <Data>
        <DoubleLongUnsigned Value="0000003C" />
    </Data>

Mngmt Set Time threshold for long power failure 0-0:96.7.20.255 (@1181)
(114) .value
PASSED
    <Data>
        <LongUnsigned Value="00B4" />
    </Data>

Mngmt Set Threshold for voltage sag 1-0:12.31.0.255 (@1193)
(115) .value
PASSED
    <Data>
        <LongUnsigned Value="00CF" />
    </Data>

Mngmt Set Time threshold for voltage sag 1-0:12.43.0.255 (@1199)
(116) .value
PASSED
    <Data>
        <LongUnsigned Value="001E" />
    </Data>

Mngmt Set Threshold for voltage swell 1-0:12.35.0.255 (@1253)
(117) .value
PASSED
    <Data>
        <LongUnsigned Value="00FD" />
    </Data>

Mngmt Set Time threshold for voltage swell 1-0:12.44.0.255 (@1259)
(118) .value
PASSED
    <Data>
        <LongUnsigned Value="001E" />
    </Data>

Mngmt Set Threshold for missing voltage (voltage cut) 1-0:12.39.0.255 (@1313)
(119) .value
PASSED
    <Data>
        <LongUnsigned Value="0067" />
    </Data>
```

Mngmt Set Time threshold for voltage cut 1-0:12.45.0.255 (@1319)
(120) .value
PASSED

```
<Data>  
  <LongUnsigned Value="001E" />  
</Data>
```

Mngmt Set Power Failure Event Log 1-0:99.97.0.255 (@1325)
(121) .capture_objects
PASSED

```
<Data>  
  <Array Qty="0002" >  
    <Structure Qty="0004" >  
      <LongUnsigned Value="0008" />  
      <OctetString Value="0000010000FF" />  
      <Integer Value="02" />  
      <LongUnsigned Value="0000" />  
    </Structure>  
    <Structure Qty="0004" >  
      <LongUnsigned Value="0003" />  
      <OctetString Value="0000600713FF" />  
      <Integer Value="02" />  
      <LongUnsigned Value="0000" />  
    </Structure>  
  </Array>  
</Data>
```

Mngmt Set Power Quality Log 0-0:99.98.4.255 (@1340)
(122) .capture_objects
PASSED

```
<Data>  
  <Array Qty="0002" >  
    <Structure Qty="0004" >  
      <LongUnsigned Value="0008" />  
      <OctetString Value="0000010000FF" />  
      <Integer Value="02" />  
      <LongUnsigned Value="0000" />  
    </Structure>  
    <Structure Qty="0004" >  
      <LongUnsigned Value="0001" />  
      <OctetString Value="0000600B04FF" />  
      <Integer Value="02" />  
      <LongUnsigned Value="0000" />  
    </Structure>  
  </Array>  
</Data>
```

Mngmt Set Sliding Average current L1 (for fuse supervision) 1-0:31.4.0.255
(@1369)
(123) .number_of_periods
PASSED

```
<Data>  
  <LongUnsigned Value="005A" />
```

</Data>

Mngmt Set Sliding Average current L2 (for fuse supervision) 1-0:51.4.0.255 (@1400)

(124) .number_of_periods

PASSED

<Data>

<LongUnsigned Value="005A" />

</Data>

Mngmt Set Sliding Average current L3 (for fuse supervision) 1-0:71.4.0.255 (@1431)

(125) .number_of_periods

PASSED

<Data>

<LongUnsigned Value="005A" />

</Data>

Mngmt Set Average Import Power (+A) 1-0:1.24.0.255 (@1498)

(126) .number_of_periods

PASSED

<Data>

<LongUnsigned Value="000F" />

</Data>

Mngmt Set Average Net Power (|+A|-|-A|) 1-0:16.24.0.255 (@1511)

(127) .number_of_periods

PASSED

<Data>

<LongUnsigned Value="000F" />

</Data>

Mngmt Set Average Total Power (|+A|+|-A|) 1-0:15.24.0.255 (@1524)

(128) .number_of_periods

PASSED

<Data>

<LongUnsigned Value="000F" />

</Data>

Mngmt Set Measurement Period 3 for Instantaneous values 1-0:0.8.2.255 (@1559)

(129) .value

PASSED

<Data>

<DoubleLongUnsigned Value="00000258" />

</Data>

Mngmt Set M-Bus client channel 1 0-1:24.1.0.255 (@1574)

(130) .mbus_port_reference

PASSED

<Data>

<OctetString Value="0000180600FF" />

</Data>

(131) .capture_definition

PASSED

```
    <Data>
      <Array Qty="0000" >
        </Array>
      </Data>
(132) .capture_period
PASSED
    <Data>
      <DoubleLongUnsigned Value="00000E10" />
    </Data>
(133) .primary_address
PASSED
    <Data>
      <Unsigned Value="00" />
    </Data>

Mngmt Set M-Bus client channel 2 0-2:24.1.0.255 (@1596)
(134) .mbus_port_reference
PASSED
    <Data>
      <OctetString Value="0000180600FF" />
    </Data>
(135) .capture_definition
PASSED
    <Data>
      <Array Qty="0000" >
        </Array>
      </Data>
(136) .capture_period
PASSED
    <Data>
      <DoubleLongUnsigned Value="00000E10" />
    </Data>
(137) .primary_address
PASSED
    <Data>
      <Unsigned Value="00" />
    </Data>

Mngmt Set M-Bus client channel 3 0-3:24.1.0.255 (@1618)
(138) .mbus_port_reference
PASSED
    <Data>
      <OctetString Value="0000180600FF" />
    </Data>
(139) .capture_definition
PASSED
    <Data>
      <Array Qty="0000" >
        </Array>
      </Data>
(140) .capture_period
PASSED
    <Data>
      <DoubleLongUnsigned Value="00000E10" />
```

```
    </Data>
(141) .primary_address
PASSED
    <Data>
        <Unsigned Value="00" />
    </Data>

Mngmt Set M-Bus client channel 4 0-4:24.1.0.255 (@1640)
(142) .mbus_port_reference
PASSED
    <Data>
        <OctetString Value="0000180600FF" />
    </Data>
(143) .capture_definition
PASSED
    <Data>
        <Array Qty="0000" >
            </Array>
    </Data>
(144) .capture_period
PASSED
    <Data>
        <DoubleLongUnsigned Value="00000E10" />
    </Data>
(145) .primary_address
PASSED
    <Data>
        <Unsigned Value="00" />
    </Data>

Mngmt Set M-Bus Value channel 1, instance 1 0-1:24.2.1.255 (@1662)
(146) .scaler_unit
PASSED
    <Data>
        <Structure Qty="0002" >
            <Integer Value="00" />
            <Enum Value="00" />
        </Structure>
    </Data>

Mngmt Set M-Bus Value channel 1, instance 2 0-1:24.2.2.255 (@1670)
(147) .scaler_unit
PASSED
    <Data>
        <Structure Qty="0002" >
            <Integer Value="00" />
            <Enum Value="00" />
        </Structure>
    </Data>

Mngmt Set M-Bus Value channel 1, instance 3 0-1:24.2.3.255 (@1678)
(148) .scaler_unit
PASSED
    <Data>
```



```
    <Structure Qty="0002" >
      <Integer Value="00" />
      <Enum Value="00" />
    </Structure>
  </Data>
```

Mngmt Set M-Bus Value channel 1, instance 4 0-1:24.2.4.255 (@1686)
(149) .scaler_unit
PASSED

```
  <Data>
    <Structure Qty="0002" >
      <Integer Value="00" />
      <Enum Value="00" />
    </Structure>
  </Data>
```

Mngmt Set M-Bus Value channel 2, instance 1 0-2:24.2.1.255 (@1694)
(150) .scaler_unit
PASSED

```
  <Data>
    <Structure Qty="0002" >
      <Integer Value="00" />
      <Enum Value="00" />
    </Structure>
  </Data>
```

Mngmt Set M-Bus Value channel 2, instance 2 0-2:24.2.2.255 (@1702)
(151) .scaler_unit
PASSED

```
  <Data>
    <Structure Qty="0002" >
      <Integer Value="00" />
      <Enum Value="00" />
    </Structure>
  </Data>
```

Mngmt Set M-Bus Value channel 2, instance 3 0-2:24.2.3.255 (@1710)
(152) .scaler_unit
PASSED

```
  <Data>
    <Structure Qty="0002" >
      <Integer Value="00" />
      <Enum Value="00" />
    </Structure>
  </Data>
```

Mngmt Set M-Bus Value channel 2, instance 4 0-2:24.2.4.255 (@1718)
(153) .scaler_unit
PASSED

```
  <Data>
    <Structure Qty="0002" >
      <Integer Value="00" />
      <Enum Value="00" />
    </Structure>
```

</Data>

Mngmt Set M-Bus Value channel 3, instance 1 0-3:24.2.1.255 (@1726)
(154) .scaler_unit

PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="00" />
    <Enum Value="00" />
  </Structure>
</Data>
```

Mngmt Set M-Bus Value channel 3, instance 2 0-3:24.2.2.255 (@1734)
(155) .scaler_unit

PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="00" />
    <Enum Value="00" />
  </Structure>
</Data>
```

Mngmt Set M-Bus Value channel 3, instance 3 0-3:24.2.3.255 (@1742)
(156) .scaler_unit

PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="00" />
    <Enum Value="00" />
  </Structure>
</Data>
```

Mngmt Set M-Bus Value channel 3, instance 4 0-3:24.2.4.255 (@1750)
(157) .scaler_unit

PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="00" />
    <Enum Value="00" />
  </Structure>
</Data>
```

Mngmt Set M-Bus Value channel 4, instance 1 0-4:24.2.1.255 (@1758)
(158) .scaler_unit

PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="00" />
    <Enum Value="00" />
  </Structure>
</Data>
```

Mngmt Set M-Bus Value channel 4, instance 2 0-4:24.2.2.255 (@1766)
(159) .scaler_unit

PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="00" />
    <Enum Value="00" />
  </Structure>
</Data>
```

Mngmt Set M-Bus Value channel 4, instance 3 0-4:24.2.3.255 (@1774)
(160) .scaler_unit

PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="00" />
    <Enum Value="00" />
  </Structure>
</Data>
```

Mngmt Set M-Bus Value channel 4, instance 4 0-4:24.2.4.255 (@1782)
(161) .scaler_unit

PASSED

```
<Data>
  <Structure Qty="0002" >
    <Integer Value="00" />
    <Enum Value="00" />
  </Structure>
</Data>
```

Mngmt Set M-Bus Device ID 1 channel 1 0-1:96.1.0.255 (@1790)
(162) .value

PASSED

```
<Data>
  <OctetString Value="" />
</Data>
```

Mngmt Set M-Bus Device ID 1 channel 2 0-2:96.1.0.255 (@1794)
(163) .value

PASSED

```
<Data>
  <OctetString Value="" />
</Data>
```

Mngmt Set M-Bus Device ID 1 channel 3 0-3:96.1.0.255 (@1798)
(164) .value

PASSED

```
<Data>
  <OctetString Value="" />
</Data>
```

Mngmt Set M-Bus Device ID 1 channel 4 0-4:96.1.0.255 (@1802)
(165) .value

PASSED

```
<Data>
  <OctetString Value="" />
```

```

    </Data>

Mngmt Set M-Bus Device ID 2 channel 1 0-1:96.1.1.255 (@1806)
(166) .value
PASSED
    <Data>
        <OctetString Value="" />
    </Data>

Mngmt Set M-Bus Device ID 2 channel 2 0-2:96.1.1.255 (@1810)
(167) .value
PASSED
    <Data>
        <OctetString Value="" />
    </Data>

Mngmt Set M-Bus Device ID 2 channel 3 0-3:96.1.1.255 (@1814)
(168) .value
PASSED
    <Data>
        <OctetString Value="" />
    </Data>

Mngmt Set M-Bus Device ID 2 channel 4 0-4:96.1.1.255 (@1818)
(169) .value
PASSED
    <Data>
        <OctetString Value="" />
    </Data>

Mngmt Set M-Bus Master Load profile for channel 1 0-1:24.3.0.255 (@1838)
(170) .capture_objects
PASSED
    <Data>
        <Array Qty="0006" >
            <Structure Qty="0004" >
                <LongUnsigned Value="0008" />
                <OctetString Value="0000010000FF" />
                <Integer Value="02" />
                <LongUnsigned Value="0000" />
            </Structure>
            <Structure Qty="0004" >
                <LongUnsigned Value="0001" />
                <OctetString Value="0001600A03FF" />
                <Integer Value="02" />
                <LongUnsigned Value="0000" />
            </Structure>
            <Structure Qty="0004" >
                <LongUnsigned Value="0004" />
                <OctetString Value="0001180201FF" />
                <Integer Value="02" />
                <LongUnsigned Value="0000" />
            </Structure>
            <Structure Qty="0004" >

```

```

        <LongUnsigned Value="0004" />
        <OctetString Value="0001180202FF" />
        <Integer Value="02" />
        <LongUnsigned Value="0000" />
    </Structure>
</Structure>
<Structure Qty="0004" >
    <LongUnsigned Value="0004" />
    <OctetString Value="0001180203FF" />
    <Integer Value="02" />
    <LongUnsigned Value="0000" />
</Structure>
<Structure Qty="0004" >
    <LongUnsigned Value="0004" />
    <OctetString Value="0001180204FF" />
    <Integer Value="02" />
    <LongUnsigned Value="0000" />
</Structure>
</Array>
</Data>
(171) .capture_period
PASSED
    <Data>
        <DoubleLongUnsigned Value="00000E10" />
    </Data>

Mngmt Set M-Bus Master Load profile for channel 2 0-2:24.3.0.255 (@1849)
(172) .capture_objects
PASSED
    <Data>
        <Array Qty="0006" >
            <Structure Qty="0004" >
                <LongUnsigned Value="0008" />
                <OctetString Value="0000010000FF" />
                <Integer Value="02" />
                <LongUnsigned Value="0000" />
            </Structure>
            <Structure Qty="0004" >
                <LongUnsigned Value="0001" />
                <OctetString Value="0002600A03FF" />
                <Integer Value="02" />
                <LongUnsigned Value="0000" />
            </Structure>
            <Structure Qty="0004" >
                <LongUnsigned Value="0004" />
                <OctetString Value="0002180201FF" />
                <Integer Value="02" />
                <LongUnsigned Value="0000" />
            </Structure>
            <Structure Qty="0004" >
                <LongUnsigned Value="0004" />
                <OctetString Value="0002180202FF" />
                <Integer Value="02" />
                <LongUnsigned Value="0000" />
            </Structure>
        </Array>
    </Data>

```

```

    <Structure Qty="0004" >
      <LongUnsigned Value="0004" />
      <OctetString Value="0002180203FF" />
      <Integer Value="02" />
      <LongUnsigned Value="0000" />
    </Structure>
    <Structure Qty="0004" >
      <LongUnsigned Value="0004" />
      <OctetString Value="0002180204FF" />
      <Integer Value="02" />
      <LongUnsigned Value="0000" />
    </Structure>
  </Array>
</Data>
(173) .capture_period
PASSED
<Data>
  <DoubleLongUnsigned Value="00000E10" />
</Data>

Mngmt Set M-Bus Master Load profile for channel 3 0-3:24.3.0.255 (@1860)
(174) .capture_objects
PASSED
<Data>
  <Array Qty="0006" >
    <Structure Qty="0004" >
      <LongUnsigned Value="0008" />
      <OctetString Value="0000010000FF" />
      <Integer Value="02" />
      <LongUnsigned Value="0000" />
    </Structure>
    <Structure Qty="0004" >
      <LongUnsigned Value="0001" />
      <OctetString Value="0003600A03FF" />
      <Integer Value="02" />
      <LongUnsigned Value="0000" />
    </Structure>
    <Structure Qty="0004" >
      <LongUnsigned Value="0004" />
      <OctetString Value="0003180201FF" />
      <Integer Value="02" />
      <LongUnsigned Value="0000" />
    </Structure>
    <Structure Qty="0004" >
      <LongUnsigned Value="0004" />
      <OctetString Value="0003180202FF" />
      <Integer Value="02" />
      <LongUnsigned Value="0000" />
    </Structure>
    <Structure Qty="0004" >
      <LongUnsigned Value="0004" />
      <OctetString Value="0003180203FF" />
      <Integer Value="02" />
      <LongUnsigned Value="0000" />
    </Structure>
  </Array>

```

```

        </Structure>
        <Structure Qty="0004" >
            <LongUnsigned Value="0004" />
            <OctetString Value="0003180204FF" />
            <Integer Value="02" />
            <LongUnsigned Value="0000" />
        </Structure>
    </Array>
</Data>
(175) .capture_period
PASSED
<Data>
    <DoubleLongUnsigned Value="00000E10" />
</Data>

Mngmt Set M-Bus Master Load profile for channel 4 0-4:24.3.0.255 (@1871)
(176) .capture_objects
PASSED
<Data>
    <Array Qty="0006" >
        <Structure Qty="0004" >
            <LongUnsigned Value="0008" />
            <OctetString Value="0000010000FF" />
            <Integer Value="02" />
            <LongUnsigned Value="0000" />
        </Structure>
        <Structure Qty="0004" >
            <LongUnsigned Value="0001" />
            <OctetString Value="0004600A03FF" />
            <Integer Value="02" />
            <LongUnsigned Value="0000" />
        </Structure>
        <Structure Qty="0004" >
            <LongUnsigned Value="0004" />
            <OctetString Value="0004180201FF" />
            <Integer Value="02" />
            <LongUnsigned Value="0000" />
        </Structure>
        <Structure Qty="0004" >
            <LongUnsigned Value="0004" />
            <OctetString Value="0004180202FF" />
            <Integer Value="02" />
            <LongUnsigned Value="0000" />
        </Structure>
        <Structure Qty="0004" >
            <LongUnsigned Value="0004" />
            <OctetString Value="0004180203FF" />
            <Integer Value="02" />
            <LongUnsigned Value="0000" />
        </Structure>
        <Structure Qty="0004" >
            <LongUnsigned Value="0004" />
            <OctetString Value="0004180204FF" />
            <Integer Value="02" />
        </Structure>
    </Array>

```

```

                <LongUnsigned Value="0000" />
            </Structure>
        </Array>
    </Data>
(177) .capture_period
PASSED
    <Data>
        <DoubleLongUnsigned Value="00000E10" />
    </Data>

Mngmt Set M-Bus Master Disconnect control object 1 0-1:24.4.0.255 (@1882)
(178) .control_mode
PASSED
    <Data>
        <Enum Value="05" />
    </Data>

Mngmt Set M-Bus Master Disconnect control object 2 0-2:24.4.0.255 (@1890)
(179) .control_mode
PASSED
    <Data>
        <Enum Value="05" />
    </Data>

Mngmt Set M-Bus Master Disconnect control object 3 0-3:24.4.0.255 (@1898)
(180) .control_mode
PASSED
    <Data>
        <Enum Value="05" />
    </Data>

Mngmt Set M-Bus Master Disconnect control object 4 0-4:24.4.0.255 (@1906)
(181) .control_mode
PASSED
    <Data>
        <Enum Value="05" />
    </Data>

Mngmt Set M-Bus Disconnect control scheduler 0-1:15.0.1.255 (@1914)
(182) .executed_script
PASSED
    <Data>
        <Structure Qty="0002" >
            <OctetString Value="00010A006AFF" />
            <LongUnsigned Value="0001" />
        </Structure>
    </Data>
(183) .type
PASSED
    <Data>
        <Enum Value="01" />
    </Data>
(184) .execution_time
PASSED

```



```
<Data>
  <Array Qty="0000" >
  </Array>
</Data>
```

Mngmt Set M-Bus Master Control log object 1 0-1:24.5.0.255 (@1941)
(185) .capture_objects
PASSED

```
<Data>
  <Array Qty="0002" >
    <Structure Qty="0004" >
      <LongUnsigned Value="0008" />
      <OctetString Value="0000010000FF" />
      <Integer Value="02" />
      <LongUnsigned Value="0000" />
    </Structure>
    <Structure Qty="0004" >
      <LongUnsigned Value="0001" />
      <OctetString Value="0001600B04FF" />
      <Integer Value="02" />
      <LongUnsigned Value="0000" />
    </Structure>
  </Array>
</Data>
```

Mngmt Set M-Bus Master Control log object 2 0-2:24.5.0.255 (@1952)
(186) .capture_objects
PASSED

```
<Data>
  <Array Qty="0002" >
    <Structure Qty="0004" >
      <LongUnsigned Value="0008" />
      <OctetString Value="0000010000FF" />
      <Integer Value="02" />
      <LongUnsigned Value="0000" />
    </Structure>
    <Structure Qty="0004" >
      <LongUnsigned Value="0001" />
      <OctetString Value="0002600B04FF" />
      <Integer Value="02" />
      <LongUnsigned Value="0000" />
    </Structure>
  </Array>
</Data>
```

Mngmt Set M-Bus Master Control log object 3 0-3:24.5.0.255 (@1963)
(187) .capture_objects
PASSED

```
<Data>
  <Array Qty="0002" >
    <Structure Qty="0004" >
      <LongUnsigned Value="0008" />
      <OctetString Value="0000010000FF" />
      <Integer Value="02" />
    </Structure>
  </Array>
</Data>
```

```
        <LongUnsigned Value="0000" />
    </Structure>
    <Structure Qty="0004" >
        <LongUnsigned Value="0001" />
        <OctetString Value="0003600B04FF" />
        <Integer Value="02" />
        <LongUnsigned Value="0000" />
    </Structure>
</Array>
</Data>
```

Mngmt Set M-Bus Master Control log object 4 0-4:24.5.0.255 (@1974)
(188) .capture_objects
PASSED

```
<Data>
  <Array Qty="0002" >
    <Structure Qty="0004" >
      <LongUnsigned Value="0008" />
      <OctetString Value="0000010000FF" />
      <Integer Value="02" />
      <LongUnsigned Value="0000" />
    </Structure>
    <Structure Qty="0004" >
      <LongUnsigned Value="0001" />
      <OctetString Value="0004600B04FF" />
      <Integer Value="02" />
      <LongUnsigned Value="0000" />
    </Structure>
  </Array>
</Data>
```

Mngmt Set M-Bus Event Log 0-0:99.98.3.255 (@1989)
(189) .capture_objects
PASSED

```
<Data>
  <Array Qty="0002" >
    <Structure Qty="0004" >
      <LongUnsigned Value="0008" />
      <OctetString Value="0000010000FF" />
      <Integer Value="02" />
      <LongUnsigned Value="0000" />
    </Structure>
    <Structure Qty="0004" >
      <LongUnsigned Value="0001" />
      <OctetString Value="0000600B03FF" />
      <Integer Value="02" />
      <LongUnsigned Value="0000" />
    </Structure>
  </Array>
</Data>
```

Mngmt Set IEC local port setup - IEC Optical port 0-0:20.0.0.255 (@2001)
(190) .default_mode
PASSED

```
    <Data>
      <Enum Value="01" />
    </Data>
(191) .default_baud
PASSED
    <Data>
      <Enum Value="05" />
    </Data>
(192) .prop_baud
PASSED
    <Data>
      <Enum Value="05" />
    </Data>
(193) .response_time
PASSED
    <Data>
      <Enum Value="00" />
    </Data>
(194) .device_addr
PASSED
    <Data>
      <OctetString Value="\12000016" />
    </Data>
(195) .pass_p1
PASSED
    <Data>
      <OctetString Value="\12345678" />
    </Data>
(196) .pass_p2
PASSED
    <Data>
      <OctetString Value="\12345678" />
    </Data>
(197) .pass_p3
PASSED
    <Data>
      <OctetString Value="\12345678" />
    </Data>

Mngmt Set IEC HDLC setup - HDLC Optical port 0-0:22.0.0.255 (@2012)
(198) .comm_speed
PASSED
    <Data>
      <Enum Value="05" />
    </Data>
(199) .window_size_transmit
PASSED
    <Data>
      <Unsigned Value="01" />
    </Data>
(200) .window_size_receive
PASSED
    <Data>
      <Unsigned Value="01" />
    </Data>
```

```
</Data>
(201) .max_info_field_lenght_transmit
PASSED
    <Data>
        <LongUnsigned Value="00F2" />
    </Data>
(202) .max_info_field_lenght_receive
PASSED
    <Data>
        <LongUnsigned Value="00F2" />
    </Data>
(203) .inter_octet_time_out
PASSED
    <Data>
        <LongUnsigned Value="0019" />
    </Data>
(204) .inactivity_time_out
PASSED
    <Data>
        <LongUnsigned Value="0078" />
    </Data>
(205) .device_address
PASSED
    <Data>
        <LongUnsigned Value="0015" />
    </Data>

Mngmt Set TCP-UDP setup 0-0:25.0.0.255 (@2024)
(206) .TCP-UDP_port
PASSED
    <Data>
        <LongUnsigned Value="F0B0" />
    </Data>
(207) .MSS
PASSED
    <Data>
        <LongUnsigned Value="0500" />
    </Data>
(208) .nb_of_sim_conn
PASSED
    <Data>
        <Unsigned Value="01" />
    </Data>
(209) .inactivity_time_out
PASSED
    <Data>
        <LongUnsigned Value="00B4" />
    </Data>

Mngmt Set IPv4 setup 0-0:25.1.0.255 (@2032)
(210) .DL_reference
INAPPLICABLE
    Object is not required according to OM and/or extensions
(211) .IP_address
```

INAPPLICABLE

Object is not required according to OM and/or extensions
(212) .multicast_IP_address

INAPPLICABLE

Object is not required according to OM and/or extensions
(213) .IP_options

INAPPLICABLE

Object is not required according to OM and/or extensions
(214) .subnet_mask

INAPPLICABLE

Object is not required according to OM and/or extensions
(215) .gateway_IP_address

INAPPLICABLE

Object is not required according to OM and/or extensions
(216) .use_DHCP_flag

INAPPLICABLE

Object is not required according to OM and/or extensions
(217) .primary_DNS_address

INAPPLICABLE

Object is not required according to OM and/or extensions
(218) .secondary_DNS_address

INAPPLICABLE

Object is not required according to OM and/or extensions

Mngmt Set IPv6 setup 0-0:25.7.0.255 (@2047)

(219) .DL_reference

PASSED

```
<Data>
  <OctetString Value="0000190200FF" />
</Data>
```

(220) .address_config_mode

PASSED

```
<Data>
  <Enum Value="00" />
</Data>
```

(221) .unicast_IPv6_addresses

PASSED

```
<Data>
  <Array Qty="0002" >
    <OctetString Value="FE80000000000000781D00FFFE000001" />
    <OctetString Value="FFFFFFFFFFFFFFFFFFFFFFFFFFFFFFFF" />
  </Array>
</Data>
```

(222) .multicast_IPv6_addresses

PASSED

```
<Data>
  <Array Qty="0000" >
  </Array>
</Data>
```

(223) .gateway_IPv6_address

PASSED

```
<Data>
  <Array Qty="0000" >
  </Array>
```

```

    </Data>
(224) .primary_DNS_address
PASSED
    <Data>
        <OctetString Value="FE80000000000000781D00FFFE000000" />
    </Data>
(225) .secondary_DNS_address
PASSED
    <Data>
        <OctetString Value="00000000000000000000000000000000" />
    </Data>
(226) .traffic_class
PASSED
    <Data>
        <Unsigned Value="00" />
    </Data>
(227) .neighbor_discovery_setup
PASSED
    <Data>
        <Array Qty="0000" >
            </Array>
    </Data>

Mngmt Set PPP setup 0-0:25.3.0.255 (@2061)
(228) .PHY_refernce
INAPPLICABLE
    Object is not required according to OM and/or extensions
(229) .LCP_options
INAPPLICABLE
    Object is not required according to OM and/or extensions
(230) .IPCP_options
INAPPLICABLE
    Object is not required according to OM and/or extensions
(231) .PPP_authentication
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Set Push setup - Interval_1 0-1:25.9.0.255 (@2069)
(232) .push_object_list
PASSED
    <Data>
        <Array Qty="0000" >
            </Array>
    </Data>
(233) .send_destination_and_method
PASSED
    <Data>
        <Structure Qty="0003" >
            <Enum Value="01" />
            <OctetString Value="\[fe80:0:0:0:781d:ff:fe00:0]:61616" />
            <Enum Value="00" />
        </Structure>
    </Data>
(234) .communication_window

```

PASSED

```
<Data>
  <Array Qty="0000" >
  </Array>
</Data>
```

(235) .randomisation_start_interval

PASSED

```
<Data>
  <LongUnsigned Value="0000" />
</Data>
```

(236) .number_of_retries

PASSED

```
<Data>
  <Unsigned Value="00" />
</Data>
```

(237) .repetition_delay

PASSED

```
<Data>
  <LongUnsigned Value="0000" />
</Data>
```

Mngmt Set Push setup - Interval_2 0-2:25.9.0.255 (@2079)

(238) .push_object_list

PASSED

```
<Data>
  <Array Qty="0000" >
  </Array>
</Data>
```

(239) .send_destination_and_method

PASSED

```
<Data>
  <Structure Qty="0003" >
    <Enum Value="01" />
    <OctetString Value="\[fe80:0:0:0:781d:ff:fe00:0]:61616" />
    <Enum Value="00" />
  </Structure>
</Data>
```

(240) .communication_window

PASSED

```
<Data>
  <Array Qty="0000" >
  </Array>
</Data>
```

(241) .randomisation_start_interval

PASSED

```
<Data>
  <LongUnsigned Value="0000" />
</Data>
```

(242) .number_of_retries

PASSED

```
<Data>
  <Unsigned Value="00" />
</Data>
```

(243) .repetition_delay

PASSED

```
<Data>
  <LongUnsigned Value="0000" />
</Data>
```

Mngmt Set Push setup - Interval_3 0-3:25.9.0.255 (@2089)

(244) .push_object_list

PASSED

```
<Data>
  <Array Qty="0000" >
  </Array>
</Data>
```

(245) .send_destination_and_method

PASSED

```
<Data>
  <Structure Qty="0003" >
    <Enum Value="01" />
    <OctetString Value="\[fe80:0:0:0:781d:ff:fe00:0]:61616" />
    <Enum Value="00" />
  </Structure>
</Data>
```

(246) .communication_window

PASSED

```
<Data>
  <Array Qty="0000" >
  </Array>
</Data>
```

(247) .randomisation_start_interval

PASSED

```
<Data>
  <LongUnsigned Value="0000" />
</Data>
```

(248) .number_of_retries

PASSED

```
<Data>
  <Unsigned Value="00" />
</Data>
```

(249) .repetition_delay

PASSED

```
<Data>
  <LongUnsigned Value="0000" />
</Data>
```

Mngmt Set Push setup - On Alarm 0-4:25.9.0.255 (@2099)

(250) .push_object_list

PASSED

```
<Data>
  <Array Qty="0000" >
  </Array>
</Data>
```

(251) .send_destination_and_method

PASSED

```
<Data>
  <Structure Qty="0003" >
```



```

        <Enum Value="01" />
        <OctetString Value="\[fe80:0:0:0:4400:ff:fe00:0]:61616" />
        <Enum Value="00" />
    </Structure>
</Data>
(252) .communication_window
PASSED
    <Data>
        <Array Qty="0000" >
            </Array>
        </Data>
(253) .randomisation_start_interval
PASSED
    <Data>
        <LongUnsigned Value="0000" />
    </Data>
(254) .number_of_retries
PASSED
    <Data>
        <Unsigned Value="00" />
    </Data>
(255) .repetition_delay
PASSED
    <Data>
        <LongUnsigned Value="0000" />
    </Data>

Mngmt Set Push setup - On Connectivity 0-0:25.9.0.255 (@2109)
(256) .push_object_list
PASSED
    <Data>
        <Array Qty="0000" >
            </Array>
        </Data>
(257) .send_destination_and_method
PASSED
    <Data>
        <Structure Qty="0003" >
            <Enum Value="01" />
            <OctetString Value="\[fe80:0:0:0:4400:ff:fe00:0]:61616" />
            <Enum Value="00" />
        </Structure>
    </Data>
(258) .communication_window
PASSED
    <Data>
        <Array Qty="0000" >
            </Array>
        </Data>
(259) .randomisation_start_interval
PASSED
    <Data>
        <LongUnsigned Value="0000" />
    </Data>

```

(260) .number_of_retries
PASSED

```
<Data>  
  <Unsigned Value="00" />  
</Data>
```

(261) .repetition_delay
PASSED

```
<Data>  
  <LongUnsigned Value="0000" />  
</Data>
```

Mngmt Set Push setup - On Installation 0-7:25.9.0.255 (@2119)

(262) .push_object_list
PASSED

```
<Data>  
  <Array Qty="0000" >  
  </Array>  
</Data>
```

(263) .send_destination_and_method
PASSED

```
<Data>  
  <Structure Qty="0003" >  
    <Enum Value="01" />  
    <OctetString Value="\[fe80:0:0:0:4400:ff:fe00:0]:61616" />  
    <Enum Value="00" />  
  </Structure>  
</Data>
```

(264) .communication_window
PASSED

```
<Data>  
  <Array Qty="0000" >  
  </Array>  
</Data>
```

(265) .randomisation_start_interval
PASSED

```
<Data>  
  <LongUnsigned Value="0000" />  
</Data>
```

(266) .number_of_retries
PASSED

```
<Data>  
  <Unsigned Value="00" />  
</Data>
```

(267) .repetition_delay
PASSED

```
<Data>  
  <LongUnsigned Value="0000" />  
</Data>
```

Mngmt Set Push setup - On Power down 0-5:25.9.0.255 (@2129)

(268) .push_object_list
INAPPLICABLE

Optional object is not implemented

(269) .send_destination_and_method

INAPPLICABLE

Optional object is not implemented
(270) .communication_window

INAPPLICABLE

Optional object is not implemented
(271) .randomisation_start_interval

INAPPLICABLE

Optional object is not implemented
(272) .number_of_retries

INAPPLICABLE

Optional object is not implemented
(273) .repetition_delay

INAPPLICABLE

Optional object is not implemented

Mngmt Set Push script table 0-0:10.0.108.255 (@2139)

(274) .scripts

PASSED

```
<_Data>
  <Array Qty="0010" >
    <Structure Qty="0002" >
      <LongUnsigned Value="0001" />
      <Array Qty="0001" >
        <Structure Qty="0005" >
          <Enum Value="02" />
          <LongUnsigned Value="0028" />
          <OctetString Value="0001190900FF" />
          <Integer Value="01" />
          <Integer Value="00" />
        </Structure>
      </Array>
    </Structure>
    <Structure Qty="0002" >
      <LongUnsigned Value="0002" />
      <Array Qty="0001" >
        <Structure Qty="0005" >
          <Enum Value="02" />
          <LongUnsigned Value="0028" />
          <OctetString Value="0002190900FF" />
          <Integer Value="01" />
          <Integer Value="00" />
        </Structure>
      </Array>
    </Structure>
    <Structure Qty="0002" >
      <LongUnsigned Value="0003" />
      <Array Qty="0001" >
        <Structure Qty="0005" >
          <Enum Value="02" />
          <LongUnsigned Value="0028" />
          <OctetString Value="0003190900FF" />
          <Integer Value="01" />
          <Integer Value="00" />
        </Structure>
      </Array>
    </Structure>
  </Array>
</_Data>
```

```
</Array>
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <Array Qty="0001" >
    <Structure Qty="0005" >
      <Enum Value="02" />
      <LongUnsigned Value="0028" />
      <OctetString Value="0004190900FF" />
      <Integer Value="01" />
      <Integer Value="00" />
    </Structure>
  </Array>
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0005" />
  <Array Qty="0001" >
    <Structure Qty="0005" >
      <Enum Value="02" />
      <LongUnsigned Value="0028" />
      <OctetString Value="0000190900FF" />
      <Integer Value="01" />
      <Integer Value="00" />
    </Structure>
  </Array>
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0006" />
  <Array Qty="0001" >
    <Structure Qty="0005" >
      <Enum Value="02" />
      <LongUnsigned Value="0028" />
      <OctetString Value="0007190900FF" />
      <Integer Value="01" />
      <Integer Value="00" />
    </Structure>
  </Array>
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0008" />
  <Array Qty="0001" >
    <Structure Qty="0005" >
      <Enum Value="02" />
      <LongUnsigned Value="0028" />
      <OctetString Value="0006190900FF" />
      <Integer Value="01" />
      <Integer Value="00" />
    </Structure>
  </Array>
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0008" />
  <Array Qty="0002" >
    <Structure Qty="0005" >
```

```
        <Enum Value="01" />
        <LongUnsigned Value="0007" />
        <OctetString Value="0100630100FF" />
        <Integer Value="07" />
        <DoubleLongUnsigned Value="00000002" />
    </Structure>
    <Structure Qty="0005" >
        <Enum Value="01" />
        <LongUnsigned Value="0012" />
        <OctetString Value="00002C0000FF" />
        <Integer Value="06" />
        <Enum Value="06" />
    </Structure>
</Array>
</Structure>
<Structure Qty="0002" >
    <LongUnsigned Value="0090" />
    <Array Qty="0002" >
        <Structure Qty="0005" >
            <Enum Value="01" />
            <LongUnsigned Value="0001" />
            <OctetString Value="0000600B05FF" />
            <Integer Value="02" />
            <Enum Value="90" />
        </Structure>
        <Structure Qty="0005" >
            <Enum Value="02" />
            <LongUnsigned Value="0007" />
            <OctetString Value="0000636205FF" />
            <Integer Value="02" />
            <Integer Value="00" />
        </Structure>
    </Array>
</Structure>
<Structure Qty="0002" >
    <LongUnsigned Value="0091" />
    <Array Qty="0002" >
        <Structure Qty="0005" >
            <Enum Value="01" />
            <LongUnsigned Value="0001" />
            <OctetString Value="0000600B05FF" />
            <Integer Value="02" />
            <Enum Value="91" />
        </Structure>
        <Structure Qty="0005" >
            <Enum Value="02" />
            <LongUnsigned Value="0007" />
            <OctetString Value="0000636205FF" />
            <Integer Value="02" />
            <Integer Value="00" />
        </Structure>
    </Array>
</Structure>
<Structure Qty="0002" >
```

```
<LongUnsigned Value="0092" />
<Array Qty="0002" >
  <Structure Qty="0005" >
    <Enum Value="01" />
    <LongUnsigned Value="0001" />
    <OctetString Value="0000600B05FF" />
    <Integer Value="02" />
    <Enum Value="92" />
  </Structure>
  <Structure Qty="0005" >
    <Enum Value="02" />
    <LongUnsigned Value="0007" />
    <OctetString Value="0000636205FF" />
    <Integer Value="02" />
    <Integer Value="00" />
  </Structure>
</Array>
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0093" />
  <Array Qty="0002" >
    <Structure Qty="0005" >
      <Enum Value="01" />
      <LongUnsigned Value="0001" />
      <OctetString Value="0000600B05FF" />
      <Integer Value="02" />
      <Enum Value="93" />
    </Structure>
    <Structure Qty="0005" >
      <Enum Value="02" />
      <LongUnsigned Value="0007" />
      <OctetString Value="0000636205FF" />
      <Integer Value="02" />
      <Integer Value="00" />
    </Structure>
  </Array>
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0094" />
  <Array Qty="0002" >
    <Structure Qty="0005" >
      <Enum Value="01" />
      <LongUnsigned Value="0001" />
      <OctetString Value="0000600B05FF" />
      <Integer Value="02" />
      <Enum Value="94" />
    </Structure>
    <Structure Qty="0005" >
      <Enum Value="02" />
      <LongUnsigned Value="0007" />
      <OctetString Value="0000636205FF" />
      <Integer Value="02" />
      <Integer Value="00" />
    </Structure>
  </Array>
</Structure>
```

```
</Array>
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0097" />
  <Array Qty="0002" >
    <Structure Qty="0005" >
      <Enum Value="01" />
      <LongUnsigned Value="0001" />
      <OctetString Value="0000600B05FF" />
      <Integer Value="02" />
      <Enum Value="97" />
    </Structure>
    <Structure Qty="0005" >
      <Enum Value="02" />
      <LongUnsigned Value="0007" />
      <OctetString Value="0000636205FF" />
      <Integer Value="02" />
      <Integer Value="00" />
    </Structure>
  </Array>
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0098" />
  <Array Qty="0002" >
    <Structure Qty="0005" >
      <Enum Value="01" />
      <LongUnsigned Value="0001" />
      <OctetString Value="0000600B05FF" />
      <Integer Value="02" />
      <Enum Value="98" />
    </Structure>
    <Structure Qty="0005" >
      <Enum Value="02" />
      <LongUnsigned Value="0007" />
      <OctetString Value="0000636205FF" />
      <Integer Value="02" />
      <Integer Value="00" />
    </Structure>
  </Array>
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0099" />
  <Array Qty="0002" >
    <Structure Qty="0005" >
      <Enum Value="01" />
      <LongUnsigned Value="0001" />
      <OctetString Value="0000600B05FF" />
      <Integer Value="02" />
      <Enum Value="99" />
    </Structure>
    <Structure Qty="0005" >
      <Enum Value="02" />
      <LongUnsigned Value="0007" />
      <OctetString Value="0000636205FF" />
    </Structure>
  </Array>
</Structure>
```

```
        <Integer Value="02" />
        <Integer Value="00" />
    </Structure>
</Array>
</Structure>
</Array>
</_Data>
```

Mngmt Set Push action scheduler - Interval_1 0-1:15.0.4.255 (@2144)
(275) .executed_script
PASSED

```
<Data>
  <Structure Qty="0002" >
    <OctetString Value="00000A006CFF" />
    <LongUnsigned Value="0001" />
  </Structure>
</Data>
```

(276) .type
PASSED

```
<Data>
  <Enum Value="05" />
</Data>
```

(277) .execution_time
PASSED

```
<Data>
  <Array Qty="0000" >
  </Array>
</Data>
```

Mngmt Set Push action scheduler - Interval_2 0-2:15.0.4.255 (@2150)
(278) .executed_script
PASSED

```
<Data>
  <Structure Qty="0002" >
    <OctetString Value="00000A006CFF" />
    <LongUnsigned Value="0002" />
  </Structure>
</Data>
```

(279) .type
PASSED

```
<Data>
  <Enum Value="05" />
</Data>
```

(280) .execution_time
PASSED

```
<Data>
  <Array Qty="0000" >
  </Array>
</Data>
```

Mngmt Set Push action scheduler - Interval_3 0-3:15.0.4.255 (@2156)
(281) .executed_script
PASSED

```
<Data>
```



```
        <Structure Qty="0002" >
          <OctetString Value="00000A006CFF" />
          <LongUnsigned Value="0003" />
        </Structure>
      </Data>
```

(282) .type

PASSED

```
      <Data>
        <Enum Value="05" />
      </Data>
```

(283) .execution_time

PASSED

```
      <Data>
        <Array Qty="0000" >
        </Array>
      </Data>
```

Mngmt Set Auto connect 0-0:2.1.0.255 (@2163)

(284) .mode

PASSED

```
      <Data>
        <Enum Value="65" />
      </Data>
```

(285) .repetitions

PASSED

```
      <Data>
        <Unsigned Value="00" />
      </Data>
```

(286) .repetition_delay

PASSED

```
      <Data>
        <LongUnsigned Value="0000" />
      </Data>
```

(287) .calling_window

PASSED

```
      <Data>
        <Array Qty="0000" >
        </Array>
      </Data>
```

(288) .destination_list

PASSED

```
      <Data>
        <Array Qty="0000" >
        </Array>
      </Data>
```

Mngmt Set GPRS modem setup 0-0:25.4.0.255 (@2177)

(289) .APN

INAPPLICABLE

Object is not required according to OM and/or extensions

(290) .PIN_code

INAPPLICABLE

Object is not required according to OM and/or extensions

(291) .quality_of_service


```
    <Data>
      <Unsigned Value="02" />
    </Data>
(304) .mac_max_frame_retries
PASSED
    <Data>
      <Unsigned Value="05" />
    </Data>
(305) .mac_neighbour_table_entry_TTL
PASSED
    <Data>
      <Unsigned Value="FF" />
    </Data>
(306) .mac_high_priority_window_size
PASSED
    <Data>
      <Unsigned Value="07" />
    </Data>
(307) .mac_CSMA_fairness_limit
PASSED
    <Data>
      <Unsigned Value="19" />
    </Data>
(308) .mac_beacon_randomization_window_length
PASSED
    <Data>
      <Unsigned Value="0C" />
    </Data>
(309) .mac_A
PASSED
    <Data>
      <Unsigned Value="08" />
    </Data>
(310) .mac_K
PASSED
    <Data>
      <Unsigned Value="05" />
    </Data>
(311) .mac_min_CW_attempts
PASSED
    <Data>
      <Unsigned Value="0A" />
    </Data>
(312) .mac_max_BE
PASSED
    <Data>
      <Unsigned Value="08" />
    </Data>
(313) .mac_max_CSMA_backoffs
PASSED
    <Data>
      <Unsigned Value="32" />
    </Data>
(314) .mac_min_BE
```

PASSED

```
<Data>  
  <Unsigned Value="03" />  
</Data>
```

Mngmt Set G3-PLC MAC 6LoWPAN adaptation layer setup 0-0:29.2.0.255 (@2237)

(315) .adp_max_hops

PASSED

```
<Data>  
  <Unsigned Value="08" />  
</Data>
```

(316) .adp_weak_LQI_value

PASSED

```
<Data>  
  <Unsigned Value="34" />  
</Data>
```

(317) .adp_security_level

PASSED

```
<Data>  
  <Unsigned Value="05" />  
</Data>
```

(318) .adp_routing_configuration

PASSED

```
<Data>  
  <Array Qty="0001" >  
    <Structure Qty="000E" >  
      <Unsigned Value="14" />  
      <LongUnsigned Value="0B40" />  
      <Unsigned Value="00" />  
      <Unsigned Value="00" />  
      <Unsigned Value="00" />  
      <Unsigned Value="0A" />  
      <Unsigned Value="04" />  
      <Unsigned Value="00" />  
      <Unsigned Value="00" />  
      <Unsigned Value="32" />  
      <LongUnsigned Value="000A" />  
      <Boolean Value="00" />  
      <Boolean Value="00" />  
      <Unsigned Value="00" />  
    </Structure>  
  </Array>  
</Data>
```

(319) .adp_broadcast_log_table_entry_TTL

PASSED

```
<Data>  
  <LongUnsigned Value="0002" />  
</Data>
```

(320) .adp_max_join_wait_time

PASSED

```
<Data>  
  <LongUnsigned Value="0014" />  
</Data>
```

(321) .adp_path_discovery_time

```
PASSED
  <Data>
    <Unsigned Value="28" />
  </Data>
(322) .adp_metric_type
PASSED
  <Data>
    <Unsigned Value="0F" />
  </Data>
(323) .adp_coord_short_address
PASSED
  <Data>
    <LongUnsigned Value="0000" />
  </Data>
(324) .adp_disable_default_routing
PASSED
  <Data>
    <Boolean Value="00" />
  </Data>
(325) .adp_device_type
PASSED
  <Data>
    <Enum Value="00" />
  </Data>
```

```
*****
Test Case 7 : Set Pre attributes, 71 item(s)
*****
```

```
Pre Set Clock 0-0:1.0.0.255 (@75)
(1) .time
PASSED
  <Data>
    <OctetString Value="07E60C15030E270D00FFC400" />
  </Data>
(2) .time_zone
PASSED
  <Data>
    <Long Value="FFC4" />
  </Data>
(3) .daylights_savings_begin
PASSED
  <Data>
    <OctetString Value="FFFF03FE07020000008000FF" />
  </Data>
(4) .daylights_savings_end
PASSED
  <Data>
    <OctetString Value="FFFF0AFE07030000008000FF" />
  </Data>
(5) .daylights_savings_deviation
PASSED
  <Data>
    <Integer Value="3C" />
```

```

    </Data>
(6) .daylights_savings_enabled
PASSED
    <Data>
        <Boolean Value="01" />
    </Data>

Pre Set Clock Time Shift Limit 1-0:0.9.11.255 (@94)
(7) .value
PASSED
    <Data>
        <Unsigned Value="3C" />
    </Data>

Pre Set NTP setup 0-0:25.10.0.255 (@100)
(8) .activated
INAPPLICABLE
    Optional object is not implemented

Pre Set Activity Calendar 0-0:13.0.0.255 (@112)
(9) .calendar_name_passive
PASSED
    <Data>
        <OctetString Value="\CNP_674F" />
    </Data>
(10) .season_profile_passive
PASSED
    <Data>
        <Array Qty="0004" >
            <Structure Qty="0003" >
                <OctetString Value="01" />
                <OctetString Value="FFFF0101FF000000008000FF" />
                <OctetString Value="01" />
            </Structure>
            <Structure Qty="0003" >
                <OctetString Value="02" />
                <OctetString Value="FFFF0102FF000000008000FF" />
                <OctetString Value="02" />
            </Structure>
            <Structure Qty="0003" >
                <OctetString Value="03" />
                <OctetString Value="FFFF0103FF000000008000FF" />
                <OctetString Value="03" />
            </Structure>
            <Structure Qty="0003" >
                <OctetString Value="04" />
                <OctetString Value="FFFF0104FF000000008000FF" />
                <OctetString Value="04" />
            </Structure>
        </Array>
    </Data>
(11) .week_profile_table_passive
PASSED
    <Data>

```

```
<Array Qty="0004" >
  <Structure Qty="0008" >
    <OctetString Value="01" />
    <Unsigned Value="01" />
    <Unsigned Value="01" />
    <Unsigned Value="01" />
    <Unsigned Value="01" />
    <Unsigned Value="01" />
    <Unsigned Value="01" />
    <Unsigned Value="01" />
  </Structure>
  <Structure Qty="0008" >
    <OctetString Value="02" />
    <Unsigned Value="02" />
    <Unsigned Value="02" />
    <Unsigned Value="02" />
    <Unsigned Value="02" />
    <Unsigned Value="02" />
    <Unsigned Value="02" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0008" >
    <OctetString Value="03" />
    <Unsigned Value="03" />
    <Unsigned Value="03" />
    <Unsigned Value="03" />
    <Unsigned Value="03" />
    <Unsigned Value="03" />
    <Unsigned Value="03" />
    <Unsigned Value="03" />
  </Structure>
  <Structure Qty="0008" >
    <OctetString Value="04" />
    <Unsigned Value="04" />
    <Unsigned Value="04" />
    <Unsigned Value="04" />
    <Unsigned Value="04" />
    <Unsigned Value="04" />
    <Unsigned Value="04" />
    <Unsigned Value="04" />
  </Structure>
</Array>
```

</Data>

(12) .day_profile_table_passive
PASSED

<_Data>

```
<Array Qty="0004" >
  <Structure Qty="0002" >
    <Unsigned Value="01" />
  <Array Qty="0005" >
    <Structure Qty="0003" >
      <OctetString Value="00000000" />
      <OctetString Value="00000A0064FF" />
      <LongUnsigned Value="0001" />
    </Structure>
  </Array>
</Array>
```

```
</Structure>
<Structure Qty="0003" >
  <OctetString Value="04000000" />
  <OctetString Value="00000A0064FF" />
  <LongUnsigned Value="0002" />
</Structure>
<Structure Qty="0003" >
  <OctetString Value="08000000" />
  <OctetString Value="00000A0064FF" />
  <LongUnsigned Value="0003" />
</Structure>
<Structure Qty="0003" >
  <OctetString Value="0C000000" />
  <OctetString Value="00000A0064FF" />
  <LongUnsigned Value="0004" />
</Structure>
<Structure Qty="0003" >
  <OctetString Value="10000000" />
  <OctetString Value="00000A0064FF" />
  <LongUnsigned Value="0001" />
</Structure>
</Array>
</Structure>
<Structure Qty="0002" >
  <Unsigned Value="02" />
  <Array Qty="0005" >
    <Structure Qty="0003" >
      <OctetString Value="00000000" />
      <OctetString Value="00000A0064FF" />
      <LongUnsigned Value="0003" />
    </Structure>
    <Structure Qty="0003" >
      <OctetString Value="04000000" />
      <OctetString Value="00000A0064FF" />
      <LongUnsigned Value="0003" />
    </Structure>
    <Structure Qty="0003" >
      <OctetString Value="08000000" />
      <OctetString Value="00000A0064FF" />
      <LongUnsigned Value="0003" />
    </Structure>
    <Structure Qty="0003" >
      <OctetString Value="0C000000" />
      <OctetString Value="00000A0064FF" />
      <LongUnsigned Value="0003" />
    </Structure>
    <Structure Qty="0003" >
      <OctetString Value="10000000" />
      <OctetString Value="00000A0064FF" />
      <LongUnsigned Value="0003" />
    </Structure>
  </Array>
</Structure>
<Structure Qty="0002" >
```



```
<Unsigned Value="03" />
<Array Qty="0005" >
  <Structure Qty="0003" >
    <OctetString Value="00000000" />
    <OctetString Value="00000A0064FF" />
    <LongUnsigned Value="0001" />
  </Structure>
  <Structure Qty="0003" >
    <OctetString Value="04000000" />
    <OctetString Value="00000A0064FF" />
    <LongUnsigned Value="0002" />
  </Structure>
  <Structure Qty="0003" >
    <OctetString Value="08000000" />
    <OctetString Value="00000A0064FF" />
    <LongUnsigned Value="0003" />
  </Structure>
  <Structure Qty="0003" >
    <OctetString Value="0C000000" />
    <OctetString Value="00000A0064FF" />
    <LongUnsigned Value="0004" />
  </Structure>
  <Structure Qty="0003" >
    <OctetString Value="10000000" />
    <OctetString Value="00000A0064FF" />
    <LongUnsigned Value="0001" />
  </Structure>
</Array>
</Structure>
<Structure Qty="0002" >
  <Unsigned Value="04" />
  <Array Qty="0005" >
    <Structure Qty="0003" >
      <OctetString Value="00000000" />
      <OctetString Value="00000A0064FF" />
      <LongUnsigned Value="0001" />
    </Structure>
    <Structure Qty="0003" >
      <OctetString Value="04000000" />
      <OctetString Value="00000A0064FF" />
      <LongUnsigned Value="0002" />
    </Structure>
    <Structure Qty="0003" >
      <OctetString Value="08000000" />
      <OctetString Value="00000A0064FF" />
      <LongUnsigned Value="0003" />
    </Structure>
    <Structure Qty="0003" >
      <OctetString Value="0C000000" />
      <OctetString Value="00000A0064FF" />
      <LongUnsigned Value="0004" />
    </Structure>
    <Structure Qty="0003" >
      <OctetString Value="10000000" />
    </Structure>
  </Array>
</Structure>
```

```
        <OctetString Value="00000A0064FF" />
        <LongUnsigned Value="0001" />
    </Structure>
</Array>
</Structure>
</Array>
</_Data>
```

(13) .activate_passive_calendar_time
PASSED

```
<Data>
  <OctetString Value="FFFFFFFFFFFFFFFF008000FF" />
</Data>
```

Pre Set Special Days Table 0-0:11.0.0.255 (@125)

(14) .entries
PASSED

```
<_Data>
  <Array Qty="001E" >
    <Structure Qty="0003" >
      <LongUnsigned Value="0001" />
      <OctetString Value="FFFF0101FF" />
      <Unsigned Value="02" />
    </Structure>
    <Structure Qty="0003" >
      <LongUnsigned Value="0002" />
      <OctetString Value="FFFF0102FF" />
      <Unsigned Value="02" />
    </Structure>
    <Structure Qty="0003" >
      <LongUnsigned Value="0003" />
      <OctetString Value="FFFF0103FF" />
      <Unsigned Value="02" />
    </Structure>
    <Structure Qty="0003" >
      <LongUnsigned Value="0004" />
      <OctetString Value="FFFF0104FF" />
      <Unsigned Value="02" />
    </Structure>
    <Structure Qty="0003" >
      <LongUnsigned Value="0005" />
      <OctetString Value="FFFF0105FF" />
      <Unsigned Value="02" />
    </Structure>
    <Structure Qty="0003" >
      <LongUnsigned Value="0006" />
      <OctetString Value="FFFF0106FF" />
      <Unsigned Value="02" />
    </Structure>
    <Structure Qty="0003" >
      <LongUnsigned Value="0007" />
      <OctetString Value="FFFF0107FF" />
      <Unsigned Value="02" />
    </Structure>
    <Structure Qty="0003" >
```

```
<LongUnsigned Value="0008" />
<OctetString Value="FFFF0108FF" />
<Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0009" />
  <OctetString Value="FFFF0109FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="000A" />
  <OctetString Value="FFFF010AFF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="000B" />
  <OctetString Value="FFFF0201FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="000C" />
  <OctetString Value="FFFF0202FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="000D" />
  <OctetString Value="FFFF0203FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="000E" />
  <OctetString Value="FFFF0204FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="000F" />
  <OctetString Value="FFFF0205FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0010" />
  <OctetString Value="FFFF0206FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0011" />
  <OctetString Value="FFFF0207FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0012" />
  <OctetString Value="FFFF0208FF" />
  <Unsigned Value="02" />
</Structure>
```

```
<Structure Qty="0003" >
  <LongUnsigned Value="0013" />
  <OctetString Value="FFFF0209FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0014" />
  <OctetString Value="FFFF020AFF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0015" />
  <OctetString Value="FFFF0301FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0016" />
  <OctetString Value="FFFF0302FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0017" />
  <OctetString Value="FFFF0303FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0018" />
  <OctetString Value="FFFF0304FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0019" />
  <OctetString Value="FFFF0305FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="001A" />
  <OctetString Value="FFFF0306FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="001B" />
  <OctetString Value="FFFF0307FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="001C" />
  <OctetString Value="FFFF0308FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="001D" />
  <OctetString Value="FFFF0309FF" />
  <Unsigned Value="02" />
</Structure>
```

```
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="001E" />
  <OctetString Value="FFFF030AFF" />
  <Unsigned Value="02" />
</Structure>
</Array>
</_Data>
```

Pre Set Register activation - Energy 0-0:14.0.1.255 (@129)
(15) .register_assignment
PASSED

```
<_Data>
  <Array Qty="0038" >
    <Structure Qty="0002" >
      <LongUnsigned Value="0003" />
      <OctetString Value="0100010800FF" />
    </Structure>
    <Structure Qty="0002" >
      <LongUnsigned Value="0003" />
      <OctetString Value="0100010801FF" />
    </Structure>
    <Structure Qty="0002" >
      <LongUnsigned Value="0003" />
      <OctetString Value="0100010802FF" />
    </Structure>
    <Structure Qty="0002" >
      <LongUnsigned Value="0003" />
      <OctetString Value="0100010803FF" />
    </Structure>
    <Structure Qty="0002" >
      <LongUnsigned Value="0003" />
      <OctetString Value="0100010804FF" />
    </Structure>
    <Structure Qty="0002" >
      <LongUnsigned Value="0003" />
      <OctetString Value="0100020800FF" />
    </Structure>
    <Structure Qty="0002" >
      <LongUnsigned Value="0003" />
      <OctetString Value="0100020801FF" />
    </Structure>
    <Structure Qty="0002" >
      <LongUnsigned Value="0003" />
      <OctetString Value="0100020802FF" />
    </Structure>
    <Structure Qty="0002" >
      <LongUnsigned Value="0003" />
      <OctetString Value="0100020803FF" />
    </Structure>
    <Structure Qty="0002" >
      <LongUnsigned Value="0003" />
      <OctetString Value="0100020804FF" />
    </Structure>
```

```
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100030800FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100030801FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100030802FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100030803FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100030804FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100040800FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100040801FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100040802FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100040803FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100040804FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100050800FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100050801FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100050802FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
```

```
<OctetString Value="0100050803FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100050804FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100060800FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100060801FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100060802FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100060803FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100060804FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100070800FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100070801FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100070802FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100070803FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100070804FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100080800FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100080801FF" />
</Structure>
```

```
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100080802FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100080803FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100080804FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100090800FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100090801FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100090802FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100090803FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100090804FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100A0800FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100A0801FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100A0802FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100A0803FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
  <OctetString Value="0100A0804FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0003" />
```



```
        <OctetString Value="01000F0800FF" />
    </Structure>
    <Structure Qty="0002" >
        <LongUnsigned Value="0003" />
        <OctetString Value="01000F0801FF" />
    </Structure>
    <Structure Qty="0002" >
        <LongUnsigned Value="0003" />
        <OctetString Value="01000F0802FF" />
    </Structure>
    <Structure Qty="0002" >
        <LongUnsigned Value="0003" />
        <OctetString Value="01000F0803FF" />
    </Structure>
    <Structure Qty="0002" >
        <LongUnsigned Value="0003" />
        <OctetString Value="01000F0804FF" />
    </Structure>
    <Structure Qty="0002" >
        <LongUnsigned Value="0003" />
        <OctetString Value="0100100800FF" />
    </Structure>
</Array>
</_Data>
(16) .mask_list
PASSED
```

```
<_Data>
  <Array Qty="0004" >
    <Structure Qty="0002" >
      <OctetString Value="01" />
      <Array Qty="0017" >
        <Unsigned Value="00" />
        <Unsigned Value="01" />
        <Unsigned Value="05" />
        <Unsigned Value="06" />
        <Unsigned Value="0A" />
        <Unsigned Value="0B" />
        <Unsigned Value="0F" />
        <Unsigned Value="10" />
        <Unsigned Value="14" />
        <Unsigned Value="15" />
        <Unsigned Value="19" />
        <Unsigned Value="1A" />
        <Unsigned Value="1E" />
        <Unsigned Value="1F" />
        <Unsigned Value="23" />
        <Unsigned Value="24" />
        <Unsigned Value="28" />
        <Unsigned Value="29" />
        <Unsigned Value="2D" />
        <Unsigned Value="2E" />
        <Unsigned Value="32" />
        <Unsigned Value="33" />
        <Unsigned Value="37" />
      </Array>
    </Structure>
  </Array>
</_Data>
```

```
</Array>
</Structure>
<Structure Qty="0002" >
  <OctetString Value="02" />
  <Array Qty="0017" >
    <Unsigned Value="00" />
    <Unsigned Value="02" />
    <Unsigned Value="05" />
    <Unsigned Value="07" />
    <Unsigned Value="0A" />
    <Unsigned Value="0C" />
    <Unsigned Value="0F" />
    <Unsigned Value="11" />
    <Unsigned Value="14" />
    <Unsigned Value="16" />
    <Unsigned Value="19" />
    <Unsigned Value="1B" />
    <Unsigned Value="1E" />
    <Unsigned Value="20" />
    <Unsigned Value="23" />
    <Unsigned Value="25" />
    <Unsigned Value="28" />
    <Unsigned Value="2A" />
    <Unsigned Value="2D" />
    <Unsigned Value="2F" />
    <Unsigned Value="32" />
    <Unsigned Value="34" />
    <Unsigned Value="37" />
  </Array>
</Structure>
<Structure Qty="0002" >
  <OctetString Value="03" />
  <Array Qty="0017" >
    <Unsigned Value="00" />
    <Unsigned Value="03" />
    <Unsigned Value="05" />
    <Unsigned Value="08" />
    <Unsigned Value="0A" />
    <Unsigned Value="0D" />
    <Unsigned Value="0F" />
    <Unsigned Value="12" />
    <Unsigned Value="14" />
    <Unsigned Value="17" />
    <Unsigned Value="19" />
    <Unsigned Value="1C" />
    <Unsigned Value="1E" />
    <Unsigned Value="21" />
    <Unsigned Value="23" />
    <Unsigned Value="26" />
    <Unsigned Value="28" />
    <Unsigned Value="2B" />
    <Unsigned Value="2D" />
    <Unsigned Value="30" />
    <Unsigned Value="32" />
  </Array>
</Structure>
```

```

        <Unsigned Value="35" />
        <Unsigned Value="37" />
    </Array>
</Structure>
<Structure Qty="0002" >
    <OctetString Value="04" />
    <Array Qty="0017" >
        <Unsigned Value="00" />
        <Unsigned Value="04" />
        <Unsigned Value="05" />
        <Unsigned Value="09" />
        <Unsigned Value="0A" />
        <Unsigned Value="0E" />
        <Unsigned Value="0F" />
        <Unsigned Value="13" />
        <Unsigned Value="14" />
        <Unsigned Value="18" />
        <Unsigned Value="19" />
        <Unsigned Value="1D" />
        <Unsigned Value="1E" />
        <Unsigned Value="22" />
        <Unsigned Value="23" />
        <Unsigned Value="27" />
        <Unsigned Value="28" />
        <Unsigned Value="2C" />
        <Unsigned Value="2D" />
        <Unsigned Value="31" />
        <Unsigned Value="32" />
        <Unsigned Value="36" />
        <Unsigned Value="37" />
    </Array>
</Structure>
</Array>
</_Data>

```

Pre Set Register activation - Maximum Demand 0-0:14.0.2.255 (@135)

(17) .register_assignment

PASSED

```

<_Data>
  <Array Qty="0049" >
    <Structure Qty="0002" >
      <LongUnsigned Value="0005" />
      <OctetString Value="0100010400FF" />
    </Structure>
    <Structure Qty="0002" >
      <LongUnsigned Value="0004" />
      <OctetString Value="0100010500FF" />
    </Structure>
    <Structure Qty="0002" >
      <LongUnsigned Value="0004" />
      <OctetString Value="0100010600FF" />
    </Structure>
    <Structure Qty="0002" >
      <LongUnsigned Value="0004" />
    </Structure>
  </Array>

```

```
<OctetString Value="0100010601FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100010602FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100010603FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100010604FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0005" />
  <OctetString Value="0100020400FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100020500FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100020600FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100020601FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100020602FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100020603FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100020604FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0005" />
  <OctetString Value="0100030400FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100030500FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100030600FF" />
</Structure>
```

```
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100030601FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100030602FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100030603FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100030604FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0005" />
  <OctetString Value="0100040400FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100040500FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100040600FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100040601FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100040602FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100040603FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100040604FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0005" />
  <OctetString Value="0100050400FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100050500FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
```

```
<OctetString Value="0100050600FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100050601FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100050602FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100050603FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100050604FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0005" />
  <OctetString Value="0100060400FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100060500FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100060600FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100060601FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100060602FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100060603FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100060604FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0005" />
  <OctetString Value="0100070400FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100070500FF" />
</Structure>
```

```
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100070600FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100070601FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100070602FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100070603FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100070604FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0005" />
  <OctetString Value="0100080400FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100080500FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100080600FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100080601FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100080602FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100080603FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100080604FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0005" />
  <OctetString Value="0100090400FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
```

```
<OctetString Value="0100090500FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100090600FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100090601FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100090602FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100090603FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="0100090604FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0005" />
  <OctetString Value="01000A0400FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="01000A0500FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="01000A0600FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="01000A0601FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="01000A0602FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="01000A0603FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0004" />
  <OctetString Value="01000A0604FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0005" />
  <OctetString Value="0100011800FF" />
</Structure>
```



```
<Structure Qty="0002" >
  <LongUnsigned Value="0005" />
  <OctetString Value="01000F1800FF" />
</Structure>
<Structure Qty="0002" >
  <LongUnsigned Value="0005" />
  <OctetString Value="0100101800FF" />
</Structure>
</Array>
</_Data>
(18) .mask_list
PASSED
```

```
<_Data>
  <Array Qty="0004" >
    <Structure Qty="0002" >
      <OctetString Value="01" />
      <Array Qty="002B" >
        <Unsigned Value="00" />
        <Unsigned Value="01" />
        <Unsigned Value="02" />
        <Unsigned Value="03" />
        <Unsigned Value="07" />
        <Unsigned Value="08" />
        <Unsigned Value="09" />
        <Unsigned Value="0A" />
        <Unsigned Value="0E" />
        <Unsigned Value="0F" />
        <Unsigned Value="10" />
        <Unsigned Value="11" />
        <Unsigned Value="15" />
        <Unsigned Value="16" />
        <Unsigned Value="17" />
        <Unsigned Value="18" />
        <Unsigned Value="1C" />
        <Unsigned Value="1D" />
        <Unsigned Value="1E" />
        <Unsigned Value="1F" />
        <Unsigned Value="23" />
        <Unsigned Value="24" />
        <Unsigned Value="25" />
        <Unsigned Value="26" />
        <Unsigned Value="2A" />
        <Unsigned Value="2B" />
        <Unsigned Value="2C" />
        <Unsigned Value="2D" />
        <Unsigned Value="31" />
        <Unsigned Value="32" />
        <Unsigned Value="33" />
        <Unsigned Value="34" />
        <Unsigned Value="38" />
        <Unsigned Value="39" />
        <Unsigned Value="3A" />
        <Unsigned Value="3B" />
        <Unsigned Value="3F" />
      </Array>
    </Structure>
  </Array>
</_Data>
```

```
<Unsigned Value="40" />
<Unsigned Value="41" />
<Unsigned Value="42" />
<Unsigned Value="46" />
<Unsigned Value="47" />
<Unsigned Value="48" />
</Array>
</Structure>
<Structure Qty="0002" >
  <OctetString Value="02" />
  <Array Qty="002B" >
    <Unsigned Value="00" />
    <Unsigned Value="01" />
    <Unsigned Value="02" />
    <Unsigned Value="04" />
    <Unsigned Value="07" />
    <Unsigned Value="08" />
    <Unsigned Value="09" />
    <Unsigned Value="0B" />
    <Unsigned Value="0E" />
    <Unsigned Value="0F" />
    <Unsigned Value="10" />
    <Unsigned Value="12" />
    <Unsigned Value="15" />
    <Unsigned Value="16" />
    <Unsigned Value="17" />
    <Unsigned Value="19" />
    <Unsigned Value="1C" />
    <Unsigned Value="1D" />
    <Unsigned Value="1E" />
    <Unsigned Value="20" />
    <Unsigned Value="23" />
    <Unsigned Value="24" />
    <Unsigned Value="25" />
    <Unsigned Value="27" />
    <Unsigned Value="2A" />
    <Unsigned Value="2B" />
    <Unsigned Value="2C" />
    <Unsigned Value="2E" />
    <Unsigned Value="31" />
    <Unsigned Value="32" />
    <Unsigned Value="33" />
    <Unsigned Value="35" />
    <Unsigned Value="38" />
    <Unsigned Value="39" />
    <Unsigned Value="3A" />
    <Unsigned Value="3C" />
    <Unsigned Value="3F" />
    <Unsigned Value="40" />
    <Unsigned Value="41" />
    <Unsigned Value="43" />
    <Unsigned Value="46" />
    <Unsigned Value="47" />
    <Unsigned Value="48" />
```

```
</Array>
</Structure>
<Structure Qty="0002" >
  <OctetString Value="03" />
  <Array Qty="002B" >
    <Unsigned Value="00" />
    <Unsigned Value="01" />
    <Unsigned Value="02" />
    <Unsigned Value="05" />
    <Unsigned Value="07" />
    <Unsigned Value="08" />
    <Unsigned Value="09" />
    <Unsigned Value="0C" />
    <Unsigned Value="0E" />
    <Unsigned Value="0F" />
    <Unsigned Value="10" />
    <Unsigned Value="13" />
    <Unsigned Value="15" />
    <Unsigned Value="16" />
    <Unsigned Value="17" />
    <Unsigned Value="1A" />
    <Unsigned Value="1C" />
    <Unsigned Value="1D" />
    <Unsigned Value="1E" />
    <Unsigned Value="21" />
    <Unsigned Value="23" />
    <Unsigned Value="24" />
    <Unsigned Value="25" />
    <Unsigned Value="28" />
    <Unsigned Value="2A" />
    <Unsigned Value="2B" />
    <Unsigned Value="2C" />
    <Unsigned Value="2F" />
    <Unsigned Value="31" />
    <Unsigned Value="32" />
    <Unsigned Value="33" />
    <Unsigned Value="36" />
    <Unsigned Value="38" />
    <Unsigned Value="39" />
    <Unsigned Value="3A" />
    <Unsigned Value="3D" />
    <Unsigned Value="3F" />
    <Unsigned Value="40" />
    <Unsigned Value="41" />
    <Unsigned Value="44" />
    <Unsigned Value="46" />
    <Unsigned Value="47" />
    <Unsigned Value="48" />
  </Array>
</Structure>
<Structure Qty="0002" >
  <OctetString Value="04" />
  <Array Qty="002B" >
    <Unsigned Value="00" />
```

```
<Unsigned Value="01" />
<Unsigned Value="02" />
<Unsigned Value="06" />
<Unsigned Value="07" />
<Unsigned Value="08" />
<Unsigned Value="09" />
<Unsigned Value="0D" />
<Unsigned Value="0E" />
<Unsigned Value="0F" />
<Unsigned Value="10" />
<Unsigned Value="14" />
<Unsigned Value="15" />
<Unsigned Value="16" />
<Unsigned Value="17" />
<Unsigned Value="1B" />
<Unsigned Value="1C" />
<Unsigned Value="1D" />
<Unsigned Value="1E" />
<Unsigned Value="22" />
<Unsigned Value="23" />
<Unsigned Value="24" />
<Unsigned Value="25" />
<Unsigned Value="29" />
<Unsigned Value="2A" />
<Unsigned Value="2B" />
<Unsigned Value="2C" />
<Unsigned Value="30" />
<Unsigned Value="31" />
<Unsigned Value="32" />
<Unsigned Value="33" />
<Unsigned Value="37" />
<Unsigned Value="38" />
<Unsigned Value="39" />
<Unsigned Value="3A" />
<Unsigned Value="3E" />
<Unsigned Value="3F" />
<Unsigned Value="40" />
<Unsigned Value="41" />
<Unsigned Value="45" />
<Unsigned Value="46" />
<Unsigned Value="47" />
<Unsigned Value="48" />
</Array>
</Structure>
</Array>
</_Data>
```

Pre Set Consumer Message Code - Meter Display 0-0:96.13.1.255 (@343)
(19) .value
PASSED

```
<Data>
  <OctetString Value="" />
</Data>
```

Pre Set Consumer Message Text - Consumer Information 0-0:96.13.0.255 (@347)
(20) .value
PASSED
 <Data>
 <OctetString Value="\12345678" />
 </Data>

Pre Set IEC HDLC setup - Consumer Information Interface 0-1:22.0.0.255 (@376)
(21) .comm_speed
PASSED
 <Data>
 <Enum Value="05" />
 </Data>

(22) .window_size_transmit
PASSED

 <Data>
 <Unsigned Value="01" />
 </Data>

(23) .window_size_receive
PASSED

 <Data>
 <Unsigned Value="01" />
 </Data>

(24) .max_info_field_lenght_transmit
PASSED

 <Data>
 <LongUnsigned Value="00F2" />
 </Data>

(25) .max_info_field_lenght_receive
PASSED

 <Data>
 <LongUnsigned Value="00F2" />
 </Data>

(26) .inter_octet_time_out
PASSED

 <Data>
 <LongUnsigned Value="0019" />
 </Data>

(27) .inactivity_time_out
PASSED

 <Data>
 <LongUnsigned Value="0078" />
 </Data>

Pre Set Time threshold for long power failure 0-0:96.7.20.255 (@1181)
(28) .value
PASSED
 <Data>
 <LongUnsigned Value="00B4" />
 </Data>

Pre Set Threshold for voltage sag 1-0:12.31.0.255 (@1193)
(29) .value
PASSED

```
<Data>
  <LongUnsigned Value="00CF" />
</Data>
```

Pre Set Time threshold for voltage sag 1-0:12.43.0.255 (@1199)
(30) .value

PASSED

```
<Data>
  <LongUnsigned Value="001E" />
</Data>
```

Pre Set Threshold for voltage swell 1-0:12.35.0.255 (@1253)
(31) .value

PASSED

```
<Data>
  <LongUnsigned Value="00FD" />
</Data>
```

Pre Set Time threshold for voltage swell 1-0:12.44.0.255 (@1259)
(32) .value

PASSED

```
<Data>
  <LongUnsigned Value="001E" />
</Data>
```

Pre Set Threshold for missing voltage (voltage cut) 1-0:12.39.0.255 (@1313)
(33) .value

PASSED

```
<Data>
  <LongUnsigned Value="0067" />
</Data>
```

Pre Set Time threshold for voltage cut 1-0:12.45.0.255 (@1319)
(34) .value

PASSED

```
<Data>
  <LongUnsigned Value="001E" />
</Data>
```

Pre Set Measurement Period 3 for Instantaneous values 1-0:0.8.2.255 (@1559)
(35) .value

PASSED

```
<Data>
  <DoubleLongUnsigned Value="00000258" />
</Data>
```

Pre Set M-Bus client channel 1 0-1:24.1.0.255 (@1574)
(36) .capture_period

PASSED

```
<Data>
  <DoubleLongUnsigned Value="00000E10" />
</Data>
```

Pre Set M-Bus client channel 2 0-2:24.1.0.255 (@1596)

(37) .capture_period
PASSED

```
<Data>
  <DoubleLongUnsigned Value="00000E10" />
</Data>
```

Pre Set M-Bus client channel 3 0-3:24.1.0.255 (@1618)

(38) .capture_period
PASSED

```
<Data>
  <DoubleLongUnsigned Value="00000E10" />
</Data>
```

Pre Set M-Bus client channel 4 0-4:24.1.0.255 (@1640)

(39) .capture_period
PASSED

```
<Data>
  <DoubleLongUnsigned Value="00000E10" />
</Data>
```

Pre Set M-Bus Master Disconnect control object 1 0-1:24.4.0.255 (@1882)

(40) .control_mode
PASSED

```
<Data>
  <Enum Value="05" />
</Data>
```

Pre Set M-Bus Master Disconnect control object 2 0-2:24.4.0.255 (@1890)

(41) .control_mode
PASSED

```
<Data>
  <Enum Value="05" />
</Data>
```

Pre Set M-Bus Master Disconnect control object 3 0-3:24.4.0.255 (@1898)

(42) .control_mode
PASSED

```
<Data>
  <Enum Value="05" />
</Data>
```

Pre Set M-Bus Master Disconnect control object 4 0-4:24.4.0.255 (@1906)

(43) .control_mode
PASSED

```
<Data>
  <Enum Value="05" />
</Data>
```

Pre Set IEC local port setup - IEC Optical port 0-0:20.0.0.255 (@2001)

(44) .default_mode
PASSED

```
<Data>
  <Enum Value="01" />
</Data>
```

(45) .default_baud

PASSED

```
<Data>
  <Enum Value="05" />
</Data>
```

(46) .prop_baud

PASSED

```
<Data>
  <Enum Value="05" />
</Data>
```

(47) .response_time

PASSED

```
<Data>
  <Enum Value="00" />
</Data>
```

(48) .device_addr

PASSED

```
<Data>
  <OctetString Value="\12000016" />
</Data>
```

(49) .pass_p1

PASSED

```
<Data>
  <OctetString Value="\12345678" />
</Data>
```

(50) .pass_p2

PASSED

```
<Data>
  <OctetString Value="\12345678" />
</Data>
```

(51) .pass_p3

PASSED

```
<Data>
  <OctetString Value="\12345678" />
</Data>
```

Pre Set IEC HDLC setup - HDLC Optical port 0-0:22.0.0.255 (@2012)

(52) .comm_speed

PASSED

```
<Data>
  <Enum Value="05" />
</Data>
```

(53) .window_size_transmit

PASSED

```
<Data>
  <Unsigned Value="01" />
</Data>
```

(54) .window_size_receive

PASSED

```
<Data>
  <Unsigned Value="01" />
</Data>
```

(55) .max_info_field_lenght_transmit

PASSED


```
        <Data>
          <LongUnsigned Value="00F2" />
        </Data>
(56) .max_info_field_lenght_receive
PASSED
        <Data>
          <LongUnsigned Value="00F2" />
        </Data>
(57) .inter_octet_time_out
PASSED
        <Data>
          <LongUnsigned Value="0019" />
        </Data>
(58) .inactivity_time_out
PASSED
        <Data>
          <LongUnsigned Value="0078" />
        </Data>

Pre Set G3-PLC MAC setup 0-0:29.1.0.255 (@2212)
(59) .mac_TMR_TTL
PASSED
        <Data>
          <Unsigned Value="02" />
        </Data>
(60) .mac_max_frame_retries
PASSED
        <Data>
          <Unsigned Value="05" />
        </Data>
(61) .mac_neighbour_table_entry_TTL
PASSED
        <Data>
          <Unsigned Value="FF" />
        </Data>
(62) .mac_high_priority_window_size
PASSED
        <Data>
          <Unsigned Value="07" />
        </Data>
(63) .mac_CSMA_fairness_limit
PASSED
        <Data>
          <Unsigned Value="19" />
        </Data>
(64) .mac_beacon_randomization_window_length
PASSED
        <Data>
          <Unsigned Value="0C" />
        </Data>
(65) .mac_A
PASSED
        <Data>
          <Unsigned Value="08" />
        </Data>
```

```
        </Data>
(66) .mac_K
PASSED
        <Data>
            <Unsigned Value="05" />
        </Data>
(67) .mac_min_CW_attempts
PASSED
        <Data>
            <Unsigned Value="0A" />
        </Data>
(68) .mac_max_BE
PASSED
        <Data>
            <Unsigned Value="08" />
        </Data>
(69) .mac_max_CSMA_backoffs
PASSED
        <Data>
            <Unsigned Value="32" />
        </Data>
(70) .mac_min_BE
PASSED
        <Data>
            <Unsigned Value="03" />
        </Data>
(71) Pre Set passive calendar name and check
PASSED
        calendar_name_passive set to "CNP_7A55"
```

```
*****
Test Case 8 : Selective access of profiles, 18 item(s)
*****
```

```
Mngmt Get Data of billing period 1 0-0:98.1.0.255 (@158)
(1) .buffer
PASSED
    Earliest date: 21-DEC-2022 03:22:29, latest date: 02-JUN-2023 00:00:00
    Middle date: 21-DEC-2022 07:22:29

Mngmt Get Disconnecter Control Log 0-0:99.98.2.255 (@193)
(2) .buffer
PASSED
    Earliest date: 20-DEC-2022 06:57:46, latest date: 20-DEC-2022 11:38:01
    Middle date: 20-DEC-2022 06:58:24

Mngmt Get Standard Event Log 0-0:99.98.0.255 (@301)
(3) .buffer
PASSED
    Earliest date: 14-DEC-2022 23:59:50, latest date: 15-JUN-2023 03:15:07
    Middle date: 02-FEB-2023 00:00:04

Mngmt Get Fraud Detection Log 0-0:99.98.1.255 (@316)
(4) .buffer
```

PASSED

Earliest date: 20-DEC-2022 07:09:16, latest date: 21-DEC-2022 14:39:33
Middle date: 20-DEC-2022 07:10:50

Mngmt Get Communication Log 0-0:99.98.5.255 (@331)
(5) .buffer

PASSED

Earliest date: 08-DEC-2022 13:58:40, latest date: 21-DEC-2022 13:45:44
Middle date: 20-DEC-2022 09:06:46

Mngmt Get Load profile with period 1 i.e. General Load Profile 1-0:99.1.0.255
(@1146)
(6) .buffer

PASSED

Earliest date: 21-DEC-2022 03:30:00, latest date: 21-DEC-2022 15:15:00
Middle date: 21-DEC-2022 10:30:00

Mngmt Get Load profile with period 2 i.e. Daily Values Profile 1-0:99.2.0.255
(@1161)
(7) .buffer

PASSED

Earliest date: 19-DEC-2022 00:00:00, latest date: 25-DEC-2022 00:00:00
Middle date: 24-DEC-2022 00:00:00

Mngmt Get Power Failure Event Log 1-0:99.97.0.255 (@1325)
(8) .buffer

PASSED

Earliest date: 08-DEC-2022 13:52:01, latest date: 20-DEC-2022 08:59:23
Middle date: 08-DEC-2022 13:56:42

Mngmt Get Power Quality Log 0-0:99.98.4.255 (@1340)
(9) .buffer

PASSED

Earliest date: 01-JAN-2018 00:00:00, latest date: 20-DEC-2022 09:20:01
Middle date: 08-DEC-2022 13:51:54

Mngmt Get M-Bus Master Load profile for channel 1 0-1:24.3.0.255 (@1838)
(10) .buffer

PASSED

Earliest date: 01-JUN-2022 00:00:00, latest date: 01-DEC-2022 00:00:00
Middle date: 01-SEP-2022 00:00:00

Mngmt Get M-Bus Master Load profile for channel 2 0-2:24.3.0.255 (@1849)
(11) .buffer

PASSED

Earliest date: 01-JUN-2022 00:00:00, latest date: 01-DEC-2022 00:00:00
Middle date: 01-SEP-2022 00:00:00

Mngmt Get M-Bus Master Load profile for channel 3 0-3:24.3.0.255 (@1860)
(12) .buffer

PASSED

Earliest date: 01-JUN-2022 00:00:00, latest date: 01-DEC-2022 00:00:00
Middle date: 01-SEP-2022 00:00:00

Mngmt Get M-Bus Master Load profile for channel 4 0-4:24.3.0.255 (@1871)
(13) .buffer
PASSED
Earliest date: 01-JUN-2022 00:00:00, latest date: 01-DEC-2022 00:00:00
Middle date: 01-SEP-2022 00:00:00

Mngmt Get M-Bus Master Control log object 1 0-1:24.5.0.255 (@1941)
(14) .buffer
PASSED
Earliest date: 01-JAN-2018 00:00:00, latest date: 08-DEC-2022 13:49:56
Middle date: 08-DEC-2022 13:49:51

Mngmt Get M-Bus Master Control log object 2 0-2:24.5.0.255 (@1952)
(15) .buffer
PASSED
Earliest date: 01-JAN-2018 00:00:00, latest date: 08-DEC-2022 13:50:12
Middle date: 08-DEC-2022 13:50:07

Mngmt Get M-Bus Master Control log object 3 0-3:24.5.0.255 (@1963)
(16) .buffer
PASSED
Earliest date: 01-JAN-2018 00:00:00, latest date: 08-DEC-2022 13:50:31
Middle date: 08-DEC-2022 13:50:27

Mngmt Get M-Bus Master Control log object 4 0-4:24.5.0.255 (@1974)
(17) .buffer
PASSED
Earliest date: 01-JAN-2018 00:00:00, latest date: 08-DEC-2022 13:50:48
Middle date: 08-DEC-2022 13:50:44

Mngmt Get M-Bus Event Log 0-0:99.98.3.255 (@1989)
(18) .buffer
PASSED
Earliest date: 01-JAN-2018 00:00:00, latest date: 07-MAY-2022 10:11:51
Middle date: 01-JAN-2018 00:00:00

Test Case 9 : Multiple references, 4 item(s)

(1) Public, logical names
PASSED
Reading 5 attributes
<Result Qty="0005" >
 <Data>
 <OctetString Value="0000290000FF" />
 </Data>
 <Data>
 <OctetString Value="0000280000FF" />
 </Data>
 <Data>
 <OctetString Value="00002B0101FF" />
 </Data>
 <Data>
 <OctetString Value="00002B0100FF" />

```
</Data>
<Data>
  <OctetString Value="00002A0000FF" />
</Data>
</Result>
```

(2) Mngmt, logical names

PASSED

Reading 16 attributes

```
<Result Qty="0010" >
  <Data>
    <OctetString Value="0000020100FF" />
  </Data>
  <Data>
    <OctetString Value="00030F0004FF" />
  </Data>
  <Data>
    <OctetString Value="00020F0004FF" />
  </Data>
  <Data>
    <OctetString Value="00010F0004FF" />
  </Data>
  <Data>
    <OctetString Value="00000A0006CFF" />
  </Data>
  <Data>
    <OctetString Value="0007190900FF" />
  </Data>
  <Data>
    <OctetString Value="0000190900FF" />
  </Data>
  <Data>
    <OctetString Value="0004190900FF" />
  </Data>
  <Data>
    <OctetString Value="0003190900FF" />
  </Data>
  <Data>
    <OctetString Value="0002190900FF" />
  </Data>
  <Data>
    <OctetString Value="0001190900FF" />
  </Data>
  <Data>
    <OctetString Value="0000190000FF" />
  </Data>
  <Data>
    <OctetString Value="0000160000FF" />
  </Data>
  <Data>
    <OctetString Value="0100040700FF" />
  </Data>
  <Data>
    <OctetString Value="0100030700FF" />
  </Data>
```

```
    <Data>
      <OctetString Value="0100020700FF" />
    </Data>
  </Result>
```

(3) Mngmt, mixed attributes
PASSED

Reading 9 attributes

```
<Result Qty="0009" >
  <Data>
    <OctetString Value="0000290000FF" />
  </Data>
  <Data>
    <Enum Value="00" />
  </Data>
  <Data>
    <Long Value="FFC4" />
  </Data>
  <Data>
    <OctetString Value="04" />
  </Data>
  <Data>
    <Enum Value="01" />
  </Data>
  <Data>
    <Structure Qty="0004" >
      <LongUnsigned Value="0008" />
      <OctetString Value="0000010000FF" />
      <Integer Value="02" />
      <LongUnsigned Value="0000" />
    </Structure>
  </Data>
  <Data>
    <DoubleLongUnsigned Value="0000001E" />
  </Data>
  <Data>
    <DoubleLongUnsigned Value="00000064" />
  </Data>
  <Data>
    <LongUnsigned Value="0001" />
  </Data>
</Result>
```

(4) Mngmt, long attributes (block transfer)
PASSED

Reading 3 attributes

```
<_Data Qty="0003" >
  <Data>
```

```
    <OctetString
Value="\ZFE0GFVPWPIHMJIRTWKOUQOUJBBJYYCESBZGCEOZPGIPOVWGTEMXPWVIJTTPNDQKPNJCTTJO
CNCCPDUZOFHITBXPZYOFHZYQQRTHVHCHLNWXGMFKEPWTOTDBHIFEGIONFJASESARNWEJWFHBYAYUGMHU
PXNVLNSBDPGIUSBUFSTFIVERQEBXZPUKXHCIFXOQECSSNIHOQNFEBYJONLYLMCQMWXBBPAHYWGWO
HICPTEETSUIOEESRCXBPLWEOBQYOTWSGUOUEVZQA0HHDWTKNMNLSVRDKIYCLSHUWDBMGXYSRFBBSZO
XRGJRYVWPBYWIXJRFGFDSRVKWXDLJHKEXMTHCEUEKAWYHPUMTHASPFSDWXZWUIEYIEDWQHIWBMPLV
XCVVUVDGDJHAHVYVBPBCOKKKVIDTHQQUDUSIFABAHRIQJTGXWSQEXKIBROKKABQAPISYHIFYLAAMOD
NDCVGPOTDRMDIGPZQLPKFEPQHGZW" />
```

```
    </Data>
    <Data>
      <OctetString
Value="\ZFOGFVWPWIHMJIRTWKOUQOUJBBJYYCESBZGCEOZPGIPOVWGTEMXPWVIJTTTPNDQKPNJCTTJO
CNCCPDUZOFHITBXPZYOFHZYQQRVHCHLNWXGMFKPWTOTDBHIFEGIONFJASESARNWEJWFHBYAYUGMHU
PXNVLNSBDPGIUSBUFSTFIVERQEBXZPUKXHXCFXOQECSSSTNIHOQNFEBYJONLYLMCQMWBPAHYWGWO
HICPTEETSUIOEESRCXBPLWEOBQYOTWSGUOUEVZQA0HHDWTKNMNLSVRDKIYCLSHUWDBMGXYSRFNBBJSZO
XRGJRYVWPBYWIXJRFGFDSRVKWXDLJHKEXMTHCEUEKKAWYHPUMTHASPFSDWXZWUIEYIEDWQHIWBPLV
XCVVUVDGDJHAHVYVBPBCOKKKVIDTHQQUDUSIFABAHIQJTGXWSQEXKIBROKKABQAPISYHIFYLAAMOD
NDCVGPTODRMDIGPZQLPKFEPQHGZW" />
      </Data>
    <Data>
      <OctetString
Value="\ZFOGFVWPWIHMJIRTWKOUQOUJBBJYYCESBZGCEOZPGIPOVWGTEMXPWVIJTTTPNDQKPNJCTTJO
CNCCPDUZOFHITBXPZYOFHZYQQRVHCHLNWXGMFKPWTOTDBHIFEGIONFJASESARNWEJWFHBYAYUGMHU
PXNVLNSBDPGIUSBUFSTFIVERQEBXZPUKXHXCFXOQECSSSTNIHOQNFEBYJONLYLMCQMWBPAHYWGWO
HICPTEETSUIOEESRCXBPLWEOBQYOTWSGUOUEVZQA0HHDWTKNMNLSVRDKIYCLSHUWDBMGXYSRFNBBJSZO
XRGJRYVWPBYWIXJRFGFDSRVKWXDLJHKEXMTHCEUEKKAWYHPUMTHASPFSDWXZWUIEYIEDWQHIWBPLV
XCVVUVDGDJHAHVYVBPBCOKKKVIDTHQQUDUSIFABAHIQJTGXWSQEXKIBROKKABQAPISYHIFYLAAMOD
NDCVGPTODRMDIGPZQLPKFEPQHGZW" />
      </Data>
    </_Data>
```

```
*****
Test Case 10 : Disconnect controls, 3 item(s)
*****
```

```
(1) Disconnect control
PASSED
  Disconnect in control mode 0
  Test control mode 1
  Test control mode 2
  Test control mode 3
  Test control mode 4
  Test control mode 5
  Test control mode 6
(2) Load Mgmt - Relay control 1
PASSED
(3) Load Mgmt - Relay control 2
PASSED
```

```
*****
Test Case 11 : Script tables, 2 item(s)
*****
```

```
(1) Tariffication script table
PASSED
  Tariffication script table (parameters 1): "01,02,03,04"
  Register activation - Energy (mask names): "01,02,03,04"
  Tariffication script table (parameters 2): "01,02,03,04"
  Register activation - Maximum Demand (mask names): "01,02,03,04"
  calendar_name_passive name: TOU_8E30
  activate_passive_calendar_time: 21-DEC-2022 14:50:17
  activate_passive_calendar_time: 21-DEC-2022 12:00:41
(2) MDI Reset / End of billing period script table
PASSED
```

Test Case 12 : Miscellaneous tests, 2 item(s)

- (1) Set/Get of long attribute
PASSED
- (5) COSEM logical device name
PASSED
Value: "MEL103071200021"

Test Case 13 : Application association, 18 item(s)

- (1) Wrong logical device Id
PASSED
- (2) Wrong client Id
PASSED
- (3) Opening an already opened application association
PASSED
- (4) Error on the Protocol version
PASSED
- (5) Application context missing
PASSED
- (6) Wrong application context
PASSED
- (7) Missing calling AP title in a ciphering AARQ
PASSED
- (8) Wrong system title in the Calling AP title
PASSED
- (9) ACSE requirement missing
PASSED
- (10) Wrong ACSE requirement
PASSED
- (11) Authentication mechanism missing
PASSED
- (12) Wrong authentication mechanism
PASSED
- (13) Authentication value missing
PASSED
- (14) Wrong authentication value
PASSED
- (15) User information missing
PASSED
- (16) Wrong dedicated key
PASSED
- (17) Incorrect proposed conformance bloc
PASSED
- (18) Incorrect negotiated conformance bloc
PASSED

Test Case 14 : xDLMS Services, 20 item(s)

- (1) Get without AA opening

PASSED
(2) Set without AA opening
PASSED
(3) Action without AA opening
PASSED
(4) Get with wrong inner tag
PASSED
(5) Set with wrong inner tag
PASSED
(6) Action with wrong inner tag
PASSED
(7) Error during block transfer with get
PASSED
(8) Error during block transfer with set
PASSED
(9) Get with wrong attribute id
PASSED
(10) Set with wrong attribute id
PASSED
(11) Action with wrong attribute id
PASSED
(12) Get with wrong access right
PASSED
(13) Set with wrong access right
PASSED
(14) Action with wrong access right
PASSED
(15) Get with wrong access selector
PASSED
(16) Get with wrong access parameters
PASSED
(17) Set with wrong data type
PASSED
(18) Action with wrong data type
PASSED
(19) Set with wrong data content
PASSED
(20) Action with wrong data content
PASSED

Test Case 15 : Security Activate, 3 item(s)

(1) Activate 1
PASSED
Pre set calendar_name_passive to CNP_C4EE using +A, -E
Pre set calendar_name_passive to CNP_263F using +A, -E tweaked A
Mngmt get calendar_name_passive using +A, -E, expect "CNP_C4EE"
Mngmt set calendar_name_passive to CNP_263F using +A, -E tweaked A
Mngmt get calendar_name_passive using +A, -E, expect "CNP_C4EE"
Mngmt set security_policy attribute to 0
(2) Activate 2
PASSED
Pre set calendar_name_passive to CNP_0209 using -A, +E

Pre set calendar_name_passive to CNP_339A using -A, +E tweaked E
Mngmt get calendar_name_passive using -A, +E, expect "CNP_0209"
Mngmt set calendar_name_passive to CNP_339A using -A, +E tweaked E
Mngmt get calendar_name_passive using -A, +E, expect "CNP_0209"
Mngmt set security_policy attribute to 0

(3) Activate 3

PASSED

Pre set calendar_name_passive to CNP_E4E7 using +A, +E
Pre set calendar_name_passive to CNP_203D using +A, +E tweaked A
Mngmt get calendar_name_passive using +A, +E, expect "CNP_E4E7"
Mngmt set calendar_name_passive to CNP_203D using +A, +E tweaked A
Mngmt get calendar_name_passive using +A, +E, expect "CNP_E4E7"
Pre set calendar_name_passive to CNP_6A11 using +A, +E tweaked E
Mngmt get calendar_name_passive using +A, +E, expect "CNP_E4E7"
Mngmt set calendar_name_passive to CNP_6A11 using +A, +E tweaked E
Mngmt get calendar_name_passive using +A, +E, expect "CNP_E4E7"
Mngmt set security_policy attribute to 0

Test Case 16 : Frame counter, 5 item(s)

(1) Unicast replay

PASSED

(2) Broadcast replay

PASSED

(3) Unicast Register

PASSED

(4) Broadcast Register

PASSED

(5) Received value

PASSED

Test Case 17 : Security global key transfer, 4 item(s)

(1) Global unicast encryption key transfer

PASSED

(2) Global broadcast encryption key transfer

PASSED

(3) Global authentication key transfer

PASSED

(4) All key transfer

PASSED

Test Case 18 : Secured service user information, 9 item(s)

(1) AARQ not encrypted

PASSED

(2) AARQ not authenticated

PASSED

(3) AARQ not encrypted not authenticated

PASSED

(4) AARQ with A security header

PASSED
(5) AARQ with E security header
PASSED
(6) AARQ with empty security header
PASSED
(7) AARQ with invalid frame counter
PASSED
(8) AARQ with invalid authentication
PASSED
(9) AARQ with invalid encryption
PASSED

Test Case 19 : Application association release service, 6 item(s)

(1) RLRQ invalid release request
PASSED
(2) RLRQ with missing user information
PASSED
(3) RLRQ non secure user information
PASSED
(4) RLRQ invalid security header
PASSED
(5) RLRQ invalid authentication
PASSED
(6) RLRQ invalid encryption
PASSED

Test Case 20 : Image transfer, 3 item(s)

(1) Basic
PASSED
Block size: 192
(2) Full
PASSED
Block size: 192
ImageSize: 3072, Blocks: 16, Last block size: 192
image_to_activate_info:
<Data>
 <Array Qty="0001" >
 <Structure Qty="0003" >
 <DoubleLongUnsigned Value="00000C00" />
 <OctetString
Value="\6.51.931.[(5.4.[(5.5.2)_(1.0.0)])_(7.14.0)].98231x/U" />
 <OctetString
Value="E1C9987D365FBEFFB78CEB34E024FA956CDA49A034AA932575BD78FE76BC369E" />
 </Structure>
 </Array>
 </Data>
(3) Full delayed
PASSED
Block size: 192
ImageSize: 3072, Blocks: 16, Last block size: 192

```
image_to_activate_info:
  <Data>
    <Array Qty="0001" >
      <Structure Qty="0003" >
        <DoubleLongUnsigned Value="00000C00" />
        <OctetString
Value="\6.51.931.[(5.4.[(5.5.2)_(1.0.0)])_(7.14.0)].98231x/U" />
        <OctetString
Value="E1C9987D365FBEFFB78CEB34E024FA956CDA49A034AA932575BD78FE76BC369E" />
        </Structure>
      </Array>
    </Data>
```

Test Case 21 : Push, 6 item(s)

- (1) Push data immediately
PASSED
- (2) Push data on interval
PASSED
- (3) Scheduled push of profile data
PASSED
- (4) Push with data block
PASSED
- (5) Security activate for push
PASSED
- (6) Frame counter for push
PASSED

Test Case 22 : Profiles, 7 item(s)

- (1) Data of billing period 1
PASSED
Selective access by entry not supported
- (2) Load profile with period 1
PASSED
- (3) Load Profile with period 2
PASSED
- (4) Load profile with period 1 time shift forward
PASSED
- (5) Load profile with period 2 time shift forward
PASSED
- (6) Load profile with period 1 time shift backward
PASSED
- (7) Load profile with period 2 time shift backward
PASSED

* CTI *

// Conformance Test Information (CTI) Template

// 2.3

```
Manufacturer = {
  Name = '\Mikroelektronika'
  ThreeLettersId = '\MEL'
}
```

```
DeviceUnderTest = {

  Type = '\MET600 21MID004'
  IDISDeviceType = 103
  IDISFunctionType = [Extension_D,Extension_L,Extension_M]
  SerialNr = 12000021
  IPVersion = IPv6
  DataLinkLayer = G3
  EUI64Address = "4D454C6770B71B15"
  ConsumerInformationPush = TRUE
  SMSSupported = FALSE
  ClipCallSupported = FALSE
}
```

```
TestOptions = {
  PushDestination = '\[fe80:0:0:0:781d:ff:fe00:0]:61616'
}
```

```
ObjectModel =
{
  // Optional objects implemented
  OptionalObjects = '\
+ '1-0:0.9.1.255|1,' // Local Time (@86)
+ '1-0:0.9.2.255|1,' // Local Date (@90)
+ '0-2:96.3.10.255|70,' // Load Mgmt - Relay control 2 (@217)
+ '1-1:0.2.0.255|1,' // Active firmware identifier 1 (@420)
+ '1-1:0.2.8.255|1,' // Active firmware signature 1 (@424)
+ '1-2:0.2.0.255|1,' // Active firmware identifier 2 (@428)
+ '1-2:0.2.8.255|1,' // Active firmware signature 2 (@432)
+ '1-0:9.8.0.255|3,' // Apparent energy import (+VA) (QI+QIV) (@497)
+ '1-0:10.8.0.255|3,' // Apparent energy export (-VA) (QII+QIII) (@503)
+ '1-0:5.8.1.255|3,' // Reactive energy (QI) rate 1 (@606)
+ '1-0:5.8.2.255|3,' // Reactive energy (QI) rate 2 (@612)
+ '1-0:5.8.3.255|3,' // Reactive energy (QI) rate 3 (@618)
+ '1-0:5.8.4.255|3,' // Reactive energy (QI) rate 4 (@624)
+ '1-0:6.8.1.255|3,' // Reactive energy (QII) rate 1 (@630)
+ '1-0:6.8.2.255|3,' // Reactive energy (QII) rate 2 (@636)
+ '1-0:6.8.3.255|3,' // Reactive energy (QII) rate 3 (@642)
+ '1-0:6.8.4.255|3,' // Reactive energy (QII) rate 4 (@648)
+ '1-0:7.8.1.255|3,' // Reactive energy (QIII) rate 1 (@654)
+ '1-0:7.8.2.255|3,' // Reactive energy (QIII) rate 2 (@660)
+ '1-0:7.8.3.255|3,' // Reactive energy (QIII) rate 3 (@666)
+ '1-0:7.8.4.255|3,' // Reactive energy (QIII) rate 4 (@672)
+ '1-0:8.8.1.255|3,' // Reactive energy (QIV) rate 1 (@678)
+ '1-0:8.8.2.255|3,' // Reactive energy (QIV) rate 2 (@684)
+ '1-0:8.8.3.255|3,' // Reactive energy (QIV) rate 3 (@690)
+ '1-0:8.8.4.255|3,' // Reactive energy (QIV) rate 4 (@696)
+ '1-0:9.8.1.255|3,' // Apparent energy import (+VA) rate 1 (@702)
```

```

+ '1-0:9.8.2.255|3,' // Apparent energy import (+VA) rate 2 (@708)
+ '1-0:9.8.3.255|3,' // Apparent energy import (+VA) rate 3 (@714)
+ '1-0:9.8.4.255|3,' // Apparent energy import (+VA) rate 4 (@720)
+ '1-0:10.8.1.255|3,' // Apparent energy export (-VA) rate 1 (@726)
+ '1-0:10.8.2.255|3,' // Apparent energy export (-VA) rate 2 (@732)
+ '1-0:10.8.3.255|3,' // Apparent energy export (-VA) rate 3 (@738)
+ '1-0:10.8.4.255|3,' // Apparent energy export (-VA) rate 4 (@744)
+ '1-0:15.8.1.255|3,' // Active energy Combined total (|+A|+|-A|) rate 1
(@750)
+ '1-0:15.8.2.255|3,' // Active energy Combined total (|+A|+|-A|) rate 2
(@756)
+ '1-0:15.8.3.255|3,' // Active energy Combined total (|+A|+|-A|) rate 3
(@762)
+ '1-0:15.8.4.255|3,' // Active energy Combined total (|+A|+|-A|) rate 4
(@768)
+ '1-0:9.4.0.255|5,' // Demand Register 5 - Apparent energy import (+VA)
(@827)
+ '1-0:10.4.0.255|5,' // Demand Register 6 - Apparent energy export (-VA)
(@840)
+ '1-0:1.5.0.255|4,' // Last Average Demand Register 1 - Active energy
import (+A) (@853)
+ '1-0:2.5.0.255|4,' // Last Average Demand Register 2 - Active energy
export (-A) (@861)
+ '1-0:3.5.0.255|4,' // Last Average Demand Register 3 - Reactive energy
import (+R) (@869)
+ '1-0:4.5.0.255|4,' // Last Average Demand Register 4 - Reactive energy
export (-R) (@877)
+ '1-0:9.5.0.255|4,' // Last Average Demand Register 5 - Apparent energy
import (+VA) (@885)
+ '1-0:10.5.0.255|4,' // Last Average Demand Register 6 - Apparent energy
export (-VA) (@893)
+ '1-0:9.6.0.255|4,' // Maximum Demand Register 21 - Apparent energy import
(+VA) (@1061)
+ '1-0:9.6.1.255|4,' // Maximum Demand Register 22 - Apparent energy import
(+VA) - rate 1 (@1069)
+ '1-0:9.6.2.255|4,' // Maximum Demand Register 23 - Apparent energy import
(+VA) - rate 2 (@1077)
+ '1-0:9.6.3.255|4,' // Maximum Demand Register 24 - Apparent energy import
(+VA) - rate 3 (@1085)
+ '1-0:9.6.4.255|4,' // Maximum Demand Register 25 - Apparent energy import
(+VA) - rate 4 (@1093)
+ '1-0:10.6.0.255|4,' // Maximum Demand Register 26 - Apparent energy export
(-VA) (@1101)
+ '1-0:10.6.1.255|4,' // Maximum Demand Register 27 - Apparent energy export
(-VA) - rate 1 (@1109)
+ '1-0:10.6.2.255|4,' // Maximum Demand Register 28 - Apparent energy export
(-VA) - rate 2 (@1117)
+ '1-0:10.6.3.255|4,' // Maximum Demand Register 29 - Apparent energy export
(-VA) - rate 3 (@1125)
+ '1-0:10.6.4.255|4,' // Maximum Demand Register 30 - Apparent energy export
(-VA) - rate 4 (@1133)
+ '1-0:14.7.0.255|3,' // Instantaneous net frequency; any phase (@1450)
+ '1-0:9.7.0.255|3,' // Instantaneous apparent import power (+VA) (@1486)
+ '1-0:10.7.0.255|3,' // Instantaneous apparent export power (-VA) (@1492)

```

```
+ '1-0:16.24.0.255|5,' // Average Net Power (|+A|-|-A|) (@1511)
+ '1-0:13.7.0.255|3,' // Instantaneous Power factor (+A/+VA) (@1537)
+ '1-0:13.5.0.255|4,' // Last Average Power factor (+A/+VA) (@1543)
+ '1-0:13.3.0.255|4,' // Minimum Power factor (+A/+VA) (@1551)
+ '1-0:0.8.2.255|3,' // Measurement Period 3 for Instantaneous values
(@1559)
+ '0-0:20.0.0.255|19' // IEC local port setup - IEC Optical port (@2001)
```

```
InstanceExtraInfo = {
  LogicalName = '0-0:20.0.0.255'
  ClassId = 19
  AttributeExtraInfo = {
    AttributeId = 7
    SetData = '\<Data><OctetString Value="3132333435363738" /></Data>'
  }
  AttributeExtraInfo = {
    AttributeId = 8
    SetData = '\<Data><OctetString Value="3132333435363738" /></Data>'
  }
  AttributeExtraInfo = {
    AttributeId = 9
    SetData = '\<Data><OctetString Value="3132333435363738" /></Data>'
  }
}
```

```
InstanceExtraInfo = {
  // Current association (@9)
  LogicalName = '0-0:40.0.0.255'
  ClassId = 15
  AttributeExtraInfo = {
    // authentication_mechanism_name
    AttributeId = 6
    AccessRights = [GET,SET]
  }
  AttributeExtraInfo = {
    // secret
    AttributeId = 7
    SetData = '\<Data><OctetString Value = "3132333435363738" /></Data>'
    AccessRights = [SET]
  }
}
```

```
InstanceExtraInfo = {
  // Activity Calendar (@112)
  LogicalName = '0-0:13.0.0.255'
  ClassId = 20
  MethodExtraInfo = {
    // activate_passive_calendar
    MethodId = 1
    AccessRights = [ACTION]
  }
}
```

```
InstanceExtraInfo = {
```

```

// Register activation - Energy (@129)
LogicalName = '0-0:14.0.1.255'
ClassId = 6
  AttributeExtraInfo = {
    // register_assignment
    AttributeId = 2
    AccessRights = [GET,SET]
  }
}

InstanceExtraInfo = {
  // Register activation - Maximum Demand (@135)
  LogicalName = '0-0:14.0.2.255'
  ClassId = 6
  AttributeExtraInfo = {
    // register_assignment
    AttributeId = 2
    AccessRights = [GET,SET]
  }
}

InstanceExtraInfo = {
  // Tariffication script table (@141)
  LogicalName = '0-0:10.0.100.255'
  ClassId = 9
  MethodExtraInfo = {
    // execute
    MethodId = 1
    AccessRights = [ACTION]
  }
}

InstanceExtraInfo = {
  // End of billing period 1 scheduler (@152)
  LogicalName = '0-0:15.0.0.255'
  ClassId = 22
  AttributeExtraInfo = {
    // type
    AttributeId = 3
    AccessRights = [GET,SET]
  }
}

InstanceExtraInfo = {
  // Disconnect control scheduler (@170)
  LogicalName = '0-0:15.0.1.255'
  ClassId = 22
  AttributeExtraInfo = {
    // type
    AttributeId = 3
    AccessRights = [GET,SET]
  }
}

```



```
InstanceExtraInfo = {
  // Disconnecter Control Log (@193)
  LogicalName = '0-0:99.98.2.255'
  ClassId = 7
  AttributeExtraInfo = {
    // capture_objects
    AttributeId = 3
    AccessRights = [GET,SET]
  }
}
```

```
InstanceExtraInfo = {
  // Load Mgmt - Relay control 1 (@209)
  LogicalName = '0-1:96.3.10.255'
  ClassId = 70
  AttributeExtraInfo = {
    // control_mode
    AttributeId = 4
    AccessRights = [GET,SET]
  }
}
```

```
InstanceExtraInfo = {
  // Load Mgmt - Relay control 2 (@217)
  LogicalName = '0-2:96.3.10.255'
  ClassId = 70
  AttributeExtraInfo = {
    // control_mode
    AttributeId = 4
    AccessRights = [GET,SET]
  }
}
```

```
InstanceExtraInfo = {
  // Limiter (@225)
  LogicalName = '0-0:17.0.0.255'
  ClassId = 71
  AttributeExtraInfo = {
    // actions
    AttributeId = 11
    AccessRights = [GET,SET]
  }
}
```

```
InstanceExtraInfo = {
  // Standard Event Log (@301)
  LogicalName = '0-0:99.98.0.255'
  ClassId = 7
  AttributeExtraInfo = {
    // capture_objects
    AttributeId = 3
    AccessRights = [GET,SET]
  }
}
```

```

InstanceExtraInfo = {
  // Fraud Detection Log (@316)
  LogicalName = '0-0:99.98.1.255'
  ClassId = 7
  AttributeExtraInfo = {
    // capture_objects
    AttributeId = 3
    AccessRights = [GET,SET]
  }
}

InstanceExtraInfo = {
  // Communication Log (@331)
  LogicalName = '0-0:99.98.5.255'
  ClassId = 7
  AttributeExtraInfo = {
    // capture_objects
    AttributeId = 3
    AccessRights = [GET,SET]
  }
}

InstanceExtraInfo = {
  // Push action scheduler - Consumer Information (@351)
  LogicalName = '0-4:15.0.4.255'
  ClassId = 22
  AttributeExtraInfo = {
    // executed_script
    AttributeId = 2
    AccessRights = [GET,SET]
  }
  AttributeExtraInfo = {
    // type
    AttributeId = 3
    AccessRights = [GET,SET]
  }
}

InstanceExtraInfo = {
  // Image transfer (@388)
  LogicalName = '0-0:44.0.0.255'
  ClassId = 18
  AttributeExtraInfo = {
    // image_block_size
    AttributeId = 2
    AccessRights = [GET,SET]
  }
}

InstanceExtraInfo = {
  // Image transfer activation scheduler (@401)
  LogicalName = '0-0:15.0.2.255'
  ClassId = 22

```

```

AttributeExtraInfo = {
    // executed_script
    AttributeId = 2
    AccessRights = [GET,SET]
}
AttributeExtraInfo = {
    // type
    AttributeId = 3
    AccessRights = [GET,SET]
}
}

InstanceExtraInfo = {
    // Load profile with period 1 i.e. General Load Profile (@1146)
    LogicalName = '1-0:99.1.0.255'
    ClassId = 7
    AttributeExtraInfo = {
        // profile_entries
        AttributeId = 8
        AccessRights = [GET,SET]
    }
}

InstanceExtraInfo = {
    // Load profile with period 2 i.e. Daily Values Profile (@1161)
    LogicalName = '1-0:99.2.0.255'
    ClassId = 7
    AttributeExtraInfo = {
        // profile_entries
        AttributeId = 8
        AccessRights = [GET,SET]
    }
}

InstanceExtraInfo = {
    // Power Failure Event Log (@1325)
    LogicalName = '1-0:99.97.0.255'
    ClassId = 7
    AttributeExtraInfo = {
        // capture_objects
        AttributeId = 3
        AccessRights = [GET,SET]
    }
}

InstanceExtraInfo = {
    // Power Quality Log (@1340)
    LogicalName = '0-0:99.98.4.255'
    ClassId = 7
    AttributeExtraInfo = {
        // capture_objects
        AttributeId = 3
        AccessRights = [GET,SET]
    }
}

```

```

}

InstanceExtraInfo = {
  // M-Bus client channel 1 (@1574)
  LogicalName = '0-1:24.1.0.255'
  ClassId = 72
  MethodExtraInfo = {
    // capture
    MethodId = 3
    AccessRights = [ACTION]
  }
  MethodExtraInfo = {
    // reset_alarm
    MethodId = 4
    AccessRights = [ACTION]
  }
  MethodExtraInfo = {
    // synchronize_clock
    MethodId = 5
    AccessRights = [ACTION]
  }
  MethodExtraInfo = {
    // data_send
    MethodId = 6
    AccessRights = [ACTION]
  }
}

```

```

InstanceExtraInfo = {
  // M-Bus client channel 2 (@1596)
  LogicalName = '0-2:24.1.0.255'
  ClassId = 72
  MethodExtraInfo = {
    // capture
    MethodId = 3
    AccessRights = [ACTION]
  }
  MethodExtraInfo = {
    // reset_alarm
    MethodId = 4
    AccessRights = [ACTION]
  }
  MethodExtraInfo = {
    // synchronize_clock
    MethodId = 5
    AccessRights = [ACTION]
  }
  MethodExtraInfo = {
    // data_send
    MethodId = 6
    AccessRights = [ACTION]
  }
}

```

```
InstanceExtraInfo = {
  // M-Bus client channel 3 (@1618)
  LogicalName = '0-3:24.1.0.255'
  ClassId = 72
  MethodExtraInfo = {
    // capture
    MethodId = 3
    AccessRights = [ACTION]
  }
  MethodExtraInfo = {
    // reset_alarm
    MethodId = 4
    AccessRights = [ACTION]
  }
  MethodExtraInfo = {
    // synchronize_clock
    MethodId = 5
    AccessRights = [ACTION]
  }
  MethodExtraInfo = {
    // data_send
    MethodId = 6
    AccessRights = [ACTION]
  }
}
```

```
InstanceExtraInfo = {
  // M-Bus client channel 4 (@1640)
  LogicalName = '0-4:24.1.0.255'
  ClassId = 72
  MethodExtraInfo = {
    // capture
    MethodId = 3
    AccessRights = [ACTION]
  }
  MethodExtraInfo = {
    // reset_alarm
    MethodId = 4
    AccessRights = [ACTION]
  }
  MethodExtraInfo = {
    // synchronize_clock
    MethodId = 5
    AccessRights = [ACTION]
  }
  MethodExtraInfo = {
    // data_send
    MethodId = 6
    AccessRights = [ACTION]
  }
}
```

```
InstanceExtraInfo = {
  // M-Bus Value channel 1, instance 1 (@1662)
```

```

LogicalName = '0-1:24.2.1.255'
ClassId = 4
  AttributeExtraInfo = {
    // scaler_unit
    AttributeId = 3
    AccessRights = [GET,SET]
  }
  MethodExtraInfo = {
    // reset
    MethodId = 1
    AccessRights = [ACTION]
  }
}

InstanceExtraInfo = {
  // M-Bus Value channel 1, instance 2 (@1670)
  LogicalName = '0-1:24.2.2.255'
  ClassId = 4
  AttributeExtraInfo = {
    // scaler_unit
    AttributeId = 3
    AccessRights = [GET,SET]
  }
  MethodExtraInfo = {
    // reset
    MethodId = 1
    AccessRights = [ACTION]
  }
}

InstanceExtraInfo = {
  // M-Bus Value channel 1, instance 3 (@1678)
  LogicalName = '0-1:24.2.3.255'
  ClassId = 4
  AttributeExtraInfo = {
    // scaler_unit
    AttributeId = 3
    AccessRights = [GET,SET]
  }
  MethodExtraInfo = {
    // reset
    MethodId = 1
    AccessRights = [ACTION]
  }
}

InstanceExtraInfo = {
  // M-Bus Value channel 1, instance 4 (@1686)
  LogicalName = '0-1:24.2.4.255'
  ClassId = 4
  AttributeExtraInfo = {
    // scaler_unit
    AttributeId = 3
    AccessRights = [GET,SET]
  }
}

```

```

    }
    MethodExtraInfo = {
        // reset
        MethodId = 1
        AccessRights = [ACTION]
    }
}

InstanceExtraInfo = {
    // M-Bus Value channel 2, instance 1 (@1694)
    LogicalName = '0-2:24.2.1.255'
    ClassId = 4
    AttributeExtraInfo = {
        // scaler_unit
        AttributeId = 3
        AccessRights = [GET,SET]
    }
    MethodExtraInfo = {
        // reset
        MethodId = 1
        AccessRights = [ACTION]
    }
}

InstanceExtraInfo = {
    // M-Bus Value channel 2, instance 2 (@1702)
    LogicalName = '0-2:24.2.2.255'
    ClassId = 4
    AttributeExtraInfo = {
        // scaler_unit
        AttributeId = 3
        AccessRights = [GET,SET]
    }
    MethodExtraInfo = {
        // reset
        MethodId = 1
        AccessRights = [ACTION]
    }
}

InstanceExtraInfo = {
    // M-Bus Value channel 2, instance 3 (@1710)
    LogicalName = '0-2:24.2.3.255'
    ClassId = 4
    AttributeExtraInfo = {
        // scaler_unit
        AttributeId = 3
        AccessRights = [GET,SET]
    }
    MethodExtraInfo = {
        // reset
        MethodId = 1
        AccessRights = [ACTION]
    }
}

```

```

}

InstanceExtraInfo = {
  // M-Bus Value channel 2, instance 4 (@1718)
  LogicalName = '0-2:24.2.4.255'
  ClassId = 4
  AttributeExtraInfo = {
    // scaler_unit
    AttributeId = 3
    AccessRights = [GET,SET]
  }
  MethodExtraInfo = {
    // reset
    MethodId = 1
    AccessRights = [ACTION]
  }
}

```

```

InstanceExtraInfo = {
  // M-Bus Value channel 3, instance 1 (@1726)
  LogicalName = '0-3:24.2.1.255'
  ClassId = 4
  AttributeExtraInfo = {
    // scaler_unit
    AttributeId = 3
    AccessRights = [GET,SET]
  }
  MethodExtraInfo = {
    // reset
    MethodId = 1
    AccessRights = [ACTION]
  }
}

```

```

InstanceExtraInfo = {
  // M-Bus Value channel 3, instance 2 (@1734)
  LogicalName = '0-3:24.2.2.255'
  ClassId = 4
  AttributeExtraInfo = {
    // scaler_unit
    AttributeId = 3
    AccessRights = [GET,SET]
  }
  MethodExtraInfo = {
    // reset
    MethodId = 1
    AccessRights = [ACTION]
  }
}

```

```

InstanceExtraInfo = {
  // M-Bus Value channel 3, instance 3 (@1742)
  LogicalName = '0-3:24.2.3.255'
  ClassId = 4

```



```

AttributeExtraInfo = {
    // scaler_unit
    AttributeId = 3
    AccessRights = [GET,SET]
}
MethodExtraInfo = {
    // reset
    MethodId = 1
    AccessRights = [ACTION]
}
}

InstanceExtraInfo = {
    // M-Bus Value channel 3, instance 4 (@1750)
    LogicalName = '0-3:24.2.4.255'
    ClassId = 4
    AttributeExtraInfo = {
        // scaler_unit
        AttributeId = 3
        AccessRights = [GET,SET]
    }
    MethodExtraInfo = {
        // reset
        MethodId = 1
        AccessRights = [ACTION]
    }
}

InstanceExtraInfo = {
    // M-Bus Value channel 4, instance 1 (@1758)
    LogicalName = '0-4:24.2.1.255'
    ClassId = 4
    AttributeExtraInfo = {
        // scaler_unit
        AttributeId = 3
        AccessRights = [GET,SET]
    }
    MethodExtraInfo = {
        // reset
        MethodId = 1
        AccessRights = [ACTION]
    }
}

InstanceExtraInfo = {
    // M-Bus Value channel 4, instance 2 (@1766)
    LogicalName = '0-4:24.2.2.255'
    ClassId = 4
    AttributeExtraInfo = {
        // scaler_unit
        AttributeId = 3
        AccessRights = [GET,SET]
    }
    MethodExtraInfo = {

```

```

        // reset
        MethodId = 1
        AccessRights = [ACTION]
    }
}

InstanceExtraInfo = {
    // M-Bus Value channel 4, instance 3 (@1774)
    LogicalName = '0-4:24.2.3.255'
    ClassId = 4
    AttributeExtraInfo = {
        // scaler_unit
        AttributeId = 3
        AccessRights = [GET,SET]
    }
    MethodExtraInfo = {
        // reset
        MethodId = 1
        AccessRights = [ACTION]
    }
}

InstanceExtraInfo = {
    // M-Bus Value channel 4, instance 4 (@1782)
    LogicalName = '0-4:24.2.4.255'
    ClassId = 4
    AttributeExtraInfo = {
        // scaler_unit
        AttributeId = 3
        AccessRights = [GET,SET]
    }
    MethodExtraInfo = {
        // reset
        MethodId = 1
        AccessRights = [ACTION]
    }
}

InstanceExtraInfo = {
    // M-Bus Disconnect control scheduler (@1914)
    LogicalName = '0-1:15.0.1.255'
    ClassId = 22
    AttributeExtraInfo = {
        // type
        AttributeId = 3
        AccessRights = [GET,SET]
    }
}

InstanceExtraInfo = {
    // M-Bus Master Control log object 1 (@1941)
    LogicalName = '0-1:24.5.0.255'
    ClassId = 7
    AttributeExtraInfo = {

```

```

        // capture_objects
        AttributeId = 3
        AccessRights = [GET,SET]
    }
}

InstanceExtraInfo = {
    // M-Bus Master Control log object 2 (@1952)
    LogicalName = '0-2:24.5.0.255'
    ClassId = 7
    AttributeExtraInfo = {
        // capture_objects
        AttributeId = 3
        AccessRights = [GET,SET]
    }
}

InstanceExtraInfo = {
    // M-Bus Master Control log object 3 (@1963)
    LogicalName = '0-3:24.5.0.255'
    ClassId = 7
    AttributeExtraInfo = {
        // capture_objects
        AttributeId = 3
        AccessRights = [GET,SET]
    }
}

InstanceExtraInfo = {
    // M-Bus Master Control log object 4 (@1974)
    LogicalName = '0-4:24.5.0.255'
    ClassId = 7
    AttributeExtraInfo = {
        // capture_objects
        AttributeId = 3
        AccessRights = [GET,SET]
    }
}

InstanceExtraInfo = {
    // M-Bus Event Log (@1989)
    LogicalName = '0-0:99.98.3.255'
    ClassId = 7
    AttributeExtraInfo = {
        // capture_objects
        AttributeId = 3
        AccessRights = [GET,SET]
    }
}

InstanceExtraInfo = {
    // Push script table (@2139)
    LogicalName = '0-0:10.0.108.255'
    ClassId = 9
}

```

```

    AttributeExtraInfo = {
        // scripts
        AttributeId = 2
        AccessRights = [GET,SET]
    }
}

InstanceExtraInfo = {
    // Push action scheduler - Interval_1 (@2144)
    LogicalName = '0-1:15.0.4.255'
    ClassId = 22
    AttributeExtraInfo = {
        // executed_script
        AttributeId = 2
        AccessRights = [GET,SET]
    }
    AttributeExtraInfo = {
        // type
        AttributeId = 3
        AccessRights = [GET,SET]
    }
}

InstanceExtraInfo = {
    // Push action scheduler - Interval_2 (@2150)
    LogicalName = '0-2:15.0.4.255'
    ClassId = 22
    AttributeExtraInfo = {
        // executed_script
        AttributeId = 2
        AccessRights = [GET,SET]
    }
    AttributeExtraInfo = {
        // type
        AttributeId = 3
        AccessRights = [GET,SET]
    }
}

InstanceExtraInfo = {
    // Push action scheduler - Interval_3 (@2156)
    LogicalName = '0-3:15.0.4.255'
    ClassId = 22
    AttributeExtraInfo = {
        // executed_script
        AttributeId = 2
        AccessRights = [GET,SET]
    }
    AttributeExtraInfo = {
        // type
        AttributeId = 3
        AccessRights = [GET,SET]
    }
}

```

```

InstanceExtraInfo = {
  // Auto connect (@2163)
  LogicalName = '0-0:2.1.0.255'
  ClassId = 29
  AttributeExtraInfo = {
    // destination_list
    AttributeId = 6
    AccessRights = [GET,SET]
  }
}

// needed for conformance test.
InstanceExtraInfo =
{
  LogicalName = '0-0:29.1.0.255'
  ClassId = 91
  Version = 1

  AttributeExtraInfo =
  {
    AttributeId = 5
    SetData = '\' +
    '<Data>' +
    ' <Array Qty = "01">' +
    '   <Structure Qty = "02">' +
    '     <Unsigned Value = "00" />' +
    '     <OctetString Value =
"00112233445566778899AABBCCDDEEFF"/>' +
    '   </Structure>' +
    ' </Array>' +
    '</Data>'
    AccessRights = [SET]
  }
}

InstanceExtraInfo = {
  // Set value for Consumer Message Text
  LogicalName = '0-0:96.13.0.255'
  ClassId = 1
  AttributeExtraInfo = {
    AttributeId = 2
    SetData = '\<Data><OctetString Value="3132333435363738"
/></Data>'
  }
}

TestParameters = {

  ConnectDisconnectDelay = 5000
  ClientSystemTitle = '58585A0102030405'
}

```

```
ImageTransfer = {
  ImageIdentifier = '\MET600_OFqQzi77_000000'
  ImageFileName   = '\MET600_OFqQzi77_000000_Application_6.51.931.bin'
  Timeout         = 60000
}

PushTimeout = 60000
MinInterWPDUFramesDelay = 1100
CaptureDelay = 30000
ClipCallDuration = 12000

WakeUpDelay = 30000
DisconnectToSendSMSDelay = 5000
DataNotificationToDisconnectDelay = 5000
}
```

```
LocalSecurityElements = {
  Public = {
    ContextName = LONG_NAMES
    MechanismName = LOWEST_LEVEL_SECURITY
    Policy = NO_SECURITY
  }
  Management = {
    ContextName = LONG_NAMES_WITH_CIPHERING
    MechanismName = HIGH_LEVEL_SECURITY_GMAC
    Policy = AUTHENTICATION_AND_ENCRYPTION
    Password = '\12345678'
  }
  PreEstablished = {
    Policy = NO_SECURITY
    ServerMaxReceivePduSize = 1224
    CipheringStyle = GENERAL
  }
}
```

```
RemoteSecurityElements = {
  Public = {
    ContextName = LONG_NAMES
    MechanismName = LOWEST_LEVEL_SECURITY
    Policy = NO_SECURITY
  }
  Management = {
    ContextName = LONG_NAMES_WITH_CIPHERING
    MechanismName = HIGH_LEVEL_SECURITY_GMAC
    Policy = AUTHENTICATION_AND_ENCRYPTION
    Password = '\12345678'
  }
  PreEstablished = {
    Policy = AUTHENTICATION_AND_ENCRYPTION
    ServerMaxReceivePduSize = 1224
    CipheringStyle = GENERAL
  }
}
```

```
}  
}
```

```
SMSSecurityElements = {  
  PreEstablished = {  
    Policy = AUTHENTICATION_AND_ENCRYPTION  
    ServerMaxReceivePDUSize = 138  
    CipherringStyle = GENERAL  
  }  
}
```

```
HDLCPprofile = {  
  
  PhysicalLayer = {  
    OpeningMode = DIRECT_HDLC  
    HdlcBaud = 9600  
  }  
  DataLinkLayer = {  
    InactivityTimeout      = 120000  
    InterFrameTimeout      = 500  
    ResponseTimeout        = 5000  
    DISCToNDMTimeout      = 3000  
    AddressingSchemes      = [TWO_BYTES_ADDRESSING]  
    ServerLowerMACAddress  = 21  
    LastRecToNextSendDelay = 0  
  }  
  
  UIFrameDelay = 2000  
  
  UIFrameLength = 126  
  
}
```

```
TCPPProfile = {  
  ServerTCPPort = 4059  
  ResponseTimeout = 10000  
  ConnectTimeout = 30000  
  DisconnectToConnectDelay = 15000  
}
```

```
// Mandatory parameters of the ''Remote'' G3-PLC profile  
G3PLCProfile = {  
  FrequencyBand = CENELEC_A  
  ResponseTimeout = 40000  
  UDPPort = 61616  
  ConnectTimeout = 10000  
  PSK = "AB10341145111BC3C12DE8FF11142204"  
}
```

```
// END CTI_Template
```

```
*****
```

* Miscellaneous *

TestMode:	G3-PLC
Test Plan Signature:	A46C9F4C6C407A1AE595D8394F5BD244
Object Model: (20200831).xlsx	IDIS-S02-002 - object model Pack2 Ed2.0 - V2.29
DUT system title:	4D454C6770B71B15
Run number:	2046